

Contract | अनुबंध



Contract No | अनुबंध क्रमांक: GEMC-511687741218665

Generated Date | अनुबंध तिथि: 30-Dec-2023

Organisation Details | संगठन विवरण

Type | प्ररूप : Central Autonomous
Ministry | मंत्रालय : Ministry of Education
Department | विभाग : Department of Higher Education
Organisation Name | संगठन का नाम : Indian Institute of Technology (IIT)
Office Zone | कार्यालय क्षेत्र : Huaz Khas Delhi

Buyer Details | खरीदार विवरण

Designation | पद : Assistant Professor
Contact No. | संपर्क नंबर : -
Email ID | ईमेल आईडी : buycon100.iiti.dl@gembuyer.in
GSTIN | जीएसटीआईएन : -
Address | पता : Material Science and Engineering Department, IIT Delhi
Hauz Khas,,
SOUTH DELHI, DELHI-110016, India

Financial Approval Detail | वित्तीय स्वीकृति विवरण

IFD Concurrence | आईएफडी सहमति : No
Designation of Administrative Approval |
प्रशासनिक अनुमोदन का पदनाम : Assistant Professor
Designation of Financial Approval |
वित्तीय अनुमोदन का पदनाम : Assistant Professor

Paying Authority Details | भुगतान प्राधिकरण विवरण

Role : BUYER
Payment Mode |
भुगतान का तरीका : Offline
Designation | पद : Assistant Professor
Email ID | ईमेल आईडी : buycon100.iiti.dl@gembuyer.in
GSTIN | जीएसटीआईएन : -
Address | पता : Material Science and Engineering Department, IIT Delhi
Hauz Khas,,
South West delhi, DELHI-110016, India

Seller Details | विक्रेता विवरण

GeM Seller ID | जेम विक्रेता आईडी : A630180000109686
Company Name | कंपनी का नाम : B.K.TECHNOLOGIES
Contact No. | संपर्क नंबर : 08795477779
Email ID | ईमेल आईडी : manisha@bktindia.net
Address | पता : SEC N1/12,AASHIYANA COLONY,NEAR BIJNAUR RAILWAY CROSSING,NEAR HP PETROL PUMP,
Lucknow, UTTAR PRADESH-226012, -
MSME Registration number | एमएसएमई पंजीकरण संख्या : UDYAM-UP-50-0021722
MSE Social Category | एमएसई सामाजिक श्रेणी : General
MSE Gender | एमएसई लिंग श्रेणी : Male
GSTIN | जीएसटीआईएन : 09BLBPS5349R1Z5

*GST / Tax invoice to be raised in the name of | जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा - Buyer

Delivery Instructions | वितरण निर्देश : NA

Product Details | उत्पाद विवरण

#	Item Description आइटम विवरण	Ordered Quantity आइटम विवरण	Unit इकाई	Unit Price (INR) इकाई मूल्य (INR)	Tax Bifurcation (INR) कर विभाजन (INR)	Price (Inclusive of all Duties and Taxes in INR) मूल्य (INR में सभी शुल्क और कर सहित)
1	<p>Product Name उत्पाद का नाम : Eaton Online UPS of Rating 6.0 KVA With Battery Of Backup Time 30 Minutes Brand ब्रांड : Eaton Brand Type ब्रांड प्रकार : Registered Brand Catalogue Status कैटलॉग की स्थिति : OEM verified catalogue Selling As कैसे बेचा जा रहा है : OEM verified Reseller Category Name & Quadrant श्रेणी का नाम और चतुर्थांश : Online UPS (V2) (Q2) Model मॉडल : 6KVA (9E) HSN Code एचएसएन कोड : HSN not specified by seller</p>	1	pieces	120,000	NA	120,000
Total Order Value कुल ऑर्डर मूल्य (in INR)						120,000

Consignee Detail | परेषिती विवरण

S.No क्र.सं.	Consignee परेषिती	Item वस्तु	Lot No. लॉट नंबर	Quantity मात्रा	Delivery Start After दिनांक के बाद डिलीवरी शुरू करना है	Delivery To Be Completed By वितरण पूरा कब तक करना है
	Designation पद : Assistant Professor Email ID ईमेल आईडी : buycon100.iiti.dl@gembuyer.in					

1	Contact संपर्क : - GSTIN जीएसटीआईएन : - Address पता : Material Science and Engineering Department, IIT Delhi Hauz Khas,, SOUTH DELHI, DELHI-110016, India	Eaton Online UPS of Rating 6.0 KVA With Battery Of Backup Time 30 Minutes	-	1	30-Dec-2023	29-Mar-2024
Product Specification for Eaton Online UPS of Rating 6.0 KVA With Battery Of Backup Time 30 Minutes						
Specification विनिर्देश	Sub-Spec उप-विनिर्देश	Value मूल्य				
Generic	Rating in KVA	6.0 KVA				
	Switching Technology	IGBT-PWM				
	Input Voltage	AC Single phase 160V - 260V 50Hz				
	Output Voltage	AC Single phase 230V +/-1% 50 Hz				
	Warranty for UPS (Years)	2				
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS (Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021)	With Battery				
	Type of Battery (hint: NA in case Battery not provided)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest				
	Backup time (Minutes) (hint: NA in case battery not provided)	30 Minutes				
	Battery Make	Exide/ Quanta				
	Battery Model Number	NA				
	Battery capacity (Ah)	18				
	Weight of the Battery (kg)	5.8				
	Number of Batteries	16				
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time				
	Warranty for battery (Years) by Battery Manufucaturer/Brand hint: NA in case battery not provided	2				
	Accessories with Battery	NA				
Installation and Commissioning or Service	Installation and Commissioning (Covered in the Scope of Supply)	Provided				
	After sales service (Turn Around Time)	Within 24 hours,Within 48 hours,Within 7 days,NA				
	Preventive Maintenance (Hint: Mention Timeline if provided, NA if not provided)	NA				
	Other Services provided	PAN India service support on 24 x 7 basis				
Performance / Functional	Inbuilt isolation transformer	With				
	Overall Efficiency (%)	>/=90% with Inbuilt isolation transformer				
	Power Factor Load Supported	0.8 or better				
	Overload limit	20% Overload for minimum 10 minute,20% Overload for minimum 5 minute,50% Overload for minimum 1 minute,50% Overload for minimum 3 seconds				
	Total Harmonic Distortion(THD) (%)	3% Maximum @ 100% Linear Load				
	Other Functional Features	Crest factor on full non-linear load is not less than 3:1,Noise level (1 meter distance from UPS) should be less than 70dB,Input power factor at full output load leading to unity with active power factor correction (APFC) >/=0.92,Transient response time (for 100% load change,output must remain within +/-1% and recovery) as <20 milliseconds,Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD : 8 to 10 Hours,Maximum overshoot and Under shoot of output rated voltage (in percentage) (4%),Voltage Regulation from no load to full load (%) (< / = 2%),UPS input power factor better than 0.95 (at rated voltage)				
Accessories	Accessories	Paralleling kit (Hot Standby Configuration)				
Salient Features	Protection	Protection for under voltage at battery terminal,Protection of Over voltage,Short Circuit & over load at UPS output terminal,Over temperature protection				
	Metering	Input Voltage,Output Voltage,Input Frequency,Output Frequency				
	Alarms and Indications	Indicator for Mains presence,Indicator for Battery charging and discharging,Indicator for Output Over Load with Audible				

		Alarm,Indicator for Low Battery Voltage with Audible Alarm,Alarm for Over temperature,Alarm for Low Battery
	Additional Features	Pure Sinewave AC Output
Design / Construction	Type of Design / Construction	Floor Standing
	Form factor of UPS	NA (for Floor Standing)
	Enclosure (mm)	1.2 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP20
	DC Bus Voltage (In Volts)	192
	Other Constructional Features	Mains ON/OFF MCB,Battery ON/OFF MCB,Battery Fuse,Inverter reset push button,Static by pass facility,Manual by pass facility,Expandable rack facility,Shall be complete with rack rail kit for mounting of UPS in the rack and shall be housed in rugged enclosure made of steel sheet having 1.2 mm (minimum) thickness, aesthetically finished,duly pretreated and powder coated,UPS shall be free from workmanship defects, sharp edges, nicks, scratches, burst, etc. All fasteners shall be fixed properly. The equipment shall be complete with all parts and all parts shall be functional,1 + 1 parallel redundant configuration facility on Rack mountable UPS UPS shall supply output power and charging current at the same time,NA
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	45 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	90 percent
Buyer Specific Requirement	Environmental Test Report Requirements	Damp Heat Test : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C
	Battery Test Report	Type Test Report as per relevant governing specifications from Govt Lab/NABL accredited lab
	Intended Applications	Network IT Equipment
	Other Requirements	ROHS compliance
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	NABL accredited lab
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

ePBG Detail ईपीबीजी विवरण	
NA	
<div> <div> Terms and Conditions नियम और शर्तें </div> <div> <div> 1. Special terms and conditions- Version:1 effective from 06-07-2022 </div> <div> 1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS (Version 2.0) with reference to Installation and Commissioning. <p>Seller's Responsibility: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.</p> <p>Buyer's Responsibility: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.</p> <p>The above is not applicable for the stores supplied without installation and commisioning.</p> <p>Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.</p> </div> <div> 2. General Terms and Conditions- </div> <div> 2.1 This contract is governed by the General Terms and Conditions, conditions stipulated to this Product/Service as provided in the Marketplace. 2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable </div> </div> </div> <div> Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose. </div>	

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।