

## Contract | अनुबंध



Contract No | अनुबंध क्रमांक: GEMC-511687775903684

Generated Date | अनुबंध तिथि: 08-Jan-2024

Organisation Details   संगठन विवरण		Buyer Details   खरीदार विवरण	
Type   प्रूप :	State Autonomous	Designation   पद :	Saqib Farooq
Ministry   मंत्रालय :	-	Contact No.   संपर्क नंबर :	0194-9797938-081
Department   विभाग :	SKUAST Kashmir	Email ID   ईमेल आईडी :	buyer13.skuas.jk@gembuyer.in
Organisation Name   संगठन का नाम :	SKUAST Kashmir	GSTIN   जीएसटीआईएन :	-
Office Zone   कार्यालय क्षेत्र :	Jammu and Kashmir	Address   पता :	Wadura, Sopore, BARAMULLA, JAMMU & KASHMIR-193201, India

Financial Approval Detail   वित्तीय स्वीकृति विवरण		Paying Authority Details   भुगतान प्राधिकरण विवरण	
IFD Concurrence   आईएफडी सहमति :	No	Role:	PAO
Designation of Administrative Approval   प्रशासनिक अनुमोदन का पदनाम :	Director Research	Payment Mode   भुगतान का तरीका:	Offline
Designation of Financial Approval   वित्तीय अनुमोदन का पदनाम :	Comptroller	Designation   पद :	Surjeel
		Email ID   ईमेल आईडी :	pao7.skuas.jk@gembuyer.in
		GSTIN   जीएसटीआईएन :	01AMRD13381E1DO
		Address   पता:	SKUAST-K, Shalimar, Srinagar., Srinagar, JAMMU & KASHMIR-191121, India

Seller Details   विक्रेता विवरण	
GeM Seller ID   जेम विक्रेता आईडी :	7BF1180000413185
Company Name   कंपनी का नाम :	B . COM
Contact No.   संपर्क नंबर :	09622905854
Email ID   ईमेल आईडी :	b.comqayoom@gmail.com
Address   पता :	NEAR DAWAT HOTEL,MAIN CHOWK BARAMULLA,BARAMULLA, Baramulla, JAMMU & KASHMIR-193101, -
MSME Registration number   एमएसएमई पंजीकरण संख्या :	UDYAM-JK-03-0025070
MSE Social Category   एमएसई सामाजिक श्रेणी :	General
MSE Gender   एमएसई लिंग श्रेणी :	Male
GSTIN   जीएसटीआईएन:	01AAOFB9567H1Z7

\*GST / Tax invoice to be raised in the name of | जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा - Buyer

Delivery Instructions | वितरण निर्देश : NA

Product Details | उत्पाद विवरण

#	Item Description   आइटम विवरण	Ordered Quantity   आइटम विवरण	Unit   इकाई	Unit Price (INR)   इकाई मूल्य (INR)	Tax Bifurcation (INR)   कर विभाजन (INR)	Price (Inclusive of all Duties and Taxes in INR)   मूल्य (INR में सभी शुल्क और कर सहित)
1	<p>Product Name   उत्पाद का नाम : microtek Online UPS of Rating 6.0 KVA With Battery Of Backup Time 120 Minutes</p> <p>Brand   ब्रांड : microtek</p> <p>Brand Type   ब्रांड प्रकार : Registered Brand</p> <p>Catalogue Status   कैटलॉग की स्थिति: OEM verified catalogue</p> <p>Selling As   कैसे बेचा जा रहा है : OEM verified Reseller</p> <p>Category Name &amp; Quadrant   श्रेणी का नाम और चतुर्थांश : Online UPS (V2) (Q2)</p> <p>Model   मॉडल: 7.5 KVA Imaxx</p> <p>HSN Code   एचएसएन कोड: HSN not specified by seller</p>	1	pieces	299,500	NA	299,500
Total Order Value   कुल ऑर्डर मूल्य (in INR)						299,500

Consignee Detail | परेषिती विवरण

S.No   क्र.सं.	Consignee   परेषिती	Item   वस्तु	Lot No.   लॉट नंबर	Quantity   मात्रा	Delivery Start After   दिनांक के बाद डिलीवरी शुरू करना है	Delivery To Be Completed By   वितरण पूरा कब तक करना है
1	<p>Designation   पद : Zahoor Ahmad Baba</p> <p>Email ID   ईमेल आईडी : con1.skuas.jk@gembuyer.in</p> <p>Contact   संपर्क : -9906493444-</p> <p>GSTIN   जीएसटीआईएन : -</p>	microtek Online UPS of Rating 6.0 KVA With Battery Of Backup Time	-	1	08-Jan-2024	07-Apr-2024

Address   पता : Wadura, Sopore, BARAMULLA, JAMMU & KASHMIR-193201, India	120 Minutes				
<b>Product Specification for microtek Online UPS of Rating 6.0 KVA With Battery Of Backup Time 120 Minutes</b>					
<b>Specification   विवरण</b>	<b>Sub-Spec   उप-विवरण</b>	<b>Value   मूल्य</b>			
Generic	Rating in KVA	6.0 KVA			
	Switching Technology	IGBT-PWM			
	Input Voltage	AC Single phase 160V - 260V 50Hz			
	Output Voltage	AC Single phase 230V +/-1% 50 Hz			
	Warranty for UPS (Years)	3			
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS ( Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021 )	With Battery			
	Type of Battery (hint: NA in case Battery not provided)	SMF-VRLA conforming to JIS:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest			
	Backup time (Minutes) (hint: NA in case battery not provided)	120 Minutes			
	Battery Make	Exide			
	Battery Model Number	EP100-12			
	Battery capacity (Ah)	100			
	Weight of the Battery (kg)	31			
	Number of Batteries	16			
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time			
	Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided	2			
Installation and Commissioning or Service	Accessories with Battery	NA			
	Installation and Commissioning ( Covered in the Scope of Supply)	Provided			
	After sales service ( Turn Around Time)	Within 7 days			
	Preventive Maintenance ( Hint: Mention Timeline if provided, NA if not provided)	NA			
Performance / Functional	Other Services provided	PAN India service support on 24 x 7 basis,AMC support available warranty,Availability of spares in close proximity (Spares should be easily available close to the site)			
	Inbuilt isolation transformer	With			
	Overall Efficiency (%)	>/=80% & <90% with Inbuilt isolation transformer			
	Power Factor Load Supported	0.8 or better			
	Overload limit	50% Overload for minimum 3 seconds			
	Total Harmonic Distortion(THD) (%)	3% Maximum @ 100% Linear Load			
	Other Functional Features	Crest factor on full non-linear load is not less than 3:1, Noise level (1 meter distance from UPS) should be less than 70dB, Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD : 8 to 10 Hours			
Accessories	Accessories	Rack for Batteries			
Salient Features	Protection	Protection for under voltage at battery terminal, Protection of Over voltage, Short Circuit & over load at UPS output terminal, Over temperature protection			
	Metering	Input Voltage, Output Voltage, Input Frequency, Output Frequency, Input Power, Output Power, Input Power Factor, Output Power Factor			
	Alarms and Indications	Indicator for Mains presence, Indicator for Battery charging and discharging, Indicator for Output Over Load with Audible Alarm, Indicator for Low Battery Voltage with Audible Alarm, Alarm for Over temperature, Alarm for Low Battery			
	Additional Features	Pure Sinewave AC Output			
Design /	Type of Design / Construction	Floor Standing			
	Form factor of UPS	NA (for Floor Standing)			
	Enclosure (mm)	1.2 mm Minimum Thickness of M.S. Sheet duly powder coated			

Construction	Degree of Protection	IP20
	DC Bus Voltage (In Volts)	192
	Other Constructional Features	Static by pass facility, Manual by pass facility
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	40 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	95 percent
Buyer Specific Requirement	Environmental Test Report Requirements	NA
	Battery Test Report	NA
	Intended Applications	Critical Infrastructure, Network IT Equipment, Medical Equipment, Support for Data Centers, Network operating centers, Security operation centers, State and District centers, Command and Control center etc., across the Country to provide impetus to the e-Governance services e.g. Public food distribution, e Way bill, Counseling, e-Office, IVFRT etc., services under Digital India Programme
	Other Requirements	ROHS compliance, KW rating shall be 0.8 time of KVA rating
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	OEM
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per MeitY (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

#### ePBG Detail | ईपीबीजी विवरण

NA

#### Terms and Conditions | नियम और शर्तें

##### 1. Special terms and conditions- Version:1 effective from 06-07-2022

1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS ( Version 2.0) with reference to Installation and Commissioning.

**Seller's Responsibility:** Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

**Buyer's Responsibility:** Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

##### 2. General Terms and Conditions-

2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।