

Contract | अनुबंध



Contract No | अनुबंध क्रमांक: GEMC-511687763576480

Generated Date | अनुबंध तिथि: 10-Jan-2024

Organisation Details संगठन विवरण Type प्ररूप : Central PSU Ministry मंत्रालय : Ministry of Finance Department विभाग : Department of Financial Services Organisation Name संगठन का नाम : Union Bank of India (UBI) Office Zone कार्यालय क्षेत्र : CENTRAL OFFICE DEPT OF INFORMATION TECHNOLOGY		Buyer Details खरीदार विवरण Designation पद : Manager Contact No. संपर्क नंबर : - Email ID ईमेल आईडी : buycon214.ubiu.wb@gembuyer.in GSTIN जीएसटीआईएन : - Address पता : Regional Office, Union Bank of India, UCP-23,Bengal Ambuja, City Centre,Durgapur, BARDHAMAN, WEST BENGAL-713216, India				
Financial Approval Detail वित्तीय स्वीकृति विवरण IFD Concurrence आईएफडी सहमति : No Designation of Administrative Approval Chief Manager प्रशासनिक अनुमोदन का पदनाम : Chief Manager Designation of Financial Approval Regional Head वित्तीय अनुमोदन का पदनाम : Regional Head		Paying Authority Details भुगतान प्राधिकरण विवरण Role: PAO Payment Mode Offline भुगतान का तरीका : Offline Designation पद : Chief Manager Email ID ईमेल आईडी : pay118.ubiu.wb@gembuyer.in GSTIN जीएसटीआईएन : 19AAACU0564G1ZE Field General Manager Office-Kolkata, Union Bank of India, Operations Department, Alepe Court" 1st floor, 225C, AJC Bose Road, Kolkata, WEST BENGAL-700020, India Address पता : Kolkata, WEST BENGAL-700020, India				
Seller Details विक्रेता विवरण GeM Seller ID जेम विक्रेता आईडी : 21BA180000412759 Company Name कंपनी का नाम : MAYA BATTERY & ELECTRICAL WORKS Contact No. संपर्क नंबर : 09830022466 Email ID ईमेल आईडी : info@mayabattery.com Address पता : 3,JADULAL MULLICK ROAD,KOLKATA, KOLKATA, WEST BENGAL-700006, - MSME Registration number एमएसएमई पंजीकरण संख्या : - GSTIN जीएसटीआईएन : 19ADTPB8580G1Z1						
*GST / Tax invoice to be raised in the name of जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा - Buyer						
Delivery Instructions वितरण निर्देश : NA						
Product Details उत्पाद विवरण						
#	Item Description आइटम विवरण	Ordered Quantity आइटम विवरण	Unit इकाई	Unit Price (INR) इकाई मूल्य (INR)	Tax Bifurcation (INR) कर विभाजन (INR)	Price (Inclusive of all Duties and Taxes in INR) मूल्य (INR में सभी शुल्क और कर सहित)
1	Product Name उत्पाद का नाम : NUMERIC Online UPS of Rating 3.0 KVA With Battery Of Backup Time 120 Minutes Brand ब्रांड : NUMERIC Brand Type ब्रांड प्रकार : Registered Brand Catalogue Status कैटलॉग की स्थिति : OEM verified catalogue Selling As कैसे बेचा जा रहा है : OEM verified Reseller Category Name & Quadrant श्रेणी का नाम और चतुर्थांश : Online UPS (V2) (Q2) Model मॉडल : 3 KVA ONFINITI FM - 120MIN (9600VAH) SMF VRLA HSN Code एचएसएन कोड : HSN not specified by seller	1	pieces	124,000	NA	124,000
Total Order Value कुल ऑर्डर मूल्य (in INR)						124,000
Consignee Detail परेषिती विवरण						
S.No क्र.सं.	Consignee परेषिती	Item वस्तु	Lot No. लॉट नंबर	Quantity मात्रा	Delivery Start After दिनांक के बाद डिलीवरी शुरू करना है	Delivery To Be Completed By वितरण पूरा कब तक करना है
	Designation पद : Manager Email ID ईमेल आईडी : buycon214.ubiu.wb@gembuyer.in Contact संपर्क : -	NUMERIC Online UPS of				

1	GSTIN जीएसटीआईएन : - Address पता : Regional Office, Union Bank of India, UCP-23,Bengal Ambuja, City Centre,Durgapur, BARDHAMAN, WEST BENGAL-713216, India	Rating 3.0 KVA With Battery Of Backup Time 120 Minutes	-	1	10-Jan-2024	09-Apr-2024
Product Specification for NUMERIC Online UPS of Rating 3.0 KVA With Battery Of Backup Time 120 Minutes						
Specification विनिर्देश	Sub-Spec उप-विनिर्देश	Value मूल्य				
Generic	Rating in KVA	3.0 KVA				
	Switching Technology	IGBT-PWM				
	Input Voltage	AC Single phase 160V - 260V 50Hz				
	Output Voltage	AC Single phase 230V +/-1% 50 Hz				
	Warranty for UPS (Years)	2				
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS (Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021)	With Battery				
	Type of Battery (hint: NA in case Battery not provided)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest				
	Backup time (Minutes) (hint: NA in case battery not provided)	120 Minutes				
	Battery Make	EXIDE / AMARARAJA				
	Battery Model Number	EP100-12 / 12AL100N				
	Battery capacity (Ah)	100				
	Weight of the Battery (kg)	32.5				
	Number of Batteries	8				
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time				
	Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided	2				
	Accessories with Battery	NA				
Installation and Commissioning or Service	Installation and Commissioning (Covered in the Scope of Supply)	Provided				
	After sales service (Turn Around Time)	Within 48 hours				
	Preventive Maintenance (Hint: Mention Timeline if provided, NA if not provided)	Quarterly				
	Other Services provided	PAN India service support on 24 x 7 basis,Availability of spares in close proximity (Spares should be easily available close to the site)				
Performance / Functional	Inbuilt isolation transformer	Without				
	Overall Efficiency (%)	>=90% & <94% without Inbuilt isolation transformer				
	Power Factor Load Supported	0.8 or better				
	Overload limit	50% Overload for minimum 3 seconds				
	Total Harmonic Distortion(THD) (%)	3% Maximum @ 100% Linear Load				
	Other Functional Features	Crest factor on full non-linear load is not less than 3:1,Noise level (1 meter distance from UPS) should be less than 70dB,Input power factor at full output load leading to unity with active power factor correction (APFC) >=0.92				
Accessories	Accessories	Rack for Batteries,Paralleling kit (Hot Standby Configuration)				
Salient Features	Protection	Protection for under voltage at battery terminal,Protection of Over voltage,Short Circuit & over load at UPS output terminal,Over temperature protection				
	Metering	Input Voltage,Output Voltage,Input Frequency,Output Frequency				
	Alarms and Indications	Indicator for Mains presence,Indicator for Battery charging and discharging,Indicator for Output Over Load with Audible Alarm,Indicator for Low Battery Voltage with Audible Alarm,Alarm for Over temperature,Alarm for Low Battery				
	Additional Features	Pure Sinewave AC Output				
	Provide URL of the catalogue	www.numericups.com				
	Type of Design / Construction	Floor Standing				

Design / Construction	Form factor of UPS	NA (for Floor Standing)
	Enclosure (mm)	1.0 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP20
	DC Bus Voltage (In Volts)	96
	Other Constructional Features	Battery Fuse, Inverter reset push button, UPS shall be free from workmanship defects, sharp edges, nicks, scratches, burst, etc. All fasteners shall be fixed properly. The equipment shall be complete with all parts and all parts shall be functional
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	40 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	90 percent
Buyer Specific Requirement	Environmental Test Report Requirements	NA
	Battery Test Report	NA
	Intended Applications	Critical Infrastructure, Network IT Equipment, Medical Equipment, Support for Data Centers, Network operating centers, Security operation centers, State and District centers, Command and Control center etc., across the Country to provide impetus to the e-Governance services e.g. Public food distribution, e Way bill, Counseling, e-Office, IVFRT etc., services under Digital India Programme, NA
	Other Requirements	ROHS compliance, KW rating shall be 0.8 time of KVA rating, NA
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	Govt Lab
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

ePBG Detail | ईपीबीजी विवरण

NA

Terms and Conditions | नियम और शर्तें

1. Special terms and conditions- Version:1 effective from 06-07-2022
- 1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS (Version 2.0) with reference to Installation and Commissioning.
- Seller's Responsibility: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.
- Buyer's Responsibility: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.
- The above is not applicable for the stores supplied without installation and commissioning.
- Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.
2. General Terms and Conditions-
- 2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.
- 2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।