

Contract | अनुबंध



Contract No | अनुबंध क्रमांक: GEMC-511687716139820

Generated Date | अनुबंध तिथि: 10-Jan-2024

Organisation Details संगठन विवरण	Buyer Details खरीदार विवरण
Type प्ररूप : State Autonomous	Designation पद : MO RAJKOT DAO
Ministry मंत्रालय : -	Contact No. संपर्क नंबर : 0281-2449038-
Department विभाग : Health & Family Welfare Department Gujarat	Email ID ईमेल आईडी : dao-ayush-rjkt@gujarat.gov.in
Organisation Name संगठन का नाम : N/A	GSTIN जीएसटीआईएन : -
Office Zone कार्यालय क्षेत्र : Indian system of medicine and homeopathy	Address पता : AYURVED BRANCH, DISTRICT PANCHAYAT, OPP. RACE COURSE, RAJKOT-360001, RAJKOT, GUJARAT-360001, India

Financial Approval Detail वित्तीय स्वीकृति विवरण	Paying Authority Details भुगतान प्राधिकरण विवरण
IFD Concurrence आईएफडी सहमति : No	Role : PAO
Designation of Administrative Approval प्रशासनिक अनुमोदन का पदनाम : directorate of Aayush	Payment Mode भुगतान का तरीका : Internet Banking
Designation of Financial Approval वित्तीय अनुमोदन का पदनाम : directorate of Aayush	Designation पद : DISTRICT AYURVED OFFICER RAJKOT
	Email ID ईमेल आईडी : dao-rajkot@gujarat.gov.in
	GSTIN जीएसटीआईएन : -
	Address पता : AYURVED BRANCH, DISTRICT PANCHAYAT, OPP. RACE COURSE, RAJKOT-360001, Rajkot, GUJARAT-360001, India

Seller Details विक्रेता विवरण
GeM Seller ID जेम विक्रेता आईडी : VYAC210003581371
Company Name कंपनी का नाम : Integrity World
Contact No. संपर्क नंबर : 07990972228
Email ID ईमेल आईडी : integrityworld2021@gmail.com
Address पता : FF FLATE NO.110, SADGURU COMPLEX,,GREEN CITY PARK,,NR BAPA SITARAM CHOK MAVDI VISTAR,,MAVADI, Rajkot, GUJARAT-360004, -
MSME Registration number एमएसएमई पंजीकरण संख्या : UDYAM-GJ-20-0031121
MSE Social Category एमएसई सामाजिक श्रेणी : General
MSE Gender एमएसई लिंग श्रेणी : Female
GSTIN जीएसटीआईएन : 24BBKPV9293A1ZA

*GST / Tax invoice to be raised in the name of | जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा - Consignee

Delivery Instructions | वितरण निर्देश : NA

#	Item Description आइटम विवरण	Ordered Quantity आइटम विवरण	Unit इकाई	Unit Price (INR) इकाई मूल्य (INR)	Tax Bifurcation (INR) कर विभाजन (INR)	Price (Inclusive of all Duties and Taxes in INR) मूल्य (INR में सभी शुल्क और कर सहित)
1	Product Name उत्पाद का नाम : Champion 150 KVA/240KVA/15 Minutes/61500 VAH UPS Brand ब्रांड : Champion Brand Type ब्रांड प्रकार : Registered Brand Catalogue Status कैटलॉग की स्थिति : Catalogue not verified by OEM Selling As कैसे बेचा जा रहा है : Reseller not verified by OEM Category Name & Quadrant श्रेणी का नाम और चतुर्थांश : Online Ups Modular Type (Q3) Model मॉडल : UPS-1200VA HSN Code एचएसएन कोड : HSN not specified by seller	4	pieces	4,870	NA	19,480
Total Order Value कुल ऑर्डर मूल्य (in INR)						19,480

Consignee Detail परेषिती विवरण						
S.No क्र.सं.	Consignee परेषिती	Item वस्तु	Lot No. लॉट नंबर	Quantity मात्रा	Delivery Start After दिनांक के बाद डिलीवरी शुरू करना है	Delivery To Be Completed By वितरण पूरा कब तक करना है
	Designation पद : MO RAJKOT DAO OFFICE Email ID ईमेल आईडी : mo-ayush-rjkt@gujarat.gov.in Contact संपर्क : 0281-2449038-	Champion 150				

1	GSTIN जीएसटीआईएन : - Address पता : AYURVED BRANCH, DISTRICT PANCHAYAT, OPP. RACE COURSE, RAJKOT-360001, RAJKOT, GUJARAT-360001, India	KVA/240KVA/15 Minutes/61500 VAH UPS	-	4	10-Jan-2024	25-Jan-2024
---	--	-------------------------------------	---	---	-------------	-------------

Product Specification for Champion 150 KVA/240KVA/15 Minutes/61500 VAH UPS

Specification विनिर्देश	Sub-Spec उप-विनिर्देश	Value मूल्य
GENERIC	Online UPS Modular type should support for Data Centres, Network operating centres, Security operation centres, State and District centres, Command and Control centre etc., across the Country to provide impetus to the e-Governance services e.g.Public food distribution, e Way bill, Counseling, e-Office, IVFRT etc., services under Digital India Programme	Yes
	Modular type UPS equipped with microprocessor/Digital signal processor and power modules, Power expansion facility, LCD/Digital display upto maximum expandable capacity, Cable entry, RS 232 port and SNMP port with each power module and with suitable rack (compatible maximum expandable) with complete lockable door having visibility for maximum expandable capacity	Yes
	Output power capacity including redundancy/Expandable (Rack facility) upto/Minimum backuptime (including redundancy) /Minimum VAH (VAH shall be calculate Battery voltage x Battery Ah x No. of batteries = Total VAH)	150 KVA/240KVA/15 Minutes/61500 VAH
	VAH tolerance	-1% of the defined capacity
	Hot swappable power module	Yes
	Battery module using two or more strings in parallel for redundant supply and battery module shall be fuse protected	Yes
	Inverter Technology	PWM with IGBT, double conversion
	Output wave form	Pure sine wave
	Country of origin for Inverter	India
	Noise level	< / = 55 dB
	Type of cool (Minimum 2 Fans for each power module)	Air cooled
	Parallel (Power Modules) load sharing redundant operation with all accessories	Yes
	Installation and commissioning	Yes
	UPS shall be supply with insallation and operation manual	Yes
INPUT	Input	AC Three Phase
	In put Voltage Range	320 V to AC to 470 V AC 3 Phase
	Input frequency range	50 +/-6% Hz
	Input power factor at full output load leading to unity with active power factor correction (APFC) (from 25% load to 100% load)	> / = 0.99
	Distortion (current)	< / = 3%
	UPS shall have DG set compatibility	Yes
OUTPUT	Output	AC Three Phase
	Out put voltage	380/400/415, 3 phase, 4 wire
	Voltage regulation (Steady state) at No load to full load, 0.6 lag to Unity PF, During entire back up time, Complete input voltage range	+ / - 1%
	Output powr factor	> / = 0.99
	Frequency	50 Hz +/-0.5 % Hz
	Minimum thickness (in mm) of Rack Enclosure for Modular UPS duly powder coated	1.2
	UPS shall be free from workmanship defects, sharp edges, nicks, scratches,burst, etc. All fasteners shall be fixed properly. The equipment shall be complete with all parts and all parts shall be functional	Yes
	UPS enclosure's degree of protection as per IS:13947 (Part 1)/1993 latest	IP21
	Standard quality Out put terminals shall be provided for output connection	Yes
	UPS shall have static and manual by pass facility	Yes
	UPS shall be supplied with required rated power cable (Copper)	5 Meters
	Total Harmonic Distrotion (THD) for 100% linear load	< 3%
	Total Harmonic Distrotion (THD) for 100% non-linear load	< 5%
	Operating tempeature	0 deg C to +40 deg C

CONSTRUCTION	Humidity	Upto 95% non-condensing
	Operational: 1000 meters above sea level at 40 deg. C maximum	Yes
	Crest factor on full non-linear load	Not less than 3:1
	Over all efficiency on rated full load of 0.8 PF (min.) AC output	>/=90%
	Inverter efficiency on rated full load of 0.8 PF (min.) AC output	>/=95%
	UPS shall withstand Over load capacity - 125% (Output with mains AC-AC)	for 10 Minutes (Minimum)
	UPS shall withstand Over load capacity - 150% (Output with mains AC-AC)	for 60 seconds (Minimum)
	UPS shall withstand Over load capacity - 125% (Output in battery run DC-AC)	for 30 Seconds (Minimum)
	UPS shall withstand Over load capacity - 150% (Output in battery run DC-AC)	for 30 seconds (Minimum)
	Load power factor 0.8 lagging to unity	Yes
	Transient response time (for 100% load change, output must remain within +/-1% and recovery)	<20 milli seconds
PROTECTION	Short circuit protection	Yes
	Over load protection	Yes
	Over temperature protection	Yes
	In put low/high voltage control	Yes
	DC low/high voltage trip	Yes
	Back feed protection for both, mains and bypass input	Yes
BATTERY	Battery shall conforming to JISC:8702(Pt.I,II&III) latest or equivalent BIS standard	Yes
	Battery type	SMF VRLA, Modular Hot swappable Battery modules
	Country of origin for Battery	India
	Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD	4 to 8 hours
	Battery charger (One in each power module) should be capable to charge battery on C10 rating	Yes
	Battery cutoff voltage during back up	Not less than 10.5 V
	Batteries shall supply with	With Modular cabinet having hot swappable battery
	Modular UPS shall supply with DC Cable from UPS to battery and batteries to UPS , Battery interlink cables, battery breaker	Yes
Meters, Indicators and Display	All the meters and display LCD/Digital type shall support for maximum expanadable capacity	Yes
	Input: Voltage line to line and line to neutral, currents, frequency, power factor display	Yes
	Bypass: Phase voltage, line to line voltge, frequency display	Yes
	UPS Output: Phase voltage, phase currents, line-line voltage, power factors, frequency display	Yes
	Local load: Load of each phase (% age of total load), Active power (KW), Apparent power (KVA), and Ractive power (KVAR) of each phase, load crest factor display	Yes
	Battery: Battery bus voltage, battery charge and discharge current, forecasted battery back up time, battery capacity (Ah)	Yes
	Parrallel load (for parallel operation system): Apparent power (KVA) of each phase, Active power (KW) of each phase, reactive power (KVAR) of each phase	Yes
	UPS shall have an indication for Mains on, Load on battery, Inverter, Battery level, Load level, Inverter over load	Yes
	UPS shall have audible alaram for over temperature, mains failure, battery low, inverter overload	Yes
	Communication interface: SNMP/MODBUS/HTTP/JAVA/UPSMON/SMTP etc., and 2 serial port USB/ RS232, RS485, 1 logic level port, 4 Dry contacts ports	Yes
	Log History storage facility with display (minium 200 events)	Yes
	Warranty for Modular UPS (on site comprehensive warranty) (in years)	others
	Warranty for battery (replacement warranty) (in years)	2
	After sales and complaint service	within 48 hours

WARRANTY AND SERVICES	PAN India service support on 24 x 7 basis	No
	AMC support available after 3 year warranty	Yes
	Quarterly preventive maintenance	Yes
	Manufacturer shall provide and support for installation, commissioning, spares, technical support all over India	No
	Availability of spares in close proximity (Spares should be easily available close to the site)	Yes
CERTIFICATIONS	ISO: 9001 Certification	No
	ISO: 14001 Certification	No
	Environmental compliance certificate RoHS	Yes
	CE Certification and marking	No
	UPS shall meet and comply with the General and safety requirements as per IEC:62040-1	Yes
	UPS shall meet and comply with the Electromagnetic compatibility (EMC) requirements as per IEC:62040-2	Yes
	Damp Heat Test : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C,two cycles of (12+12) hours each 2007)	No
	Dry Heat Test : in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs	Yes
	Cold Test : in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs.	No
	Availability of the Type Test Report from Central Govt. /NABL/ILAC Accredited lab covering all technical requirements.	Yes
All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand	Yes	

Note | टिप्पणी: Seller has given an undertaking that it has made arrangements for getting the stores from an authorized distributor / dealer / channel partner of the OEM of the offered product. At the time of delivery of goods, Seller will provide necessary chain documents (in the form of GST Invoice) to prove that the supplied goods are genuine and are being sourced from an authorized distributor / dealer / channel partner of the OEM. In case of any complaint about genuineness of the supplied products, Seller shall be responsible for providing genuine replacement supplies.

ePBG Detail | ईपीबीजी विवरण

NA

Terms and Conditions | नियम और शर्तें

1. General Terms and Conditions-

- 1.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.
- 1.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।