

## Contract | अनुबंध



Contract No | अनुबंध क्रमांक: GEMC-511687796209779

Generated Date | अनुबंध तिथि: 05-Jan-2024

Organisation Details   संगठन विवरण	Buyer Details   खरीदार विवरण
Type   प्ररूप : Central Autonomous Ministry   मंत्रालय : Ministry of Education Department   विभाग : Department of Higher Education Organisation Name   संगठन का नाम : Delhi University Office Zone   कार्यालय क्षेत्र : NORTH DELHI	Designation   पद : Convenor Central Purchase Committee Contact No.   संपर्क नंबर : 011-27667706- Email ID   ईमेल आईडी : buyer83.ud.dl@gembuyer.in GSTIN   जीएसटीआईएन : - Address   पता : Ramjas College, University Enclave, Maurice Nagar, Delhi-110007, CENTRAL DELHI, DELHI-110007, India

Financial Approval Detail   वित्तीय स्वीकृति विवरण	Paying Authority Details   भुगतान प्राधिकरण विवरण
IFD Concurrence   आईएफडी सहमति : No Designation of Administrative Approval   प्रशासनिक अनुमोदन का पदनाम : Principal Designation of Financial Approval   वित्तीय अनुमोदन का पदनाम : Principal	Role: PAO Payment Mode   भुगतान का तरीका : Offline Designation   पद : Bursar Email ID   ईमेल आईडी : pao27.ud.dl@gembuyer.in GSTIN   जीएसटीआईएन : - Address   पता : Ramjas College, University Enclave, Maurice Nagar, Delhi-110007, Central Delhi, DELHI-110007, India

Seller Details   विक्रेता विवरण	
GeM Seller ID   जेम विक्रेता आईडी : Y1X3210004572517 Company Name   कंपनी का नाम : D.S COMPUTER Contact No.   संपर्क नंबर : 08882220010 Email ID   ईमेल आईडी : dscomputers71@gmail.com Address   पता : GROUND FLOOR, ANUVRAT TOWER, RAN-121 A PLOT NO.29 ANUVRAT TOWER, WAZIRPUR, North West delhi, DELHI-110052, - MSME Registration number   एमएसएमई पंजीकरण संख्या : UDYAM-DL-05-0034189 MSE Social Category   एमएसई सामाजिक श्रेणी : General MSE Gender   एमएसई लिंग श्रेणी : Male GSTIN   जीएसटीआईएन : 07ANZPK2683B1ZO	

\*GST / Tax invoice to be raised in the name of | जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा - Buyer

Delivery Instructions | वितरण निर्देश : NA

Product Details   उत्पाद विवरण						
#	Item Description   आइटम विवरण	Ordered Quantity   आइटम विवरण	Unit   इकाई	Unit Price (INR)   इकाई मूल्य (INR)	Tax Bifurcation (INR)   कर विभाजन (INR)	Price (Inclusive of all Duties and Taxes in INR)   मूल्य (INR में सभी शुल्क और कर सहित)
1	<b>Product Name</b>   उत्पाद का नाम : microtek Online UPS of Rating 10.0 KVA With Battery Of Backup Time 120 Minutes <b>Brand</b>   ब्रांड : microtek <b>Brand Type</b>   ब्रांड प्रकार : Registered Brand <b>Catalogue Status</b>   कैटलॉग की स्थिति : OEM verified catalogue <b>Selling As</b>   कैसे बेचा जा रहा है : OEM verified Reseller <b>Category Name &amp; Quadrant</b>   श्रेणी का नाम और चतुर्थांश : Online UPS (V2) (Q2) <b>Model</b>   मॉडल : 10KVA IMAXX ( 1PH-1PH) <b>HSN Code</b>   एचएसएन कोड : HSN not specified by seller	1	pieces	172,500	NA	172,500
Total Order Value   कुल ऑर्डर मूल्य (in INR)						172,500

Consignee Detail   परेषिती विवरण						
S.No   क्र.सं.	Consignee   परेषिती	Item   वस्तु	Lot No.   लॉट नंबर	Quantity   मात्रा	Delivery Start After   दिनांक के बाद डिलीवरी शुरू करना है	Delivery To Be Completed By   वितरण पूरा कब तक करना है
	Designation   पद : Convenor Central Purchase Committee Email ID   ईमेल आईडी : buyer83.ud.dl@gembuyer.in					

1	Contact   संपर्क : 011-27667706- GSTIN   जीएसटीआईएन : - Address   पता : Ramjas College, University Enclave, Maurice Nagar, Delhi-110007, CENTRAL DELHI, DELHI-110007, India	microtek Online UPS of Rating 10.0 KVA With Battery Of Backup Time 120 Minutes	-	1	05-Jan-2024	04-Apr-2024
<b>Product Specification for microtek Online UPS of Rating 10.0 KVA With Battery Of Backup Time 120 Minutes</b>						
<b>Specification   विनिर्देश</b>	<b>Sub-Spec   उप-विनिर्देश</b>	<b>Value   मूल्य</b>				
Generic	Rating in KVA	10.0 KVA				
	Switching Technology	IGBT-PWM				
	Input Voltage	AC Single phase 160V - 260V 50Hz				
	Output Voltage	AC Single phase 230V +/-1% 50 Hz				
	Warranty for UPS (Years)	3				
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS ( Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021 )	With Battery				
	Type of Battery (hint: NA in case Battery not provided)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest				
	Backup time (Minutes) (hint: NA in case battery not provided)	120 Minutes				
	Battery Make	Exide				
	Battery Model Number	EP200-12				
	Battery capacity (Ah)	200				
	Weight of the Battery (kg)	63				
	Number of Batteries	16				
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time				
	Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided	2				
Accessories with Battery	NA					
Installation and Commissioning or Service	Installation and Commissioning ( Covered in the Scope of Supply)	Provided				
	After sales service ( Turn Around Time)	Within 7 days				
	Preventive Maintenance ( Hint: Mention Timeline if provided, NA if not provided)	NA				
	Other Services provided	PAN India service support on 24 x 7 basis,AMC support available warranty,Availability of spares in close proximity (Spares should be easily available close to the site)				
Performance / Functional	Inbuilt isolation transformer	With				
	Overall Efficiency (%)	>=80% & <90% with Inbuilt isolation transformer				
	Power Factor Load Supported	0.8 or better				
	Overload limit	20% Overload for minimum 5 minute				
	Total Harmonic Distortion(THD) (%)	3% Maximum @ 100% Linear Load				
	Other Functional Features	Crest factor on full non-linear load is not less than 3:1,Noise level (1 meter distance from UPS) should be less than 70dB,Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD : 8 to 10 Hours				
Accessories	Accessories	Rack for Batteries				
Salient Features	Protection	Protection for under voltage at battery terminal,Protection of Over voltage,Short Circuit & over load at UPS output terminal,Over temperature protection				
	Metering	Input Voltage,Output Voltage,Input Frequency,Output Frequency,Input Power,Output Power,Input Power Factor,Output Power Factor				
	Alarms and Indications	Indicator for Mains presence,Indicator for Battery charging and discharging,Indicator for Output Over Load with Audible Alarm,Indicator for Low Battery Voltage with Audible Alarm,Alarm for Over temperature,Alarm for Low Battery				
	Additional Features	Pure Sinewave AC Output				
	Type of Design / Construction	Floor Standing				

Design / Construction	Form factor of UPS	NA (for Floor Standing)
	Enclosure (mm)	1.2 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP20
	DC Bus Voltage (In Volts)	192
	Other Constructional Features	Static by pass facility,Manual by pass facility
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	40 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	90 percent
Buyer Specific Requirement	Environmental Test Report Requirements	NA
	Battery Test Report	NA
	Intended Applications	Critical Infrastructure,Network IT Equipment,Medical Equipment,Support for Data Centers, Network operating centers, Security operation centers, State and District centers, Command and Control center etc., across the Country to provide impetus to the e-Governance services e.g. Public food distribution, e Way bill, Counseling, e-Office, IVFRT etc., services under Digital India Programme
	Other Requirements	ROHS compliance,KW rating shall be 0.8 time of KVA rating
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	OEM
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

#### ePBG Detail | ईपीबीजी विवरण

NA

#### Terms and Conditions | नियम और शर्तें

##### 1. Special terms and conditions- Version:1 effective from 06-07-2022

1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS ( Version 2.0) with reference to Installation and Commissioning.

**Seller's Responsibility:** Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

**Buyer's Responsibility:** Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

**Note:** The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

##### 2. General Terms and Conditions-

2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।