

अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687747504051

अनुबंध तिथि | Generated Date : 01-Feb-2024

संगठन विवरण Organisation Details		खरीदार विवरण Buyer Details				
प्ररूप Type :	Central PSU	पद Designation :	Manager			
मंत्रालय Ministry :	Ministry of Finance	संपर्क नंबर Contact No. :	-			
विभाग Department :	Department of Financial Services	ईमेल आईडी Email ID :	buycon353.ubiu.gj@gembuyer.in			
संगठन का नाम Organisation Name :	Union Bank of India (UBI)	जीएसटीआईएन GSTIN :	-			
कार्यालय क्षेत्र Office Zone:	CENTRAL OFFICE DEPT OF INFORMATION TECHNOLOGY	पता Address :	Union Bank of India, GIFT City, Tower 1, 12th floor, Zonal Office Gandhinagar, GANDHI NAGAR, GUJARAT-382355, India			
वित्तीय स्वीकृति विवरण Financial Approval Detail		भुगतान प्राधिकरण विवरण Paying Authority Details				
आईएफडी सहमति IFD Concurrence :	No	Role:	PAO			
प्रशासनिक अनुमोदन का पदनाम Designation of Administrative Approval:	DGM	भुगतान का तरीका Payment Mode:	Offline			
वित्तीय अनुमोदन का पदनाम Designation of Financial Approval :	DGM	पद Designation :	Manager1			
		ईमेल आईडी Email ID :	pay42.ubiu.gj@gembuyer.in			
		जीएसटीआईएन GSTIN :	24AAACU0564G2ZM			
			Union Bank of India, 172/1 Premchand House, 1st Floor, Ashram Road, Ahmedabad-380009 Gujarat, Ahmedabad, GUJARAT-380009, India			
विक्रेता विवरण Seller Details						
जेम विक्रेता आईडी GeM Seller ID :	GOJW210002968023					
कंपनी का नाम Company Name :	ASHU ELECTRICALS					
संपर्क नंबर Contact No. :	09510109967					
ईमेल आईडी Email ID :	rajpravin61@gmail.com					
पता Address :	49,SHIKOTAR NAGAR-2,NEAR ALWANAKA,MANJLAPUR VADODARA, Vadodara, GUJARAT-390011, -					
एमएसएमई पंजीकरण संख्या MSME Registration number :	UDYAM-GJ-24-0021568					
एमएसई सामाजिक श्रेणी MSE Social Category :	SC					
एमएसई लिंग श्रेणी MSE Gender :	Female					
जीएसटीआईएन GSTIN:	24ABTFA8876C1Z1					
*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा GST / Tax invoice to be raised in the name of - Consignee						
वितरण निर्देश Delivery Instructions : at respective locations						
उत्पाद विवरण Product Details						
#	आइटम विवरण Item Description	आइटम विवरण Ordered Quantity	इकाई Unit	इकाई मूल्य (INR) Unit Price (INR)	कर विभाजन (INR) Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम Product Name : A V O Online UPS of Rating 5.0 KVA With Battery Of Backup Time 180 Minutes ब्रांड Brand : A V O ब्रांड प्रकार Brand Type : Registered Brand कैटलॉग की स्थिति Catalogue Status: OEM verified catalogue कैसे बेचा जा रहा है Selling As : OEM verified Reseller श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : Online UPS (V2) (Q2) मॉडल Model: HP1006 एचएसएन कोड HSN Code: HSN not specified by seller	2	pieces	205,150	NA	410,300
कुल ऑर्डर मूल्य Total Order Value (in INR)						410,300
परोक्षी विवरण Consignee Detail						
क्र.सं. S.No	परोक्षी Consignee	वस्तु Item	लॉट नंबर Lot No.	मात्रा Quantity	दिनांक के बाद डिलीवरी शुरू करना है Delivery Start After	वितरण पूरा कब तक करना है Delivery To Be Completed By
	पद Designation : Manager ईमेल आईडी Email ID : buycon353.ubiu.gj@gembuyer.in					

1	संपर्क Contact : - जीएसटीआईएन GSTIN : - पता Address : Union Bank of India, GIFT City, Tower 1, 12th floor, Zonal Office Gandhinagar, GANDHI NAGAR, GUJARAT-382355, India	A V O Online UPS of Rating 5.0 KVA With Battery Of Backup Time 180 Minutes	-	2	01-Feb-2024	01-May-2024
Product Specification for A V O Online UPS of Rating 5.0 KVA With Battery Of Backup Time 180 Minutes						
विनिर्देश Specification		उप-विनिर्देश Sub-Spec	मूल्य Value			
Generic	Rating in KVA		5.0 KVA			
	Switching Technology		IGBT-PWM			
	Input Voltage		AC Single phase 160V - 260V 50Hz			
	Output Voltage		AC Single phase 230V +/-1% 50 Hz			
	Warranty for UPS (Years)		3			
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS (Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021)		With Battery			
	Type of Battery (hint: NA in case Battery not provided)		SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest			
	Backup time (Minutes) (hint: NA in case battery not provided)		180 Minutes			
	Battery Make		EXIDE			
	Battery Model Number		EP12V120AH			
	Battery capacity (Ah)		120			
	Weight of the Battery (kg)		35			
	Number of Batteries		16			
	Minimum Guaranteed VAH		1600 X Per KVA X Per hour of backup time			
	Warranty for battery (Years) by Battery Manufucaturer/Brand hint: NA in case battery not provided		2			
	Accessories with Battery		NA			
Installation and Commissioning or Service	Installation and Commissioning (Covered in the Scope of Supply)		Provided			
	After sales service (Turn Around Time)		Within 48 hours			
	Preventive Maintenance (Hint: Mention Timeline if provided, NA if not provided)		Quarterly			
	Other Services provided		PAN India service support on 24 x 7 basis,Availability of spares in close proximity (Spares should be easily available close to the site)			
Performance / Functional	Inbuilt isolation transformer		With			
	Overall Efficiency (%)		>=80% & <90% with Inbuilt isolation transformer			
	Power Factor Load Supported		0.8 or better			
	Overload limit		20% Overload for minimum 5 minute,50% Overload for minimum 3 seconds			
	Total Harmonic Distortion(THD) (%)		3% Maximum @ 100% Linear Load			
	Other Functional Features		Noise level (1 meter distance from UPS) should be less than 70dB			
Accessories	Accessories		Rack for Batteries,Cabling 6 meters (input upto 3m and output upto 3m),Paralleling kit (Hot Standby Configuration),Paralleling kit for synchronizing (Parallel Redundant Load Sharing Configuration),SNMP Card (with Suitable Software) for communication,The UPS shall be complete with Trolley for battery bank,battery, Cables and connectors etc,NA			
Salient Features	Protection		Protection for under voltage at battery terminal,Protection of Over voltage,Short Circuit & over load at UPS output terminal,Over temperature protection			
	Metering		Input Voltage,Output Voltage,Input Current,Output Current,Input Frequency,Output Frequency,Input Power,Output Power,Input Power Factor,Output Power Factor,Battery Voltage and Current			
	Alarms and Indications		Indicator for Mains presence,Indicator for Battery charging and discharging,Indicator for Output Over Load with Audible Alarm,Indicator for Low Battery Voltage with Audible Alarm,Alarm for Over temperature,Alarm for Low Battery			
	Additional Features		Pure Sinewave AC Output			
	Type of Design / Construction		Floor Standing			

Design / Construction	Form factor of UPS	3 U (for 5 KVA/6 KVA/7.5 KVA)
	Enclosure (mm)	1.0 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP20
	DC Bus Voltage (In Volts)	192
	Other Constructional Features	NA
Operating Conditions	Minimum Operating Temperature	5 degree Celsius
	Maximum Operating Temperature	45 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	90 percent
Buyer Specific Requirement	Environmental Test Report Requirements	NA
	Battery Test Report	NA
	Intended Applications	NA
	Other Requirements	NA
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	OEM
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)
ईपीबीजी विवरण ePBG Detail		
NA		
नियम और शर्तें Terms and Conditions		
1. Special terms and conditions- Version:1 effective from 06-07-2022		
1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS (Version 2.0) with reference to Installation and Commissioning. Seller's Responsibility: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller. Buyer's Responsibility: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement. The above is not applicable for the stores supplied without installation and commissioning. Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.		
2. General Terms and Conditions-		
2.1 This contract is governed by the General Terms and Conditions , conditions stipulated to this Product/Service as provided in the Marketplace. 2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable		
नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है। Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.		