

## अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687783868220

अनुबंध तिथि | Generated Date : 01-Feb-2024

<b>संगठन विवरण   Organisation Details</b>		<b>खरीदार विवरण   Buyer Details</b>				
प्ररूप   Type :	Central PSU	पद   Designation :	Manager1			
मंत्रालय   Ministry :	Ministry of Finance	संपर्क नंबर   Contact No. :	0891-274995-			
विभाग   Department :	Department of Financial Services	ईमेल आईडी   Email ID :	buycon26.ubiu.ap@gembuyer.in			
संगठन का नाम   Organisation Name :	Union Bank of India (UBI)	जीएसटीआईएन   GSTIN :	-			
कार्यालय क्षेत्र   Office Zone:	CENTRAL OFFICE DEPT OF INFORMATION TECHNOLOGY	पता   Address :	Union Bank of India, Andhra Bank Building, 4rth Floor, FGMC Office-Union Bank of India, Koti, Womens College Road, Sultan Bazar, Hyderabad-500095. Telangana, HYDERABAD, TELANGANA-500095, India			
<b>वित्तीय स्वीकृति विवरण   Financial Approval Detail</b>		<b>भुगतान प्राधिकरण विवरण   Paying Authority Details</b>				
आईएफडी सहमति   IFD Concurrence :	No	Role:	PAO			
प्रशासनिक अनुमोदन का पदनाम   Designation of Administrative Approval:	dgm	भुगतान का तरीका   Payment Mode:	Offline			
वित्तीय अनुमोदन का पदनाम   Designation of Financial Approval :	dgm	पद   Designation :	Chief Manager			
		ईमेल आईडी   Email ID :	pay70.ubiu.ts@gembuyer.in			
		जीएसटीआईएन   GSTIN :	36AAACU0564G2ZH			
		पता   Address:	Union Bank of India, Andhra Bank Building, 4rth Floor, FGMC Office-Union Bank of India, Koti, Womens College Road, Sultan Bazar, Hyderabad-500095. Telangana, Hyderabad, TELANGANA-500095, India			
<b>विक्रेता विवरण   Seller Details</b>						
जेम विक्रेता आईडी   GeM Seller ID :	A8D8180000090745					
कंपनी का नाम   Company Name :	TECHSER POWER SOLUTIONS PRIVATE LIMITED					
संपर्क नंबर   Contact No. :	09448990444					
ईमेल आईडी   Email ID :	gem@techser.com					
पता   Address :	12/1,TECHSER HOUSE, JALAHALLI,MES RING ROAD, SHARADAMBANAGAR,BENGALURU, Bangalore, KARNATAKA-560013, -					
एमएसएमई पंजीकरण संख्या   MSME Registration number :	UDYAM-KR-03-0010269					
एमएसई सामाजिक श्रेणी   MSE Social Category :	General					
एमएसई लिंग श्रेणी   MSE Gender :	Male					
जीएसटीआईएन   GSTIN:	29AABCT0359D1ZI					
<b>*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा   GST / Tax invoice to be raised in the name of - Buyer</b>						
<b>वितरण निर्देश   Delivery Instructions : delivery to nakkalagutta branch</b>						
<b>उत्पाद विवरण   Product Details</b>						
#	आइटम विवरण   Item Description	आइटम विवरण   Ordered Quantity	इकाई   Unit	इकाई मूल्य (INR)   Unit Price (INR)	कर विभाजन (INR)   Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित)   Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम   <b>Product Name</b> : Techser Online UPS of Rating 5.0 KVA With Battery Of Backup Time 180 Minutes ब्रांड   <b>Brand</b> : Techser ब्रांड प्रकार   <b>Brand Type</b> : Registered Brand कैटलॉग की स्थिति   <b>Catalogue Status</b> : OEM verified catalogue कैसे बेचा जा रहा है   <b>Selling As</b> : OEM श्रेणी का नाम और चतुर्थांश   <b>Category Name &amp; Quadrant</b> : Online UPS (V2) (Q2) मॉडल   <b>Model</b> : TECHGLARE 5000 एचएसएन कोड   <b>HSN Code</b> : 8504	1	pieces	254,665	NA	254,665
कुल ऑर्डर मूल्य   Total Order Value (in INR)						254,665
<b>परेषिती विवरण   Consignee Detail</b>						
क्र.सं.   S.No	परेषिती   Consignee	वस्तु   Item	लॉट नंबर   Lot No.	मात्रा   Quantity	दिनांक के बाद डिलीवरी शुरू करना है   Delivery Start After	वितरण पूरा कब तक करना है   Delivery To Be Completed By

1	<p>पद   Designation : Manager1 ईमेल आईडी   Email ID : buycon26.ubiu.ap@gembuyer.in संपर्क   Contact : 0891-274995- जीएसटीआईएन   GSTIN : - पता   Address : Union Bank of India, Andhra Bank Building, 4rth Floor, FGMO Office-Union Bank of India, Koti, Womens College Road, Sultan Bazar, Hyderabad-500095. Telangana, HYDERABAD, TELANGANA-500095, India</p>	Techser Online UPS of Rating 5.0 KVA With Battery Of Backup Time 180 Minutes	-	1	01-Feb-2024	01-May-2024
Product Specification for Techser Online UPS of Rating 5.0 KVA With Battery Of Backup Time 180 Minutes						
विनिर्देश   Specification	उप-विनिर्देश   Sub-Spec	मूल्य   Value				
Generic	Rating in KVA	5.0 KVA				
	Switching Technology	IGBT-PWM				
	Input Voltage	AC Single phase 160V - 260V 50Hz				
	Output Voltage	AC Single phase 230V +/-1% 50 Hz				
	Warranty for UPS (Years)	3				
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS ( Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021 )	With Battery				
	Type of Battery (hint: NA in case Battery not provided)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest				
	Backup time (Minutes) (hint: NA in case battery not provided)	180 Minutes				
	Battery Make	EXIDE/QUANTA				
	Battery Model Number	EP/AL 100AH				
	Battery capacity (Ah)	100				
	Weight of the Battery (kg)	33				
	Number of Batteries	16				
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time				
	Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided	2				
	Accessories with Battery	NA				
Installation and Commissioning or Service	Installation and Commissioning ( Covered in the Scope of Supply)	Provided				
	After sales service ( Turn Around Time)	Within 48 hours				
	Preventive Maintenance ( Hint: Mention Timeline if provided, NA if not provided)	Quarterly				
	Other Services provided	PAN India service support on 24 x 7 basis,AMC support available warranty				
Performance / Functional	Inbuilt isolation transformer	With				
	Overall Efficiency (%)	>/=80% & <90% with Inbuilt isolation transformer				
	Power Factor Load Supported	0.8 or better				
	Overload limit	50% Overload for minimum 1 minute				
	Total Harmonic Distortion(THD) (%)	2% Maximum @ 100% Linear Load				
	Other Functional Features	Crest factor on full non-linear load is not less than 3:1				
Accessories	Accessories	The UPS shall be complete with Trolley for battery bank,battery, Cables and connectors etc,NA				
Salient Features	Protection	Protection for under voltage at battery terminal,Over temperature protection				
	Metering	Input Voltage,Output Voltage,Input Current,Output Current				
	Alarms and Indications	Indicator for Mains presence,Indicator for Battery charging and discharging,Alarm for Low Battery				
	Additional Features	Pure Sinewave AC Output				
	Provide URL of the catalogue	www.techser.com				
	Type of Design / Construction	Floor Standing				
	Form factor of UPS	NA (for Floor Standing)				
	Enclosure (mm)	1.2 mm Minimum Thickness of M.S. Sheet duly powder coated				

Design / Construction	Degree of Protection	IP21
	DC Bus Voltage (In Volts)	192
	Other Constructional Features	Mains ON/OFF MCB,UPS shall be free from workmanship defects, sharp edges, nicks, scratches, burst, etc. All fasteners shall be fixed properly. The equipment shall be complete with all parts and all parts shall be functional
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	40 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	90 percent
Buyer Specific Requirement	Environmental Test Report Requirements	Damp Heat Test : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C
	Battery Test Report	Type Test Report as per relevant governing specifications from Govt Lab/NABL accredited lab
	Intended Applications	Critical Infrastructure
	Other Requirements	ROHS compliance
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	OEM
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

ईपीबीजी विवरण | ePBG Detail

NA

नियम और शर्तें | Terms and Conditions

1. Special terms and conditions- Version:1 effective from 06-07-2022
- 1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS ( Version 2.0) with reference to Installation and Commissioning.
- Seller's Responsibility: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.
- Buyer's Responsibility: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.
- The above is not applicable for the stores supplied without installation and commissioning.
- Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.
2. General Terms and Conditions-
- 2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.
- 2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.