

## अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687761471994

अनुबंध तिथि | Generated Date : 22-Feb-2024

<b>संगठन विवरण   Organisation Details</b>	<b>खरीदार विवरण   Buyer Details</b>
प्ररूप   Type : Central Government मंत्रालय   Ministry : Ministry of Communications विभाग   Department : Department of Posts संगठन का नाम   Organisation Name : Department of Posts कार्यालय क्षेत्र   Office Zone : Wb Postal Circle, Department Of Posts, O/o The Ch Pmg, Wb Circle, Kolkata-700012	पद   Designation : ADPS-II संपर्क नंबर   Contact No. : 0353-2436550-436530 ईमेल आईडी   Email ID : staff.nbengal@indiapost.gov.in जीएसटीआईएन   GSTIN : 19AAAGS1213C1ZS पता   Address : O/o the Postmaster General, North Bengal Region, Kachari Road, Court More, Siliguri-734001, DARJILING, WEST BENGAL-734001, India

<b>वित्तीय स्वीकृति विवरण   Financial Approval Detail</b>	<b>भुगतान प्राधिकरण विवरण   Paying Authority Details</b>
आईएफडी सहमति   IFD Concurrence : No प्रशासनिक अनुमोदन का पदनाम   Designation of Administrative Approval : Postmaster General वित्तीय अनुमोदन का पदनाम   Designation of Financial Approval : Accounts Officer	Role: PAO भुगतान का तरीका   Payment Mode: Offline पद   Designation : Postmaster ईमेल आईडी   Email ID : siliguriho@indiapost.gov.in जीएसटीआईएन   GSTIN : 19AAAGS1213C1ZS पता   Address : Ladenla Road, O/o the SPOs, Darjeeling Division, Beside Darjeeling HPO, Darjeeling, WEST BENGAL-734101, India

<b>विक्रेता विवरण   Seller Details</b>
जेम विक्रेता आईडी   GeM Seller ID : Z3YV220006968214 कंपनी का नाम   Company Name : MAAC SOLUTION संपर्क नंबर   Contact No. : 09007215151 ईमेल आईडी   Email ID : maacsolution.ap@gmail.com पता   Address : 23, KHUDIRAM MORE, KHUDIRAM MORE, BALURGHAT, South Dinajpur (dakshin), WEST BENGAL-733101, - एमएसएमई पंजीकरण संख्या   MSME Registration number : UDYAM-WB-19-0004790 एमएसई सामाजिक श्रेणी   MSE Social Category : General एमएसई लिंग श्रेणी   MSE Gender : Male जीएसटीआईएन   GSTIN : 19AQPPP5293D1ZA

\*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Buyer

वितरण निर्देश | Delivery Instructions : NA

<b>उत्पाद विवरण   Product Details</b>						
#	आइटम विवरण   Item Description	आइटम विवरण   Ordered Quantity	इकाई   Unit	इकाई मूल्य (INR)   Unit Price (INR)	कर विभाजन (INR)   Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित)   Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम   Product Name : CyberPower Online UPS of Rating 6.0 KVA Without Battery Of Backup Time NA ब्रांड   Brand : CyberPower ब्रांड प्रकार   Brand Type : Registered Brand कैटलॉग की स्थिति   Catalogue Status : OEM verified catalogue कैसे बेचा जा रहा है   Selling As : OEM verified Reseller श्रेणी का नाम और चतुर्थांश   Category Name & Quadrant : Online UPS (V2) (Q2) मॉडल   Model : OLS6000ECXL एचएसएन कोड   HSN Code : HSN not specified by seller	8	pieces	56,694	NA	453,552
कुल ऑर्डर मूल्य   Total Order Value (in INR)						453,552

<b>परोक्षी विवरण   Consignee Detail</b>						
क्र.सं.   S.No	परोक्षी   Consignee	वस्तु   Item	लॉट नंबर   Lot No.	मात्रा   Quantity	दिनांक के बाद डिलीवरी शुरू करना है   Delivery Start After	वितरण पूरा कब तक करना है   Delivery To Be Completed By
	पद   Designation : BUYER-CONSIGNEE ईमेल आईडी   Email ID : staff.nbengal@indiapost.gov.in					

1	संपर्क   Contact : 0353-2436550-436530 जीएसटीआईएन   GSTIN : 19AAAGS1213C1ZS पता   Address : O/o the Postmaster General, North Bengal Region, Kachari Road, Court More, Siliguri-734001, DARJILING, WEST BENGAL-734001, India	CyberPower Online UPS of Rating 6.0 KVA Without Battery Of Backup Time NA	-	8	22-Feb-2024	22-May-2024
---	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------	---	---	-------------	-------------

**Product Specification for CyberPower Online UPS of Rating 6.0 KVA Without Battery Of Backup Time NA**

विनिर्देश   Specification	उप-विनिर्देश   Sub-Spec	मूल्य   Value
Generic	Rating in KVA	6.0 KVA
	Switching Technology	IGBT-PWM
	Input Voltage	AC Single phase 160V - 260V 50Hz
	Output Voltage	AC Single phase 230V +/-1% 50 Hz
	Warranty for UPS (Years)	2
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS ( Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021 )	Without Battery
	Type of Battery (hint: NA in case Battery not provided)	NA
	Backup time (Minutes) (hint: NA in case battery not provided)	NA
	Battery Make	NA
	Battery Model Number	NA
	Battery capacity (Ah)	0
	Weight of the Battery (kg)	0
	Number of Batteries	0
	Minimum Guaranteed VAH	NA
	Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided	NA
	Accessories with Battery	NA
Installation and Commissioning or Service	Installation and Commissioning ( Covered in the Scope of Supply)	Provided
	After sales service ( Turn Around Time)	Within 24 hours, Within 48 hours, Within 7 days, NA
	Preventive Maintenance ( Hint: Mention Timeline if provided, NA if not provided)	NA
	Other Services provided	PAN India service support on 24 x 7 basis, AMC support available warranty, Availability of spares in close proximity (Spares should be easily available close to the site), NA
Performance / Functional	Inbuilt isolation transformer	With
	Overall Efficiency (%)	>=90% with Inbuilt isolation transformer
	Power Factor Load Supported	0.8 or better
	Overload limit	20% Overload for minimum 10 minute, 20% Overload for minimum 5 minute, 50% Overload for minimum 1 minute, 50% Overload for minimum 3 seconds
	Total Harmonic Distortion (THD) (%)	3% Maximum @ 100% Linear Load
	Other Functional Features	Crest factor on full non-linear load is not less than 3:1, Noise level (1 meter distance from UPS) should be less than 70dB, Input power factor at full output load leading to unity with active power factor correction (APFC) >=0.92, Transient response time (for 100% load change, output must remain within +/-1% and recovery) as <20 milliseconds, Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD : 8 to 10 Hours, Maximum overshoot and Under shoot of output rated voltage (in percentage) (4%), Voltage Regulation from no load to full load (%) (< / = 2%), UPS input power factor better than 0.95 (at rated voltage)
Accessories	Accessories	NA
	Protection	Protection for under voltage at battery terminal, Protection of Over voltage, Short Circuit & over load at UPS output terminal, Over temperature protection
	Metering	Input Voltage, Output Voltage, Input Current, Output Current, Input Frequency, Output Frequency, Input Power, Output Power, Input Power Factor, Output Power Factor, Battery Voltage and Current

Salient Features	Alarms and Indications	Indicator for Mains presence,Indicator for Battery charging and discharging,Indicator for Output Over Load with Audible Alarm,Indicator for Low Battery Voltage with Audible Alarm,Alarm for Over temperature,Alarm for Low Battery
	Additional Features	Pure Sinewave AC Output,NA
Design / Construction	Type of Design / Construction	Floor Standing
	Form factor of UPS	NA (for Floor Standing)
	Enclosure (mm)	1.2 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP21
	DC Bus Voltage (In Volts)	192
	Other Constructional Features	Mains ON/OFF MCB,Battery ON/OFF MCB,Battery Fuse,Inverter reset push button,Manual by pass facility,Static by pass facility
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	40 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	90 percent
Buyer Specific Requirement	Environmental Test Report Requirements	Damp Heat Test : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C,two cycles of (12+12) hours each 2007),Dry Heat Test : in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs,Cold Test : in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs,NA
	Battery Test Report	Type Test Report as per relevant governing specifications from Govt Lab/NABL accredited lab
	Intended Applications	Critical Infrastructure,Network IT Equipment,Medical Equipment,Support for Data Centers, Network operating centers, Security operation centers, State and District centers, Command and Control center etc., across the Country to provide impetus to the e-Governance services e.g. Public food distribution, e Way bill, Counseling, e-Office, IVFRT etc., services under Digital India Programme,NA
	Other Requirements	ROHS compliance,KW rating shall be 0.8 time of KVA rating,NA
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	OEM
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

## ईपीबीजी विवरण | ePBG Detail

NA

## नियम और शर्तें | Terms and Conditions

### 1. Special terms and conditions- Version:1 effective from 06-07-2022

#### 1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS ( Version 2.0) with reference to Installation and Commissioning.

**Seller's Responsibility:** Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

**Buyer's Responsibility:** Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

**Note:** The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

### 2. General Terms and Conditions-

2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.