

## अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687711441844

अनुबंध तिथि | Generated Date : 01-Mar-2024

## संगठन विवरण | Organisation Details

प्रकार   Type :	State PSU
मंत्रालय   Ministry :	-
विभाग   Department :	Delhi Transco Limited (DTL)
संगठन का नाम   Organisation Name :	Delhi Transco Limited (DTL)

कार्यालय क्षेत्र | Office Zone:

## खरीदार विवरण | Buyer Details

पद   Designation :	MGR OM E1
संपर्क नंबर   Contact No. :	-
ईमेल आईडी   Email ID :	anil.kumar2@dtl.gov.in
जीएसटीआईएन   GSTIN :	07AABCD6342A1Z7

पता | Address : 220 KV Substation DIAL, Near Centaur Hotel, Terminal 3 Road, IGI Airport, New Delhi 110037, EAST DELHI, DELHI-110092, India

## वित्तीय स्वीकृति विवरण | Financial Approval Detail

आईएफडी सहमति   IFD Concurrence :	No
प्रशासनिक अनुमोदन का पदनाम	Manager O&M E2
Designation of Administrative Approval:	Manager O&M E2
वित्तीय अनुमोदन का पदनाम	Manager O&M E2

Designation of Financial Approval :

## भुगतान प्राधिकरण विवरण | Paying Authority Details

Role:	PAO
भुगतान का तरीका	Offline
Payment Mode:	
पद   Designation :	Dy. Manager (Fin) Banking
ईमेल आईडी   Email ID :	harish.biridi@dtl.gov.in
जीएसटीआईएन   GSTIN :	N
पता   Address:	OFFICE OF GM(T) C&MM, DELHI TRANSCO LTD, ROOM NO. 101 FIRST FLOOR, PRE-FABRICATED BUILDING, RAJGHAT POWER HOUSE, NEW DELHI, DELHI-110002, India

## विक्रेता विवरण | Seller Details

जेम विक्रेता आईडी   GeM Seller ID :	4XZQ200001825957
कंपनी का नाम   Company Name :	ALPS ENGINEERS
संपर्क नंबर   Contact No. :	09953156004
ईमेल आईडी   Email ID :	alpsengineers7@gmail.com
पता   Address :	1709, SECOND FLOOR, KINGSWAY CAMP, OUTRAM LANE, DELHI, North West delhi, DELHI-110009, -
एमएसएमई पंजीकरण संख्या   MSME Registration number :	UDYAM-DL-11-0003136
एप्सई शामाजिक श्रेणी   MSE Social Category :	General
एमएसई लिंग श्रेणी   MSE Gender :	Male
जीएसटीआईएन   GSTIN:	07DPTPS2813J1ZA

\*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Consignee

वितरण निर्देश | Delivery Instructions : NA

## उत्पाद विवरण | Product Details

#	आइटम विवरण   Item Description	आइटम विवरण   Ordered Quantity	इकाई   Unit	इकाई मूल्य (INR)   Unit Price (INR)	कर विभाजन (INR)   Tax Bifurcation (INR)	मूल्य (INR में सभी शुक्र और कर सहित)   Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम   Product Name : ELNOVA Online UPS of Rating 1.0 KVA With Battery Of Backup Time 60 Minutes ब्रांड   Brand : ELNOVA ब्रांड प्रकार   Brand Type : Registered Brand कैटलॉग की स्थिति   Catalogue Status: OEM verified catalogue कैसे बेचा जा रहा है   Selling As : OEM verified Reseller श्रेणी का नाम और चतुर्धारा   Category Name & Quadrant : Online UPS (V2) (Q2) मॉडल   Model: ES1004L एचएसएन कोड   HSN Code: HSN not specified by seller	2	pieces	24,990	NA	49,980
कुल ऑर्डर मूल्य   Total Order Value (in INR)						49,980

## परेषिती विवरण | Consignee Detail

क्र.सं.   S.No	परेषिती   Consignee	वस्तु   Item	लॉट नंबर   Lot No.	मात्रा   Quantity	दिनोंके बाद डिलीवरी शुरू करना है   Delivery Start After	वितरण पूरा कब तक करना है   Delivery To Be Completed By
	पद   Designation : AM Patparganj					

1	ईमेल आईडी Email ID : mk.garg@dtl.gov.in संपर्क Contact : - जीएसटीआईएन GSTIN : - पता Address : 220 KV SUB STATION PATTARGANJ NEAR MANDAWALI PHATAK, NEAR URJA VIHAAR, PATTARGANJ-110092, EAST DELHI, DELHI-110092, India	ELNOVA Online UPS of Rating 1.0 KVA With Battery Of Backup Time 60 Minutes	-	2	01-Mar-2024	30-May-2024
---	--	--	---	---	-------------	-------------

#### Product Specification for ELNOVA Online UPS of Rating 1.0 KVA With Battery Of Backup Time 60 Minutes

विवरण Specification	उप-विवरण Sub-Spec	मूल्य Value
Generic	Rating in KVA	1.0 KVA
	Switching Technology	IGBT-PWM
	Input Voltage	AC Single phase 160V - 260V 50Hz
	Output Voltage	AC Single phase 230V +/-1% 50 Hz
	Warranty for UPS (Years)	1
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS ( Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021 )	With Battery
	Type of Battery (hint: NA in case Battery not provided)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest
	Backup time (Minutes) (hint: NA in case battery not provided)	60 Minutes
	Battery Make	As per availability
	Battery Model Number	As per availability
	Battery capacity (Ah)	45
	Weight of the Battery (kg)	14
	Number of Batteries	3
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time
	Warranty for battery (Years) by Battery Manufacuturer/Brand hint: NA in case battery not provided	2
Installation and Commissioning or Service	Accessories with Battery	NA
	Installation and Commissioning ( Covered in the Scope of Supply)	Provided
	After sales service ( Turn Around Time)	Within 48 hours
	Preventive Maintenance ( Hint: Mention Timeline if provided, NA if not provided)	Quarterly
Performance / Functional	Other Services provided	PAN India service support on 24 x 7 basis,AMC support available warranty,Availability of spares in close proximity (Spares should be easily available close to the site),NA
	Inbuilt isolation transformer	With
	Overall Efficiency (%)	>/=80% & <90% with Inbuilt isolation transformer
	Power Factor Load Supported	0.8 or better
	Overload limit	50% Overload for minimum 3 seconds
	Total Harmonic Distortion(THD) (%)	3% Maximum @ 100% Linear Load
Accessories	Other Functional Features	Crest factor on full non-linear load is not less than 3:1
	Accessories	Rack for Batteries
Salient Features	Protection	Protection for under voltage at battery terminal,Protection of Over voltage,Short Circuit & over load at UPS output terminal,Over temperature protection
	Metering	Input Voltage,Output Voltage,Input Frequency,Output Frequency,Input Power,Output Power,Output Power Factor
	Alarms and Indications	Indicator for Mains presence,Indicator for Battery charging and discharging,Indicator for Output Over Load with Audible Alarm,Indicator for Low Battery Voltage with Audible Alarm,Alarm for Over temperature,Alarm for Low Battery
	Additional Features	Pure Sinewave AC Output,NA
Design / Construction	Type of Design / Construction	Floor Standing
	Form factor of UPS	NA (for Floor Standing)
	Enclosure (mm)	1.0 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP20

	DC Bus Voltage (In Volts)	36
	Other Constructional Features	UPS shall be free from workmanship defects, sharp edges, nicks, scratches, burst, etc. All fasteners shall be fixed properly. The equipment shall be complete with all parts and all parts shall be functional
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	40 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	90 percent
Buyer Specific Requirement	Environmental Test Report Requirements	NA
	Battery Test Report	NA
	Intended Applications	Support for Data Centers, Network operating centers, Security operation centers, State and District centers, Command and Control center etc., across the Country to provide impetus to the e-Governance services e.g. Public food distribution, e Way bill, Counseling, e-Office, IVFRT etc., services under Digital India Programme
	Other Requirements	ROHS compliance,KW rating shall be 0.8 time of KVA rating,NA
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	Govt Lab
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

#### ईपीबीजी विवरण | ePBG Detail

NA

#### नियम और शर्तें| Terms and Conditions

##### 1. Special terms and conditions- Version:1 effective from 06-07-2022

1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS ( Version 2.0) with reference to Installation and Commissioning.

**Seller's Responsibility:** Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

**Buyer's Responsibility:** Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

##### 2. General Terms and Conditions-

2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.