

अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687759940794

अनुबंध तिथि | Generated Date : 13-Mar-2024

| संगठन विवरण Organisation Details | खरीदार विवरण Buyer Details |
|---|---|
| प्ररूप Type : State Government मंत्रालय Ministry : - विभाग Department : Health & Family Welfare Department Gujarat संगठन का नाम Organisation Name : N/A कार्यालय क्षेत्र Office Zone : DISTRICT TB CENTER PETLAD DISTRICT ANAND | पद Designation : DISTRICT PROGRAM CO ORDINATOR RNTCP संपर्क नंबर Contact No. : 02697-224659- ईमेल आईडी Email ID : pay1.hfw.gujarat@gembuyer.in जीएसटीआईएन GSTIN : - पता Address : DISTRICT TB CENTRE, NEAR SS HOSPITAL, STATION ROAD ,PETLAD,, ANAND, GUJARAT-388450, India |

| वित्तीय स्वीकृति विवरण Financial Approval Detail | भुगतान प्राधिकरण विवरण Paying Authority Details |
|--|---|
| आईएफडी सहमति IFD Concurrence : No प्रशासनिक अनुमोदन का पदनाम Designation of Administrative Approval : Chief District Health Officer वित्तीय अनुमोदन का पदनाम Designation of Financial Approval : District TB Officer | Role: PAO भुगतान का तरीका Payment Mode: Internet Banking पद Designation : DISTRICT ACCOUNTANT ईमेल आईडी Email ID : pay1.hfw.gujarat@gembuyer.in जीएसटीआईएन GSTIN : - पता Address : DISTRICT TB CENTRE, NEAR SS HOSPITAL, STATION ROAD ,PETLAD,, ANAND, GUJARAT-388450, India |

| विक्रेता विवरण Seller Details |
|---|
| जेम विक्रेता आईडी GeM Seller ID : E0F0180000090869 कंपनी का नाम Company Name : Panchal Trading Company संपर्क नंबर Contact No. : 09824169966 ईमेल आईडी Email ID : panchaltradingcompany@yahoo.co.in पता Address : 26/A,3RD FLOOR INCOME TAX,AJANTA COMM. CENTER,ASHRAM ROAD, AHMEDABAD, GUJARAT-380009, - एमएसएमई पंजीकरण संख्या MSME Registration number : UDYAM-GJ-01-0222916 एमएसई सामाजिक श्रेणी MSE Social Category : OBC एमएसई लिंग श्रेणी MSE Gender : Male जीएसटीआईएन GSTIN : 24ABEPP0749E1ZW |

*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Consignee

वितरण निर्देश | Delivery Instructions : NA

| उत्पाद विवरण Product Details | | | | | | |
|--|--|-------------------------------|-------------|-------------------------------------|---|---|
| # | आइटम विवरण Item Description | आइटम विवरण Ordered Quantity | इकाई Unit | इकाई मूल्य (INR) Unit Price (INR) | कर विभाजन (INR) Tax Bifurcation (INR) | मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR) |
| 1 | उत्पाद का नाम Product Name : UTL Online UPS of Rating 2.0 KVA With Battery Of Backup Time 120 Minutes ब्रांड Brand : UTL ब्रांड प्रकार Brand Type : Registered Brand कैटलॉग की स्थिति Catalogue Status : OEM verified catalogue कैसे बेचा जा रहा है Selling As : OEM verified Reseller श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : Online UPS (V2) (Q2) मॉडल Model : (3KVA) एचएसएन कोड HSN Code : HSN not specified by seller | 2 | pieces | 92,950 | NA | 185,900 |
| कुल ऑर्डर मूल्य Total Order Value (in INR) | | | | | | 185,900 |

| परोक्षी विवरण Consignee Detail | | | | | | |
|----------------------------------|---|--------------|--------------------|-------------------|---|--|
| क्र.सं. S.No | परोक्षी Consignee | वस्तु Item | लॉट नंबर Lot No. | मात्रा Quantity | दिनांक के बाद डिलीवरी शुरू करना है Delivery Start After | वितरण पूरा कब तक करना है Delivery To Be Completed By |
| | पद Designation : DTCMO ईमेल आईडी Email ID : con59.hfwdg.gj@gembuyer.in | | | | | |

| | | | | | | |
|---|---|---|---|---|-------------|-------------|
| 1 | संपर्क Contact : 02697-224659- जीएसटीआईएन GSTIN : - पता Address : DISTRICT TB CENTRE, NEAR SS HOSPITAL, STATION ROAD ,PETLAD,, ANAND, GUJARAT-388450, India | UTL Online UPS of Rating 2.0 KVA With Battery Of Backup Time 120 Minutes | - | 2 | 13-Mar-2024 | 11-Jun-2024 |
|---|---|---|---|---|-------------|-------------|

Product Specification for UTL Online UPS of Rating 2.0 KVA With Battery Of Backup Time 120 Minutes

| विनिर्देश Specification | उप-विनिर्देश Sub-Spec | मूल्य Value |
|---|---|--|
| Generic | Rating in KVA | 2.0 KVA |
| | Switching Technology | IGBT-PWM |
| | Input Voltage | AC Single phase 160V - 260V 50Hz |
| | Output Voltage | AC Single phase 230V +/-1% 50 Hz |
| | Warranty for UPS (Years) | 3 |
| Battery/Backup Bank | Battery/Backup Bank Provided with Online UPS (Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021) | With Battery |
| | Type of Battery (hint: NA in case Battery not provided) | SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest |
| | Backup time (Minutes) (hint: NA in case battery not provided) | 120 Minutes |
| | Battery Make | NA |
| | Battery Model Number | NA |
| | Battery capacity (Ah) | 42 |
| | Weight of the Battery (kg) | 9.3 |
| | Number of Batteries | 6 |
| | Minimum Guaranteed VAH | 1600 X Per KVA X Per hour of backup time |
| | Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided | 2 |
| | Accessories with Battery | NA |
| Installation and Commissioning or Service | Installation and Commissioning (Covered in the Scope of Supply) | Provided |
| | After sales service (Turn Around Time) | Within 48 hours |
| | Preventive Maintenance (Hint: Mention Timeline if provided, NA if not provided) | Monthly |
| | Other Services provided | PAN India service support on 24 x 7 basis |
| Performance / Functional | Inbuilt isolation transformer | With |
| | Overall Efficiency (%) | >/=90% with Inbuilt isolation transformer |
| | Power Factor Load Supported | 0.8 or better |
| | Overload limit | 20% Overload for minimum 10 minute,20% Overload for minimum 5 minute,50% Overload for minimum 1 minute,50% Overload for minimum 3 seconds |
| | Total Harmonic Distortion(THD) (%) | 3% Maximum @ 100% Linear Load |
| | Other Functional Features | Crest factor on full non-linear load is not less than 3:1,Noise level (1 meter distance from UPS) should be less than 70dB,Input power factor at full output load leading to unity with active power factor correction (APFC) >/=0.92,Transient response time (for 100% load change,output must remain within +/-1% and recovery) as <20 milliseconds,Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD : 8 to 10 Hours,Maximum overshoot and Under shoot of output rated voltage (in percentage) (4%),Voltage Regulation from no load to full load (%) (< / = 2%),UPS input power factor better than 0.95 (at rated voltage) |
| Accessories | Accessories | Rack for Batteries,Cabling 6 meters (input upto 3m and output upto 3m),Paralleling kit (Hot Standby Configuration),Paralleling kit for synchronizing (Parallel Redundant Load Sharing Configuration),SNMP Card (with Suitable Software) for communication,The UPS shall be complete with Trolley for battery bank,battery, Cables and connectors etc,NA |
| | Protection | Protection for under voltage at battery terminal |
| | Metering | Input Voltage,Output Voltage |

| | | |
|----------------------------|--|--|
| Salient Features | Alarms and Indications | Indicator for Mains presence |
| | Additional Features | Pure Sinewave AC Output |
| Design / Construction | Type of Design / Construction | Floor Standing |
| | Form factor of UPS | NA (for Floor Standing) |
| | Enclosure (mm) | 1.2 mm Minimum Thickness of M.S. Sheet duly powder coated |
| | Degree of Protection | IP21 |
| | DC Bus Voltage (In Volts) | 96 |
| | Other Constructional Features | Mains ON/OFF MCB |
| Operating Conditions | Minimum Operating Temperature | 0 degree Celsius |
| | Maximum Operating Temperature | 45 degree Celsius |
| | Relative Humidity Non Condensing at 40 deg C | 95 percent |
| Buyer Specific Requirement | Environmental Test Report Requirements | NA |
| | Battery Test Report | NA |
| | Intended Applications | NA |
| | Other Requirements | ROHS compliance,KW rating shall be 0.8 time of KVA rating,NA |
| Reports And Certification | Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification | OEM |
| | Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand | Yes |
| | As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable | Yes (For UPS rating upto 10KVA) |

ईपीबीजी विवरण | ePBG Detail

NA

नियम और शर्तें | Terms and Conditions

1. Special terms and conditions- Version:1 effective from 06-07-2022

1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS (Version 2.0) with reference to Installation and Commissioning.

Seller's Responsibility: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

Buyer's Responsibility: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

2. General Terms and Conditions-

2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.