

## अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687731000424

अनुबंध तिथि | Generated Date : 13-Mar-2024

### संगठन विवरण | Organisation Details

प्ररूप | Type : Central Autonomous  
मंत्रालय | Ministry : Ministry of Education  
विभाग | Department : Department of Higher Education  
संगठन का नाम | Organisation Name Indian Institutes of Science Education and Research : (IIISER)  
कार्यालय क्षेत्र | Office Zone: Kolkata

### खरीदार विवरण | Buyer Details

पद | Designation : Assistant Registrar S and P  
संपर्क नंबर | Contact No. : -  
ईमेल आईडी | Email ID : buyer6.iiser.koaa@gembuyer.in  
जीएसटीआईएन | GSTIN : -  
पता | Address : PO- MOHANPUR, DISTRICT- NADIA, PIN- 741 246, WEST BENGAL, INDIA,  
NADIA, WEST BENGAL-741246, India

### वित्तीय स्वीकृति विवरण | Financial Approval Detail

आईएफडी सहमति | IFD Concurrence : No  
प्रशासनिक अनुमोदन का पदनाम | Designation of Administrative Approval: DIRECTOR  
वित्तीय अनुमोदन का पदनाम | Designation of Financial Approval : DIRECTOR

### भुगतान प्राधिकरण विवरण | Paying Authority Details

Role: PAO  
भुगतान का तरीका | Payment Mode: Offline  
पद | Designation : Assistant Registrar FNA  
ईमेल आईडी | Email ID : pao2.iiser.koaa@gembuyer.in  
जीएसटीआईएन | GSTIN : 19AAAAI2170E1Z0  
पता | Address: PO- MOHANPUR, DISTRICT- NADIA, PIN- 741 246, WEST BENGAL, INDIA,  
NADIA, WEST BENGAL-741246, India

### विक्रेता विवरण | Seller Details

जेम विक्रेता आईडी | GeM Seller ID : FE7A180000704094  
कंपनी का नाम | Company Name : ADLITE ELECTRICALS  
संपर्क नंबर | Contact No. : 09910113680  
ईमेल आईडी | Email ID : ceo@adliteelectricals.com  
पता | Address : MPL NO 4575/15,FLAT NO 302 T/F,AGARWAL ROAD,DARYAGANJ,  
DELHI, DELHI-110002, -  
एमएसएमई पंजीकरण संख्या | MSME Registration number : UDYAM-DL-01-0003665  
एमएसई सामाजिक श्रेणी | MSE Social Category : General  
एमएसई लिंग श्रेणी | MSE Gender : Female  
जीएसटीआईएन | GSTIN: 07AAYFA4521C1ZK

\*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Consignee

वितरण निर्देश | Delivery Instructions : ITEM IS TO BE DELIVERED TO THE OFFICE OF PROF. RANGEET BHATTACHARYYA, DPS, IISER KOLKATA

### उत्पाद विवरण | Product Details

#	आइटम विवरण   Item Description	आइटम विवरण   Ordered Quantity	इकाई   Unit	इकाई मूल्य (INR)   Unit Price (INR)	कर विभाजन (INR)   Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित)   Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम   Product Name : Eaton Online UPS of Rating 1.0 KVA With Battery Of Backup Time 15 Minutes ब्रांड   Brand : Eaton ब्रांड प्रकार   Brand Type : Registered Brand कैटलॉग की स्थिति   Catalogue Status: OEM verified catalogue कैसे बेचा जा रहा है   Selling As : OEM verified Reseller श्रेणी का नाम और चतुर्धारा   Category Name & Quadrant : Online UPS (V2) (Q2) मॉडल   Model: 9E-IN-1000 एचएसएन कोड   HSN Code: HSN not specified by seller	1	pieces	24,990	NA	24,990
कुल और मूल्य   Total Order Value (in INR)						24,990

### परेष्ठी विवरण | Consignee Detail

क्र.सं.   S.No	परेष्ठी   Consignee	वस्तु   Item	लॉट नंबर   Lot No.	मात्रा   Quantity	दिनेंक के बाद डिलीवरी शुरू करना है   Delivery Start After	वितरण पूरा कब तक करना है   Delivery To Be Completed By

1	<p>पद   Designation : Office Superintendent S and P ईमेल आईडी   Email ID : consigne1.iiser.koaa@gembuyer.in संपर्क   Contact : - जीएसटीआईएन   GSTIN : 19AAAAI2170E1Z0 पता   Address : PO- MOHANPUR, DISTRICT- NADIA, PIN- 741 246, WEST BENGAL, INDIA, NADIA, WEST BENGAL-741246, India</p>	<p>Eaton Online UPS of Rating 1.0 KVA With Battery Of Backup Time 15 Minutes</p>	-	1	13-Mar-2024	11-Jun-2024
---	---	--	---	---	-------------	-------------

#### Product Specification for Eaton Online UPS of Rating 1.0 KVA With Battery Of Backup Time 15 Minutes

विवरण   Specification	उप-विवरण   Sub-Spec	मूल्य   Value
Generic	Rating in KVA	1.0 KVA
	Switching Technology	IGBT-PWM
	Input Voltage	AC Single phase 160V - 260V 50Hz
	Output Voltage	AC Single phase 230V +/-1% 50 Hz
	Warranty for UPS (Years)	3
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS ( Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021 )	With Battery
	Type of Battery (hint: NA in case Battery not provided)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest
	Backup time (Minutes) (hint: NA in case battery not provided)	15 Minutes
	Battery Make	Exide or Quanta
	Battery Model Number	NA
	Battery capacity (Ah)	9
	Weight of the Battery (kg)	2
	Number of Batteries	2
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time
	Warranty for battery (Years) by Battery Manufucatuer/Brand hint: NA in case battery not provided	1
Installation and Commissioning or Service	Accessories with Battery	NA
	Installation and Commissioning ( Covered in the Scope of Supply)	Provided
	After sales service ( Turn Around Time)	Within 48 hours
	Preventive Maintenance ( Hint: Mention Timeline if provided, NA if not provided)	NA
Performance / Functional	Other Services provided	PAN India service support on 24 x 7 basis
	Inbuilt isolation transformer	Without
	Overall Efficiency (%)	>/=90% & <94% without Inbuilt isolation transformer
	Power Factor Load Supported	0.8 or better
	Overload limit	50% Overload for minimum 3 seconds
	Total Harmonic Distortion(THD) (%)	2% Maximum @ 100% Linear Load
	Other Functional Features	Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD : 8 to 10 Hours,UPS input power factor better than 0.95 (at rated voltage)
Accessories	Accessories	NA
Salient Features	Protection	Protection for under voltage at battery terminal,Protection of Over voltage,Over temperature protection
	Metering	Output Power,Input Power Factor,Output Power Factor,Battery Voltage and Current
	Alarms and Indications	Indicator for Battery charging and discharging,Alarm for Low Battery
	Additional Features	Pure Sinewave AC Output,NA
Design / Construction	Type of Design / Construction	Floor Standing
	Form factor of UPS	NA (for Floor Standing)
	Enclosure (mm)	1.2 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP20

	DC Bus Voltage (In Volts)	36
	Other Constructional Features	Battery Fuse,Static by pass facility,UPS shall be free from workmanship defects, sharp edges, nicks, scratches, burst, etc. All fasteners shall be fixed properly. The equipment shall be complete with all parts and all parts shall be functional
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	50 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	95 percent
Buyer Specific Requirement	Environmental Test Report Requirements	NA
	Battery Test Report	NA
	Intended Applications	Network IT Equipment,Medical Equipment
	Other Requirements	ROHS compliance,KW rating shall be 0.8 time of KVA rating
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	Govt Lab
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

#### ईपीबीजी विवरण | ePBG Detail

NA

#### नियम और शर्तें| Terms and Conditions

##### 1. Special terms and conditions- Version:1 effective from 06-07-2022

1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS ( Version 2.0) with reference to Installation and Commissioning.

**Seller's Responsibility:** Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

**Buyer's Responsibility:** Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

##### 2. General Terms and Conditions-

2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.