अनुबंध|Contract



संगठन विवरण|Organisation Details

अनुबंध क्रमांक|Contract No: GEMC-511687717694693 अनुबंध तिथि|Generated Date : 13-Mar-2024

खरीदार विवरण|Buyer Details

प्ररूप|Type : Central PSU मंत्रालय|Ministry : Ministry of Finance

विभाग | Department : Department of Financial Services संगठन का नाम | Organisation Name : Union Bank of India (UBI)

कार्यालय क्षेत्र | Office Zone: CENTRAL OFFICE DEPT OF INFORMATION TECHNOLOGY

पद|Designation: Senior Manager संपर्क नंबर|Contact No.: 080-22958287-

ईमेल आईडी|Email ID : buycon14.ubiu.ka@gembuyer.in

जीएसटीआईएन|GSTIN: -

Union Bank of India, FGMO Office, 10/A , Chandra Kiran Building, 1st Floor, Kasturba Road, Opp Cubbon Park Police

पता|Address : Station, Bangalore - 560001 Karnataka,

Station, Bangalore - 560001 Karnataka, BANGALORE, KARNATAKA-560001, India

वित्तीय स्वीकृति विवरण|Financial Approval Detail

आईएफडी सहमति|IFD Concurrence : No

प्रशासनिक अनुमोदन का पदनाम| Designation of Administrative Approval:

वित्तीय अनुमोदन का पदनाम।

Designation of Financial Approval :

deputy general manager

dgm

भुगतान प्राधिकरण विवरण|Paying Authority Details

Role: BUYER भुगतान का तरीका| Payment Mode: Offline

पद|Designation : Senior Manager

ईमेल आईडी|Email ID : buycon14.ubiu.ka@gembuyer.in

जीएसटीआईएन|GSTIN: 29AAACU0564G2ZC

Union Bank of India, FGMO Office, 10/A, Chandra Kiran Building, 1st Floor, Kasturba Road, Opp Cubbon Park Police

पता|Address: Station, Bangalore - 560001 Karnataka,

Bangalore, KARNATAKA-560001, India

विक्रैता विवरण|Seller Details

जेम विक्रैता आईडी|GeM Seller ID : E49B180000107808 कंपनी का नाम|Company Name : NUMAX ENERGY SOLUTIONS संपर्क नंबर|Contact No. : 09052766606

ईमेल आईडी|Email ID : numaxhyd@gmail.com

पता| Address : Plot 50 & 51 Narayanaswamy nagar,Cherlapally,Cherlapally,Hyderabad,

Hyderabad, TELANGANA-500051, -

एमएसएमई पंजीकरण संख्या|MSME Registration number : UDYAM-TS-20-0009920

एमएसई सामाजिक श्रेणी|MSE Social Category : General एमएसई लिंग श्रेणी|MSE Gender : Male

जीएसटीआईएन|GSTIN: 36AAIFN0814D1ZO

*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा|GST / Tax invoice to be raised in the name of - Consignee

वितरण निर्देश | Delivery Instructions : NA

उत्पाद विवरण|Product Details

#	आइटम विवरण Item Description	आइटम विवरण Ordered Quantity	इकाई Unit	इकाई मूल्य (INR) Unit Price (INR)	कर विभाजन (INR) Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम Product Name: NUMAX Online UPS of Rating 40.0 KVA Without Battery Of Backup Time NA ब्रांड Brand: NUMAX ब्रांड Brand: NUMAX ब्रांड प्रकार Brand Type: Registered Brand कैटलॉग की स्थिति Catalogue Status: OEM verified catalogue कैसे बेचा जा रहा है Selling As: OEM श्रेणी का नाम और चतुर्थांच Category Name & Quadrant: Online UPS (V2) (Q2) मॉडल Model: NX9940 एचएसएन कोड HSN Code: HSN not specified by seller	1	pieces	365,800	NA	365,800
क	नल ऑर्डर मल्य Total Order Value (in INR)					365.800

परेषिती विवरण|Consignee Detail

क्र.सं. S.No	परेषिती Consignee	वस्तु Item	लॉट नंबर Lot No.	मात्रा Quantity	दिनांक के बाद डिलीवरी शुरू करना है Delivery Start After	वितरण पूरा कब तक करना है Delivery To Be Completed By
l I	l			Į.		

पद Designation : Senior Manager ईमेल आईडी Email ID : buycon14.ubiu.ka@gembuyer.in संपर्क Contact : 080-22958287- जीएसटीआईएन GSTIN : - पता Address : Union Bank of India, FGMO Office, 10/A , Chandra Kiran Building, 1st Floor, Kasturba Road, Opp Cubbon Park Police Station, Bangalore - 560001 Karnataka, BANGALORE, KARNATAKA-560001, India	NUMAX Online UPS of Rating 40.0 KVA Without Battery Of Backup Time NA	1	13-Mar-2024	11-Jun-2024
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------	---	-------------	-------------

विनिर्देश Specification	उप-विनिर्देश Sub-Spec	मूल्य Value
	Rating in KVA	40.0 KVA
	Switching Technology	IGBT-PWM
Generic	Input Voltage	AC Single phase 160V - 260V 50Hz
	Output Voltage	AC Single phase 230V +/-1% 50 Hz
	Warranty for UPS (Years)	2
	Battery/Backup Bank Provided with Online UPS (Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021)	Without Battery
	Type of Battery (hint: NA in case Battery not provided)	NA
	Backup time (Minutes) (hint: NA in case battery not provided)	NA
Battery/Backup Bank	Battery Make	NA
	Battery Model Number	NA
	Battery capacity (Ah)	0
	Weight of the Battery (kg)	0
	Number of Batteries	0
	Minimum Guaranteed VAH	NA
	Warranty for battery (Years) by Battery Manufucaturer/Brand hint: NA in case battery not provided	NA
	Accessories with Battery	NA
	Installation and Commissioning (Covered in the Scope of Supply)	Provided
	After sales service (Turn Around Time)	Within 48 hours
Installation and Commissioning or Service	Preventive Maintenance (Hint: Mention Timeline if provided, NA if not provided)	Quarterly
service	Other Services provided	AMC support available warranty,PAN India service support on 24 x 7 basis,Availability of spares in close proximity (Spares should be easily available close to the site),NA
	Inbuilt isolation transformer	With
Performance / Functional	Overall Efficiency (%)	>/=90% with Inbuilt isolation transformer
	Power Factor Load Supported	0.8 or better
	Overload limit	50% Overload for minimum 1 minute,50% Overload for minimum 3 secon
	Total Harmonic Distortion(THD) (%)	3% Maximum @ 100% Linear Load
	Other Functional Features	Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD : 8 to 10 Hou
Accessories	Accessories	NA,The UPS shall be complete with Trolley for battery bank,battery, Cable and connectors etc
Salient Features	Protection	Protection for under voltage at battery terminal, Protection of Over voltage, Short Circuit & over load at UPS output terminal, Over temperatur protection
	Metering	Input Voltage,Output Voltage,Input Current,Output Current,Input Frequency,Output Frequency,Input Power,Output Power,Input Power Factor,Output Power Factor,Battery Voltage and Current
	Alarms and Indications	Indicator for Mains presence,Indicator for Battery charging and discharging,Indicator for Output Over Load with Audible Alarm,Indicator Low Battery Voltage with Audible Alarm,Alarm for Over temperature,Alar for Low Battery

	Additional Features	Pure Sinewave AC Output,NA
	Provide URL of the catalogue	www.numaxups.co.in
	Type of Design / Construction	Floor Standing
	Form factor of UPS	NA (for Floor Standing)
Dagian / Canatay ation	Enclosure (mm)	1.0 mm Minimum Thickness of M.S. Sheet duly powder coated
Design / Construction	Degree of Protection	IP20
	DC Bus Voltage (In Volts)	480
	Other Constructional Features	NA
	Minimum Operating Temperature	0 degree Celsius
Operating Conditions	Maximum Operating Temperature	50 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	95 percent
	Environmental Test Report Requirements	NA
Buyer Specific Requirement	Battery Test Report	NA
	Intended Applications	NA
	Other Requirements	NA
	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	ОЕМ
Reports And Certification	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Not applicable (For UPS rating higher than 10KVA)

ईपीबीजी विवरण | ePBG Detail

NA

नियम और शर्तें|Terms and Conditions

- 1. Special terms and conditions- Version:1 effective from 06-07-2022
- 1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS (Version 2.0) with reference to Installation and Commissioning.

Seller's Responsibility: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

Buyer's Responsibility: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

- 2. General Terms and Conditions-
- 2.1 This contract is governed by the General Terms and Conditions, conditions stipulated to this Product/Service as provided in the Marketplace.
- 2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.