

अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687710536909

अनुबंध तिथि | Generated Date : 18-Mar-2024

संगठन विवरण | Organisation Details

प्ररूप | Type : State Government
मंत्रालय | Ministry : -
विभाग | Department : Revenue Department Uttar Pradesh
संगठन का नाम | Organisation Name : Disaster Management Department
कार्यालय क्षेत्र | Office Zone: COLLECTORATE ALIGARH

खरीदार विवरण | Buyer Details

पद | Designation : SDM
संपर्क नंबर | Contact No. : 0571-0000000-
ईमेल आईडी | Email ID : buycon1.dmd.up@gembuyer.in
जीएसटीआईएन | GSTIN : -
पता | Address : ADM FR OFFICE COLLECTORATE CAMPUS ALIGARH, ALIGARH, UTTAR PRADESH-202001, India

वित्तीय स्वीकृति विवरण | Financial Approval Detail

आईएफडी सहमति | IFD Concurrence : No
प्रशासनिक अनुमोदन का पदनाम | Designation of Administrative Approval: SDM
वित्तीय अनुमोदन का पदनाम | Designation of Financial Approval: SDM

भुगतान प्राधिकरण विवरण | Paying Authority Details

Role: BUYER
भुगतान का तरीका | Payment Mode: Offline
पद | Designation : SDM
ईमेल आईडी | Email ID : buycon1.dmd.up@gembuyer.in
जीएसटीआईएन | GSTIN : -
पता | Address: ADM FR OFFICE COLLECTORATE CAMPUS ALIGARH, Aligarh, UTTAR PRADESH-202001, India

विक्रेता विवरण | Seller Details

जेम विक्रेता आईडी | GeM Seller ID : EABE190000947601
कंपनी का नाम | Company Name : M/S ALIGARH ENTERPRISES
संपर्क नंबर | Contact No. : 09756202289
ईमेल आईडी | Email ID : aligarhenterprises2019@gmail.com
पता | Address : 13/85, ESHA NAGAR, SASNI GATE, Aligarh, UTTAR PRADESH-202001, -
एमएसएमई पंजीकरण संख्या | MSME Registration number : UDYAM-UP-02-0024697
एमएसई सामाजिक श्रेणी | MSE Social Category : General
एमएसई लिंग श्रेणी | MSE Gender : Male
जीएसटीआईएन | GSTIN: 09AUUPS3124R1ZK

*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Buyer

वितरण निर्देश | Delivery Instructions : NA

उत्पाद विवरण | Product Details

#	आइटम विवरण Item Description	आइटम विवरण Ordered Quantity	इकाई Unit	इकाई मूल्य (INR) Unit Price (INR)	कर विभाजन (INR) Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR)
1	<p>उत्पाद का नाम Product Name : better power 40KVA with 15/ 30 min backup 50KVA with 15/ 30 min backup 80KVA with 15/ 30 min backup UPS</p> <p>ब्रांड Brand : better power</p> <p>ब्रांड प्रकार Brand Type : Registered Brand</p> <p>कैटलॉग की स्थिति Catalogue Status: Catalogue not verified by OEM</p> <p>कैसे बेचा जा रहा है Selling As : Reseller not verified by OEM</p> <p>श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : Online Ups Modular Type (Q3)</p> <p>मॉडल Model: NX series 40 KVA</p> <p>एचएसएन कोड HSN Code: HSN not specified by seller</p>	1	pieces	5,000	NA	5,000
कुल ऑर्डर मूल्य Total Order Value (in INR)						5,000

प्रेषिती विवरण | Consignee Detail

क्र.सं. S.No	प्रेषिती Consignee	वस्तु Item	लॉट नंबर Lot No.	मात्रा Quantity	दिनांक के बाद डिलीवरी शुरू करना है Delivery Start After	वितरण पूरा कब तक करना है Delivery To Be Completed By
1	<p>पद Designation : SDM</p> <p>ईमेल आईडी Email ID : buycon1.dmd.up@gembuyer.in</p> <p>संपर्क Contact : 0571-0000000-</p> <p>जीएसटीआईएन GSTIN : -</p>	better power 40KVA with 15/ 30 min backup 50KVA with 15/ 30 min	-	1	18-Mar-2024	02-Apr-2024

	पता Address : ADM FR OFFICE COLLECTORATE CAMPUS ALIGARH, ALIGARH, UTTAR PRADESH-202001, India	backup 80KVA with 15/ 30 min backup UPS			
Product Specification for better power 40KVA with 15/ 30 min backup 50KVA with 15/ 30 min backup 80KVA with 15/ 30 min backup UPS					
	विनिर्देश Specification	उप-विनिर्देश Sub-Spec	मूल्य Value		
GENERIC		Online UPS Modular type should support for Data Centres, Network operating centres, Security operation centres, State and District centres, Command and Control centre etc., across the Country to provide impetus to the e-Governance services e.g.Public food distribution, e Way bill, Counseling, e-Office, IVFRT etc., services under Digital India Programme	Yes		
		Modular type UPS equipped with microprocessor/Digital signal processor and power modules, Power expansion facility, LCD/Digital display upto maximum expandable capacity, Cable entry, RS 232 port and SNMP port with each power module and with suitable rack (compatible maximum expandable) with complete lockable door having visibility for maximum expandable capacity	Yes		
		Output power capacity including redundancy/Expandable (Rack facility) upto/Minimum backuptime (including redundancy) /Minimum VAH (VAH shall be calculate Battery voltage x Battery Ah x No. of batteries = Total VAH)	40KVA with 15/ 30 min backup 50KVA with 15/ 30 min backup 80KVA with 15/ 30 min backup		
		VAH tolerance	-1% of the defined capacity		
		Hot swappable power module	Yes		
		Battery module using two or more strings in parallel for redundant supply and battery module shall be fuse protected	Yes		
		Inverter Technology	PWM with IGBT, double conversion		
		Output wave form	Pure sine wave		
		Country of origin for Inverter	India		
		Noise level	<= 65 dB		
		Type of cool (Minimum 2 Fans for each power module)	Air cooled		
		Parallel (Power Modules) load sharing redundant operation with all accessories	Yes		
		Installation and commissioning	Yes		
		UPS shall be supply with installation and operation manual	Yes		
INPUT		Input	AC Three Phase		
		Input Voltage Range	320 V to AC to 470 V AC 3 Phase		
		Input frequency range	50 +/-6% Hz		
		Input power factor at full output load leading to unity with active power factor correction (APFC) (from 25% load to 100% load)	>=0.99		
		Distortion (current)	< / = 3%		
		UPS shall have DG set compatibility	Yes		
OUTPUT		Output	AC Three Phase		
		Output voltage	380/400/415, 3 phase, 4 wire		
		Voltage regulation (Steady state) at No load to full load, 0.6 lag to Unity PF, During entire back up time, Complete input voltage range	+/-1%		
		Output power factor	>= 0.90		
		Frequency	50 Hz +/-0.5 % Hz		
CONSTRUCTION		Minimum thickness (in mm) of Rack Enclosure for Modular UPS duly powder coated	1.2		
		UPS shall be free from workmanship defects, sharp edges, nicks, scratches, burst, etc. All fasteners shall be fixed properly. The equipment shall be complete with all parts and all parts shall be functional	Yes		
		UPS enclosure's degree of protection as per IS:13947 (Part 1)/1993 latest	IP21		
		Standard quality Output terminals shall be provided for output connection	Yes		
		UPS shall have static and manual bypass facility	Yes		
		UPS shall be supplied with required rated power cable (Copper)	5 Meters		
		Total Harmonic Distortion (THD) for 100% linear load	< 3%		
		Total Harmonic Distortion (THD) for 100% non-linear load	< 5%		
		Operating temperature	0 deg C to +40 deg C		
		Humidity	Upto 95% non-condensing		
		Operational: 1000 meters above sea level at 40 deg. C maximum	Yes		

	Crest factor on full non-linear load	Not less than 3:1
	Over all efficiency on rated full load of 0.8 PF (min.) AC output	>=90%
	Inverter efficiency on rated full load of 0.8 PF (min.) AC output	>=95%
	UPS shall withstand Over load capacity - 125% (Output with mains AC-AC)	for 5 Minutes (Minimum)
	UPS shall withstand Over load capacity - 150% (Output with mains AC-AC)	for 60 seconds (Minimum)
	UPS shall withstand Over load capacity - 125% (Output in battery run DC-AC)	for 2 Minutes (Minimum)
	UPS shall withstand Over load capacity - 150% (Output in battery run DC-AC)	for 30 seconds (Minimum)
	Load power factor 0.8 lagging to unity	Yes
	Transient response time (for 100% load change, output must remain within +/-1% and recovery)	<20 milli seconds
PROTECTION	Short circuit protection	Yes
	Over load protection	Yes
	Over temperature protection	Yes
	In put low/high voltage control	Yes
	DC low/high voltage trip	Yes
	Back feed protection for both, mains and bypass input	Yes
BATTERY	Battery shall conforming to JISC:8702(Pt.I,II&III) latest or equivalent BIS standard	Yes
	Battery type	SMF VRLA
	Country of origin for Battery	India
	Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD	8 to 10 hours
	Battery charger (One in each power module) should be capable to charge battery on C10 rating	Yes
	Battery cutoff voltage during back up	Not less than 10.5 V
	Batteries shall supply with	With metal rack
	Modular UPS shall supply with DC Cable from UPS to battery and batteries to UPS , Battery interlink cables, battery breaker	Yes
Meters, Indicators and Display	All the meters and display LCD/Digital type shall support for maximum expanadable capacity	Yes
	Input: Voltage line to line and line to neutral, currents, frequency, power factor display	Yes
	Bypass: Phase voltage, line to line voltge, frequency display	Yes
	UPS Output: Phase voltage, phase currents, line-line voltage, power factors, frequency display	Yes
	Local load: Load of each phase (% age of total load), Active power (KW), Apparent power (KVA), and Ractive power (KVAR) of each phase, load crest factor display	Yes
	Battery: Battery bus voltage, battery charge and discharge current, forecasted battery back up time, battery capacity (Ah)	Yes
	Parrallel load (for parallel operation system): Apparent power (KVA) of each phase, Active power (KW) of each phase, reactive power (KVAR) of each phase	Yes
	UPS shall have an indication for Mains on, Load on battery, Inverter, Battery level, Load level, Inverter over load	Yes
	UPS shall have audible alaram for over temperature, mains failure, battery low, inverter overload	Yes
	Communication interface: SNMP/MODBUS/HTTP/JAVA/UPSMON/SMTP etc., and 2 serial port USB/ RS232, RS485, 1 logic level port, 4 Dry contacts ports	Yes
	Log History storage facility with display (minium 200 events)	Yes
WARRANTY AND SERVICES	Warranty for Modular UPS (on site comprehensive warranty) (in years)	3
	Warranty for battery (replacement warranty) (in years)	2
	After sales and complaint service	within 48 hours
	PAN India service support on 24 x 7 basis	Yes
	AMC support available after 3 year warranty	Yes
	Quarterly preventive maintenance	Yes
	Manufacturer shall provide and support for installation, commissioning, spares, technical support all over India	Yes
	Availability of spares in close proximity (Spares should be easily available close to the site)	Yes
	ISO: 9001 Certification	Yes
	ISO: 14001 Certification	Yes
	Environmental compliance certificate RoHS	Yes

CERTIFICATIONS	CE Certification and marking	Yes
	UPS shall meet and comply with the General and safety requirements as per IEC:62040-1	Yes
	UPS shall meet and comply with the Electromagnetic compatibility (EMC) requirements as per IEC:62040-2	Yes
	Damp Heat Test : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C,two cycles of (12+12) hours each 2007)	No
	Dry Heat Test : in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs	No
	Cold Test : in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs.	No
	Availability of the Type Test Report from Central Govt. /NABL/ILAC Accredited lab covering all technical requirements.	Yes
	All the test reports and certificates shall furnish by the supplier to the buyer/consignee on demand	Yes
<div>टिप्पणी Note:: Seller has given an undertaking that it has made arrangements for getting the stores from an authorized distributor / dealer / channel partner of the OEM of the offered product. At the time of delivery of goods, Seller will provide necessary chain documents (in the form of GST Invoice) to prove that the supplied goods are genuine and are being sourced from an authorized distributor / dealer / channel partner of the OEM. In case of any complaint about genuineness of the supplied products, Seller shall be responsible for providing genuine replacement supplies.</div>		
ईपीबीजी विवरण ePBG Detail		
NA		
<div>नियम और शर्तें Terms and Conditions</div> <div>1. General Terms and Conditions-</div> <div>1.1 This contract is governed by the General Terms and Conditions, conditions stipulated to this Product/Service as provided in the Marketplace.</div> <div>1.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable</div>		
<div>नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।</div> <div>Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.</div>		