

अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687708149243

अनुबंध तिथि | Generated Date : 26-Mar-2024

बोली/आरए/पीबीपी संख्या | Bid/RA/PBP No.: [GEM/2024/B/4430736](#)

| संगठन विवरण Organisation Details | खरीदार विवरण Buyer Details |
|---|---|
| प्रकार Type : Central PSU मंत्रालय Ministry : Ministry of Power विभाग Department : THDC INDIA Limited संगठन का नाम Organisation Name : THDC INDIA Limited कार्यालय क्षेत्र Office Zone : Thdc India Ltd., Rishikesh | पद Designation : Sr Manager संपर्क नंबर Contact No. : 0135-2473519- ईमेल आईडी Email ID : buyer5.thdc.rksh@gembuyer.in जीएसटीआईएन GSTIN : 05AAACT7905Q1ZW पता Address : By Pass Road THDC INDIA LTD RISHIKESH, DEHRADUN, UTTARAKHAND-249201, India |

| वित्तीय स्वीकृति विवरण Financial Approval Detail | भुगतान प्राधिकरण विवरण Paying Authority Details |
|---|--|
| आईएफडी सहमति IFD Concurrence : Yes प्रशासनिक अनुमोदन का पदनाम Designation of Administrative Approval : CGM वित्तीय अनुमोदन का पदनाम Designation of Financial Approval : AGM (F&A-CAC) | Role: PAO भुगतान का तरीका Payment Mode: Offline पद Designation : Dy Manager ईमेल आईडी Email ID : pao1.thdc.rksh@gembuyer.in जीएसटीआईएन GSTIN : N पता Address: Finance, CORPORATE OFFICE, BHAGIRATHI BHAWAN, THDC INDIA LTD., RISHIKESH, DEHRADUN, UTTARAKHAND-249201, India |

| विक्रेता विवरण Seller Details |
|--|
| जेम विक्रेता आईडी GeM Seller ID : 9010190000994723 कंपनी का नाम Company Name : HARISON GENERATORS PRIVATE LIMITED संपर्क नंबर Contact No. : 09915999332 ईमेल आईडी Email ID : CONTACTRAMANSEHGAL@GMAIL.COM पता Address : Plot Number 81,Daulatpur Industrial Area,New Focal Point,Near Daulatpur Primary School 147001, Patiala, PUNJAB-147001, - एमएसएमई सत्यापित MSME verified : No एमएसएमई पंजीकरण संख्या MSME Registration number : UDYAM-PB-17-0005195 एमएसई सामाजिक श्रेणी MSE Social Category : General एमएसई लिंग श्रेणी MSE Gender : Male जीएसटीआईएन GSTIN: 03AAECH6842C1ZZ |

*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Buyer

वितरण निर्देश | Delivery Instructions : NA

उत्पाद विवरण | Product Details

| # | आइटम विवरण Item Description | आइटम विवरण Ordered Quantity | इकाई Unit | इकाई मूल्य (INR) Unit Price (INR) | कर विभाजन (INR) Tax Bifurcation (INR) | मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR) |
|---|---|-------------------------------|-------------|-------------------------------------|---|---|
| 1 | उत्पाद का नाम Product Name : DURKATO Power Generator- DG set of 250 AMF Control Panel ब्रांड Brand : DURKATO ब्रांड प्रकार Brand Type : Registered Brand कैटलॉग की स्थिति Catalogue Status: OEM verified catalogue कैसे बेचा जा रहा है Selling As : OEM श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : Power Generator - DG Set (up to 900 KVA) (Q2) मॉडल Model: HARISON250KVA एचएसएन कोड HSN Code: HSN not specified by seller | 1 | pieces | 1,796,800 | NA | 1,796,800 |
| 2 | उत्पाद का नाम Product Name : ICT charges for Power Generator - DG Set (up to 900 KVA) ब्रांड Brand : NA ब्रांड प्रकार Brand Type : Unbranded कैटलॉग की स्थिति Catalogue Status: Catalogue not verified by OEM कैसे बेचा जा रहा है Selling As : Reseller not verified by OEM श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : Addon Services for bid (Q3) मॉडल Model: ICT एचएसएन कोड HSN Code: HSN not specified by seller | 1 | pieces | 449,200 | NA | 449,200 |

कुल ऑर्डर मूल्य | Total Order Value (in INR)

2,246,000

प्रेषित विवरण | Consignee Detail

| क्र.सं. S.No | प्रेषिती Consignee | वस्तु Item | लॉट नंबर Lot No. | मात्रा Quantity | दिनांक के बाद डिलीवरी शुरू करना है Delivery Start After | वितरण पूरा कब तक करना है Delivery To Be Completed By |
|----------------|--|--|--------------------|-------------------|---|--|
| 1 | पद Designation : - ईमेल आईडी Email ID : con1.thdc.rksh@gembuyer.in संपर्क Contact : 0135-2473585- जीएसटीआईएन GSTIN : 05AAACT7905Q1ZW पता Address : Central Stores, Gate no.-3, CORPORATE OFFICE, Pragatipuram, THDC INDIA LTD., RISHIKESH, DEHRADUN, UTTARAKHAND-249201, India | DURKATO Power Generator- DG set of 250 AMF Control Panel | - | 1 | 26-Mar-2024 | 24-Jun-2024 |

Product Specification for DURKATO Power Generator- DG set of 250 AMF Control Panel

| विनिर्देश Specification | उप-विनिर्देश Sub-Spec | मूल्य Value |
|--|---|---|
| Power Generator INSTALLATION CONFIGURATIONS | Power Generator installation configurations as defined in CPWD General Specifications for Electrical works - Part VII (DG Set) | Fixed (Power Generators are permanently installed)" |
| OUTPUT CAPACITY RATING/ PHASE | Nominal Rated Capacity (kVA) | 250 |
| | No of Phase (Single Phase-3-5kVA) (Single Phase or Three Phase-5 & 7-5, 10,15, 20, 25, 30 & 40 kVA) (Three Phase-50 to 900 kVA) | Three Phase |
| ENGINE | Make of Engine | HARISON |
| | Model Number of Engine | 6DTAA89G33 |
| | Capacity of Engine (cc) | 8819 |
| | Rated Engine Power (kWm) | 110 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator Any Auxilary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficience |
| | Type of Engine cooling | Liquid Cooled |
| | Type of governer | Electronic |
| | Number of cylinders (nos) | 6 |
| | No of Strokes (nos) | 4 |
| | Rated RPM of Engine (RPM) | 1500 |
| | Fuel | High Speed Diesel (HSD) |
| | Overload capacity | Engine is capable of delivering an output of 10% in excess of rated KVA for a period of one hour in any period of 12 hours continous running |
| | Specific Fuel Consumption (gm/kWh) | 200 to 265 |
| | Starting voltage (volt) | 24 |
| | Salient Features of Engine | Turbo Charged Engine,Naturally aspirated engine,Direct injection Fuel System,CRDi Fuel System,cold start upto (-20 deg c),No derating applicable upto 4500 above MSL of altitude at 25 degree celcius,Indirect injection (IDI) Fuel System,Ambient working temperature upto 55 degree celcius. |
| Class of governer | A2 or better | |
| "Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Transient) " | 10 | |

| | | |
|--------------------------------|--|---|
| GOVERNING CLASS | "Maximum Recovery Time in Seconds on suddenly taking-off the rated load(Transient) " | 10 second |
| | Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Permanent) | 4 |
| | "Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Transient) " | 4 |
| | "Maximum Recovery Time in Seconds on a change of load, both on and off, by all steps of 25 percent of the rated load(Transient) " | 4 second |
| | "Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Permanent) | 1.5 |
| ALTERNATOR | AC GENERATOR (ALTERNATOR) Make | LEROYSOMER/MECCALTE |
| | AC GENERATOR (ALTERNATOR) model Number | LEROYSOMER/MECCALTE |
| | Alternator Voltage Rating | 415 Volt |
| | Rating of AC Generator (KVA) | 250KVA |
| | Power Factor of AC generator | 0.8 |
| | Efficiency at rated Power factor at 75% of full Load | 91.16 percent |
| | Conformity to Indian Standard (for Alternator) | Generally conforming to IS:13364 (Part-2) latest (Above 20 KVA) |
| | Type of alternator | Brushless |
| | Voltage Regulation Grade | VG 3 |
| | Alternator IP Rating | IP 23 |
| | Class of Insulation | H |
| Salient features of Alternator | NA | |
| | Control Panel | AMF Control Panel |
| | Control Panel Location | Inside the canopy |
| | IP Rating of Control Panel | IP 55 |
| | Display meters in the control panel (with appropriate rating and accuracy class) - | Voltmeter, Ammeter, Frequency meter, Power Factor meter, Multifunctional Digital display meter (displaying Voltage, Current, Frequency, Power Factor) |

| | | |
|--------------------|---|--|
| CONTROL PANEL | inclusive in the scope of supply | |
| | Other devices in the control panel (with appropriate rating) - inclusive in the scope of supply | Required switches and cutout,MCB,MCCB,Contactor,Circuit breaker,Battery charger,remote monitoring over internet with GSM modem. |
| | Displayed parameters/Features | Engine Speed,Lube oil pressure,Coolant/cylinder head Temperature,Engine running hours,Engine battery voltage,Engine Running status,Generator Voltage (Ph-Ph),Generator Voltage (Ph-N),Generator Current (R, Y, B),Generator apparent Power (kVA),Generator active Power (kW),Powerfactor,Frequency,Fuel level,Event log,Control supply Voltage |
| | Indicators | Low Lube oil pressure,High water / coolant / cylinder head temperature,Low fuel level,Over speed |
| | Audio Alarm | Low Lube oil pressure,High water / coolant / cylinder head temperature,Low fuel level,Over speed |
| ACOUSTIC ENCLOSURE | Acoustic Enclosure (inclusive in the scope of supply) | Yes, Power Generator supplied with Acoustic Enclosure |
| | Sheet Thickness(mm) | 1.6 |
| | Thickness of insulation | 30 millimeter |
| | Density of insulation (kg/cubic m) | 30 |
| | Noise level at 1 meter (dB) | 75 |
| Fuel Tank | Fuel Tank Capacity | 400 liter |
| | Number of Fuel tank | 1 |
| | Fuel Tank Sheet Material Thickness(mm) | 2 |
| | Fuel Tank Fabricated Material | M.S Sheet |
| | Fuel Tank Features | Fuel Tank capacity is sufficient for 8 hrs of running at full load |
| BATTERY | Battery Type & Specification | "Low Maintenance free to IS: 14257 for high cranking performance" |
| | Battery capacity (Ah) | 150 |
| | No of batteries | 2 |
| SALIENT FEATURES | Salient Features of Power Generator | Glass window on Accoustic Enclosure in front of the Control Panel,Emergency Stop outside the Accoustic Enclosure |
| | Additional Features | NA |
| TRAILER | Trailer | NA for Fixed/Skid Mounted Power Generator |
| | Pay load of the Trailer | 2000 kilogram |
| | Number of Axlels | 0 |
| | Number of wheels | 'NA' for without trailer |
| | Wheel Tyre size | 0 inch |
| | Brakes | NA for Fixed/Skid Mounted Power Generator |
| | Trailer Complying to CMVR act and Regulation | NA for Fixed/Skid Mounted Power Generator |
| | Maximum permissible Speed of Trailer(Km/hr) | 0 |
| | Trailer unladen weight | 0 kilogram |
| | Trailer overall length | 0 millimeter |
| | Gross Towing Weight (including Power Generator) | 0 kilogram |
| | Salient Features of trailer | NA |

| | | |
|---|---|---|
| General Technical Requirements (GTR) / Commissioning | General Technical Requirements (GTR) / Commissioning(Part-1) | a) Power Generator shall be complete with Diesel Engine, Alternator and AMF/MANUAL Control Panel along with Acoustic Enclosure. Diesel engine and alternator shall be closely coupled or provided with flexible coupling and mounted on a base plate / M.S. frame of robust in construction. |
| | General Technical Requirements (GTR) / Commissioning(Part-2) | b) Anti-Vibration mountings shall be provided for complete Power Generator in case of flexible coupling. In case of direct coupling Anti-Vibration mountings shall be provided for the Engine as well as the alternator. |
| | General Technical Requirements (GTR) / Commissioning(Part-3) | c) Power Generator should have protection against under voltage, over voltage, under frequency, over frequency, low battery voltage, over current, earth-fault, short circuit, phase sequence change etc. |
| | General Technical Requirements (GTR) / Commissioning(Part-4) | d) Automatic Mains Failure (AMF) control panel, where applicable, shall be able to start up the Power Generator and transfer the load on to the Power Generator on mains failure without requiring any human intervention. Similarly on restoration of mains supply, it shall be able to transfer the load to mains supply and switch off the Power Generator automatically. |
| | General Technical Requirements (GTR) / Commissioning(Part-5) | e) Control Panel (Manual / AMF), where applicable, shall be equipped with suitable Voltmeter, Ammeter, Frequency meter, power factor meter (these items can be alternatively supplied in one multifunctional digital display meter), battery charger, indicators, various switches and cutout / MCB / MCCB / Contactor / Circuit breaker for the DG output of appropriate rating and accuracy class as per trade practice for better utility. |
| | General Technical Requirements (GTR) / Commissioning(Part-6) | f) Supply and installation of a change-over Switch / MCCB of suitable rating for Power Generator with manual control panel, where applicable, is inclusive in the scope of supply. |
| | General Technical Requirements (GTR) / Commissioning(Part-7) | g) Acoustic Enclosure shall be made of Pre-treated and Powder coated CRCA Sheet. The sheet shall be Pre-treated and Powder coated with weather-proof paint. The Acoustic Enclosure shall be vermin proof. The enclosure shall accommodate the (daily service) fuel tank of the Power Generator to make the system compact. |
| | General Technical Requirements (GTR) / Commissioning(Part-8) | h) Power Generators shall meet the requirements of Environmental (Protection) Rules 1986 as laid down by Min. of Environment & Forests read with GSR 371 (E) dated 17.5.2002,GSR 520(E)dated 1.7.2003 , No.448 (E)dated 12.07.2004 , GSR 771(E) dated 11.12.2013 GSR 232(E)dated 31.03.2014,Gazette Notification No.167 dated. 31.03.2014 and Gazette Notification No. 578 dated. 11.11.2014 in respect of noise and emission norms. The latest amendments to above GSRs shall be applicable as and when amended by Ministry of Environment and Forest. |
| | General Technical Requirements (GTR) / Commissioning(Part-9) | i) Standard set of tools consisting of a set of 3 spanners, one screw driver, one standard plier and one nose plier of appropriate size shall be provided along with each Power Generator. |
| | General Technical Requirements (GTR) / Commissioning(Part-10) | j) Supply of Fuel tank of suitable capacity, sufficient for minimum 8 hours running/990 liters(whichever is lower) the Power Generator, is inclusive in the scope of supply. Fuel Tank shall be complete with fuel piping (between fuel tank and diesel engine), valves, level indications and all standard accessories. MS pipes, heavy class of suitable dia conforming to IS 1239 (Part-1) - latest shall be used for fuel piping. |
| | General Technical Requirements (GTR) / Commissioning(Part-11) | Buyer's Responsibilities: i. Mains ACB for AMF operation shall be provided by the buyer for DG set rating above 600 KVA and above .For DG set other ratings seller shall provide mains and DG contactor/breaker, ii. Exhaust piping, extra civil work, distribution board shall be provided by the buyer. iii. Consumables such as filters, lube oil at the time of servicing during warranty period shall be provided by the buyer. iv. Obtaining necessary approvals, if any, is the responsibility of the buyer. |
| Above General Technical Requirements (GTR) / Commissioning have been seen, read, understood and agreed to comply | Yes | |
| Installation | with installation - inclusive in the scope of supply | |
| Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-1) | a) Installation of Power Generator when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of Power Generator and its constituent parts shall be generally conforming to CPWD General Specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of PCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the Power Generator. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller. | |
| Scope of installation | c) Supply, laying and termination of interconnecting power and control cable shall be done by the seller. The cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with | |

| | | |
|--|---|---|
| SCOPE OF INSTALLATION | for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-2) | aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For 3-Phase Power Generators, 3.5 core or higher core cables shall be used. Total length of the cable supplied by the seller shall be within 30 meters for each Power Generator with manual control panel and within 60 metres for each Power Generator with AMF control panel. The current rating of the cables shall be as indicated below: 2C, 6 Sq mm for Single Phase, 3.5 & 5.0 KVA 2C, 10 Sq mm for Single Phase, 7.5 & 10 KVA 2C, 25 Sq mm for Single Phase, 15 KVA 2C, 35 Sq mm for Single Phase, 20 KVA 2C, 70Sq mm for Single Phase, 25 KVA 2C, 95Sq mm for Single Phase, 30 KVA 2C, 120Sq mm for Single Phase, 40 KVA 4C, 4 Sq mm for Three Phase, |
| | Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-3) | d) 10 KVA 4C, 6 Sq mm for Three Phase, 15 KVA 4C, 10 Sq mm for Three Phase, 20 & 25 KVA 4C, 16 Sq mm for Three Phase, 30 KVA 3.5C, 25 Sq mm for Three Phase, 40 KVA 3.5C, 35 Sq mm for Three Phase, 50 KVA 3.5C, 70 Sq mm for Three Phase, 62.5 & 75 KVA 3.5C, 95 Sq mm for Three Phase, 82.5 KVA 3.5C, 120 Sq mm for Three Phase, 100 KVA 3.5C, 185 Sq mm for Three Phase, 125 KVA 3.5C, 300 Sq mm for Three Phase, 160 KVA 3.5C, 2 Run of 120 Sq mm for Three Phase, 180 KVA 3.5C, 2 Run of 150 Sq mm for Three Phase, 200 KVA 3.5C, 2 Run of 185 Sq mm for Three Phase, 225 KVA 3.5C, 2 Run of 240 Sq mm for Three Phase, 250 & 275 KVA 3.5C, 3 Run of 185 Sq mm for Three Phase, 320 KVA 3.5C, 3 Run of 240 Sq mm for Three Phase, 380 & 400 KVA 3.5C, 4 Run of 240 Sq mm for Three Phase, 500, 600 & 750 KVA 3.5C, 6 Run of 240 Sq mm for Three Phase, 900 KVA |
| | Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-4) | e) Construction of suitable earthing station and necessary connections shall be done by the seller. All the materials / labour required for construction of earthing station shall be supplied by the seller. The total number of earthing pits/stations shall be 4, i.e., 2 for neutral and 2 for body-earthing. Netutral earthing shall be done with copper Plate and Body earthing shall be done with G.I. plate / Copper. The consignee should choose installation site in such a way that the earthing stations can be made within 10 metres of the Power Generator. Earthing station shall be typically constructed as per prevalent standard practices and shall be generally conforming to CPWD General specification for Electrical Works, Part - VII & Part - I - latest. e) Installation of Fuel Tank including foundation / stand shall be done by the seller. f)The warranty is applicable upto specified value of month/hours whichever occurs first's. |
| | Above Scope of installation for Diesel Generating Set when offered by the vendor has been seen, read, understood and agreed to comply | Yes |
| WARRANTY/SERVICES | Warranty on Complete power genertor/DG Set | 36 month |
| | Warranty in running hours | 5000 hour |
| | Number of preventive maintenance visits offered in an year during warranty period (Supply of all consumables is the buyer's responsibilty)* | 1 |
| | Response Time to attend the complaint during Warranty | 2 day |
| | Time Duration for Repairing /Replace the defect during Warranty | 5 day |
| TEST REPORTS | Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification | Certificates required as per CPCB |
| | Test report Available for (Test/approval) | Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB,COP Certificate for engine,Type test report and Endurance test report for Engine as per IS: 10001 latest / IS: 10002 latest,Type test report for Alternator as per IS:13364 (Part-1) latest / IS:13364 (Part-2) latest to prove conformity to the specifications |
| | Agree to provide all relevant documents Test Report/supporting document /reports etc to the buyer at the time of bidding or on demand | YES |
| उपरोक्त मद के लिए स्थापना कमीशनिंग और परीक्षण (आईसीटी) विवरण Installation Commissioning and Testing (ICT) details for the above item:: | | |

| | |
|---|---------|
| % of Product Cost Payable on Product Delivery | 75 % |
| Min Cost Allocation for ICT as a % of product cost | 25 % |
| Number of days allowed for ICT after site readiness communication to seller | 30 Days |

ईपीबीजी विवरण | ePBG Detail

| | |
|---|---------------------|
| सलाहकार बैंक Advisory Bank : | State Bank of India |
| ईपीबीजी प्रतिशत (%) ePBG Percentage(%): | 5.00 |

बोली लगाने वाले को बोली के नियमों और शर्तों के अनुसार लागू ईपीबीजी प्रस्तुत करना होगा | The bidder shall furnish ePBG as applicable as per bid's terms and conditions

नियम और शर्तें | Terms and Conditions

1. General Terms and Conditions-

- 1.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.
- 1.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

2. Buyer Added Bid Specific Terms and Conditions-

2.1 Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

2.2 Forms of EMD and PBG:

Bidders can also submit the EMD with Payment online through RTGS / internet banking in Beneficiary name

THDC INDIA LIMITED

Account No.

10548872555

IFSC Code

SBIN0001180

Bank Name

STATE BANK OF INDIA

Branch address

RAILWAY ROAD RISHIKESH

Bidder to indicate bid number and name of bidding entity in the transaction details field at the time of on-line transfer. Bidder has to upload scanned copy / proof of the Online Payment Transfer along with bid.

2.3 Certificates:

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

2.4 Generic

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- Copy of PAN Card.
- Copy of GSTIN.
- Copy of Cancelled Cheque.
- Copy of EFT Mandate duly certified by Bank.

2.5 Buyer Added Bid Specific ATC:

Buyer Added text based ATC clauses

SPECIAL CONDITIONS OF CONTRACT

1. LOCATION AND COMMUNICATIONS :-

1.1 Rishikesh Town is located in Dehradun District. It is connected by rail and the nearest rail head is at Rishikesh which is about 225 km North from Delhi.

The facilities for railway siding, storage for diesel etc. exist at the rail head.

THDCIL Township is situated at Pragatipuram, Bypass Road, Rishikesh.

1.2 The tenderer is advised to visit the site and assess the site condition and local conditions such as approach roads to the site, water supply, electricity etc.

Tenderer shall be deemed to have considered site conditions and to have satisfied himself in all respects before quoting rates.

2. CONSTRUCTION PLANT AND MACHINERY :

The contractor shall arrange at his own expense all tools, plant, equipment (herein after referred to as T&P) required for execution of work.

3. MATERIAL TO BE SUPPLIED BY THE CORPORATION

No material shall be supplied by the Corporation. The Contractor at his own expenses, provide/ arrange all materials.

4. DEFECT LIABILITY PERIOD :

Defect liability period shall be thirty six (36) months from the date of certified completion of the work.

5. POWER SUPPLY :

Corporation will provide water & electricity free of cost to be consumed at the job site for execution of work only.

6. CONTRACT PRICE ADJUSTMENT :

Not applicable. All quoted prices shall remain firm during the currency of contract and no compensation due to any reasons or whatsoever shall be payable in this regard.

7. TIME SCHEDULE FOR COMPLETION :

The entire work is to be completed within (03) months from the date of start as specified in Letter of Award (LOA). Tenderer shall submit a work program which shall clearly indicate major key events as per requirements so as to complete the works within time frame stated above.

8. TAX: The prices are inclusive of all taxes, GST, labour cess and transportation, handling & transit insurance etc. as applicable.

9. Payment Terms:

75% payment of supply part shall be made through RTGS /NEFT after receipt of material at Central store, Rishikesh, inspection and acceptance of material within 30 days. Balance 25% payment of supply part shall be made within 30 days, after a satisfactory testing, erection & commissioning & demo/ training get conducted by the supplier at free of cost basis on the utility and handling of equipment to the employees of THDCIL at Rishikesh. Supplier shall submit a certificate of satisfactory installation of equipment duly signed by Sr. Manager (Eelct.)

10. SCOPE OF WORK:

- (a) Supply, Erection, Testing & Commissioning work of Supply, Fixing, Testing & Commissioning of 250KVA DG Set with Automatic Changeover Starting Panel for Ganga Bhawan at THDC India Limited complex, Rishikesh as per BOQ shall also include all taxes and duties as applicable and cost of transportation, freight & insurances etc.
- (b) All other associated work in testing & commissioning of Electrical system.
- (c) If the goods supplied from the supplier are required to be replaced / rectified on account of loss /damage to the originally supplied goods, all costs involved in such replacement /repair shall be borne by the supplier at his cost.
- (d) Offered materials should be strictly in line with the Specifications/ BOQ and the bidder has to provide test certificate of equipment / material from Manufacturer at the time of delivery.
- (e) Inspection of materials shall be carried out on receipt of materials at THDCIL premises, Rishikesh.
- (f) Supplier will provide free training at THDCIL site to operate the equipment to the person nominated by THDCIL RISHIKESH, if required.
- (g) The technical data i.e. name of manufacturer, brand, and specification's leaf- lets/ catalogues etc. should be enclosed f o r each item of tender.

(h) All supply should be made from the current manufacturing

11. Following Test carried out by vendor in presence of owner before dispatch,

a- Operation at least minimum 08 hours.

b- HV Test.

c- Insulation Test.

d- Load Test.

e- Operational & functional Test.

12. Only OEM or OEMs authorized Distributors / Dealers / Sellers can participate in this Bid.

2.6 Warranty:

Warranty period of the supplied products shall be 3 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

2.7 Service & Support:

Dedicated / toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

2.8 Generic:

Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.

2.9 Service & Support:

Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

2.10 Generic:

Installation, Commissioning, Testing, Configuration, Training (if any - which ever is applicable as per scope of supply) is to be carried out by OEM / OEM Certified resource or OEM authorised Reseller.

2.11 Generic:

Manufacturer Authorization: Wherever Authorised Distributors/service providers are submitting the bid, Authorisation Form /Certificate with OEM/Original Service Provider details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid

2.12 Purchase Preference (Centre):

Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for percentage of 25% of total value.

2.13 Inspection:

Pre-dispatch inspection at Seller premises (Fee/Charges to be borne by the BUYER): Before dispatch, the goods will be inspected by Buyer / Consignee or their Authorized Representative or by Nominated External Inspection Agency (independently or jointly with Buyer or Consignee as decided by the Buyer) at Seller premises (or at designated place for inspection as declared / communicated by the seller) for their compliance to the contract specifications. Fee/Charges taken by the External inspection Agency and any external laboratories testing charges shall be borne by the Buyer. For in-house testing, the Sellers will provide necessary facilities free of cost. Seller shall notify the Buyer through e-mail about readiness of goods for pre-dispatch inspection and Buyer will notify the Seller about the Authorized Representative/ Nominated External Inspection Agency and the date for testing. The goods would be dispatched to consignee only after clearance in pre-dispatch inspection. Consignee's right of rejection as per GTC in respect of the goods finally received at his location shall in no way be limited or waived by reason of the goods having previously been inspected, tested and passed by Buyer/ Consignee or its Nominated External Inspection Agency prior to the goods' shipment. While bidding, the sellers should take into account 7 days for inspection from the date of email offering the goods for inspection. Any delay in inspection beyond 7 days shall be on the part of the buyer and shall be regularised without Liquidated Damages.

When there is requirement of submission the advance sample, the seller shall inform the buyer promptly through emails about the date of submission of sample to the buyer nominated Inspection agency.

2.14 Scope of Supply:

Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

2.15 Forms of EMD and PBG:

Successful Bidder can submit the Performance Security in the form of Payment online through RTGS / internet banking also (besides PBG which is allowed as per GeM GTC). On-line payment shall be in Beneficiary name

THDC INDIA LIMITED

Account No.

10548872555

IFSC Code

SBIN0001180

Bank Name

STATE BANK OF INDIA

Branch address

RAILWAY ROAD RISHIKESH

. Successful Bidder to indicate Contract number and name of Seller entity in the transaction details field at the time of on-line transfer. Bidder has to upload scanned copy / proof of the Online Payment Transfer in place of PBG within 15 days of award of contract.

2.16 Certificates:

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.