

## अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687715265420

अनुबंध तिथि | Generated Date : 27-Mar-2024

संगठन विवरण   Organisation Details		खरीदार विवरण   Buyer Details	
प्ररूप   Type :	Central Government	पद   Designation :	SP ANAKAPALLE
मंत्रालय   Ministry :	Ministry of Communications	संपर्क नंबर   Contact No. :	08924-222318-222118
विभाग   Department :	Department of Posts	ईमेल आईडी   Email ID :	doanakapalle.ap@indiapost.gov.in
संगठन का नाम   Organisation Name :	AP Postal Circle Department of Posts	जीएसटीआईएन   GSTIN :	37AAAGH0104H1ZZ
कार्यालय क्षेत्र   Office Zone:	A.p. Postal Circle	पता   Address :	O/o SPOs Anakapalle, VISAKHAPATNAM, ANDHRA PRADESH-531001, India

वित्तीय स्वीकृति विवरण   Financial Approval Detail		भुगतान प्राधिकरण विवरण   Paying Authority Details	
आईएफडी सहमति   IFD Concurrence :	No	Role:	PAO
प्रशासनिक अनुमोदन का पदनाम	SPOs	भुगतान का तरीका	Offline
Designation of Administrative Approval:	SPOs	Payment Mode:	
वित्तीय अनुमोदन का पदनाम	SPOs	पद   Designation :	POSTMASTER
Designation of Financial Approval :		ईमेल आईडी   Email ID :	anakapalleho@indiapost.gov.in
		जीएसटीआईएन   GSTIN :	N
		पता   Address:	O/o SPOs Anakapalle, GODAVARI EAST, ANDHRA PRADESH-531001, India

विक्रेता विवरण   Seller Details	
जेम विक्रेता आईडी   GeM Seller ID :	B3A8180000093340
कंपनी का नाम   Company Name :	DJ DIGITAL POWER SYSTEMS PRIVATE LIMITED
संपर्क नंबर   Contact No. :	09959988546
ईमेल आईडी   Email ID :	baba@djdigitalpower.com
पता   Address :	H.No 40-203,Plot No.85,NA,Sri raghavendra nagar,Moula-Ali, Hyderabad, TELANGANA-500040, -
एमएसएई पंजीकरण संख्या   MSME Registration number :	UDYAM-TS-20-0004455
एमएसई सामाजिक श्रेणी   MSE Social Category :	General
एमएसई लिंग श्रेणी   MSE Gender :	Male
जीएसटीआईएन   GSTIN:	36AACCD7620C1ZZ

\*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Buyer

वितरण निर्देश | Delivery Instructions : NA

उत्पाद विवरण | Product Details

#	आइटम विवरण   Item Description	आइटम विवरण   Ordered Quantity	इकाई   Unit	इकाई मूल्य (INR)   Unit Price (INR)	कर विभाजन (INR)   Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित)   Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम   Product Name : BPE Online UPS of Rating 1.0 KVA With Battery Of Backup Time 60 Minutes ब्रांड   Brand : BPE ब्रांड प्रकार   Brand Type : Registered Brand कैटलॉग की स्थिति   Catalogue Status: OEM verified catalogue कैसे बेचा जा रहा है   Selling As : OEM verified Reseller श्रेणी का नाम और चतुर्भूति   Category Name & Quadrant : Online UPS (V2) (Q2) मॉडल   Model: MF1101L एचएसएन कोड   HSN Code: 8504	2	pieces	29,955	NA	59,910
कुल ऑर्डर मूल्य   Total Order Value (in INR)						59,910

परेषिती विवरण | Consignee Detail

क्र.सं.   S.No	परेषिती   Consignee	वस्तु   Item	लॉट नंबर   Lot No.	मात्रा   Quantity	दिनांक के बाद डिलीवरी शुरू करना है   Delivery Start After	वितरण पूरा कब तक करना है   Delivery To Be Completed By
1	पद   Designation : SP ANAKAPALLE ईमेल आईडी   Email ID : doanakapalle.ap@indiapost.gov.in संपर्क   Contact : 08924-222318-222118 जीएसटीआईएन   GSTIN : 37AAAGH0104H1ZZ	BPE Online UPS of Rating 1.0 KVA With Battery Of Backup Time	-	2	27-Mar-2024	25-Jun-2024

**Product Specification for BPE Online UPS of Rating 1.0 KVA With Battery Of Backup Time 60 Minutes**

विवरण   Specification	उप-विवरण   Sub-Spec	मूल्य   Value
Generic	Rating in KVA	1.0 KVA
	Switching Technology	IGBT-PWM
	Input Voltage	AC Single phase 160V - 260V 50Hz
	Output Voltage	AC Single phase 230V +/-1% 50 Hz
	Warranty for UPS (Years)	3
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS ( Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021 )	With Battery
	Type of Battery (hint: NA in case Battery not provided)	SMF-VRLA conforming to IISI:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest
	Backup time (Minutes) (hint: NA in case battery not provided)	60 Minutes
	Battery Make	Exide/Quanta
	Battery Model Number	N/A
	Battery capacity (Ah)	42
	Weight of the Battery (kg)	13
	Number of Batteries	3
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time
	Warranty for battery (Years) by Battery Manufucaturer/Brand hint: NA in case battery not provided	2
Installation and Commissioning or Service	Accessories with Battery	NA
	Installation and Commissioning ( Covered in the Scope of Supply)	Provided
	After sales service ( Turn Around Time)	Within 48 hours
	Preventive Maintenance ( Hint: Mention Timeline if provided, NA if not provided)	Half Yearly
Performance / Functional	Other Services provided	PAN India service support on 24 x 7 basis,AMC support available warranty,Availability of spares in close proximity (Spares should be easily available close to the site)
	Inbuilt isolation transformer	Without
	Overall Efficiency (%)	>=90% with Inbuilt isolation transformer
	Power Factor Load Supported	0.8 or better
	Overload limit	20% Overload for minimum 5 minute,50% Overload for minimum 1 minute
	Total Harmonic Distortion(THD) (%)	3% Maximum @ 100% Linear Load
Accessories	Other Functional Features	Crest factor on full non-linear load is not less than 3:1,Noise level (1 meter distance from UPS) should be less than 70dB,Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD : 8 to 10 Hours,Maximum overshoot and Under shoot of output rated voltage (in percentage) (4%),Voltage Regulation from no load to full load (%) (< / = 2%),UPS input power factor better than 0.95 (at rated voltage)
	Accessories	Rack for Batteries,Cabling 6 meters ( input upto 3m and output upto 3m)
Salient Features	Protection	Protection for under voltage at battery terminal,Protection of Over voltage,Short Circuit & over load at UPS output terminal,Over temperature protection
	Metering	Input Voltage,Output Voltage,Input Frequency,Output Frequency,Input Power,Output Power
	Alarms and Indications	Indicator for Mains presence,Indicator for Battery charging and discharging,Indicator for Output Over Load with Audible Alarm,Indicator for Low Battery Voltage with Audible Alarm,Alarm for Over temperature,Alarm for Low Battery
	Additional Features	Pure Sinewave AC Output
	Provide URL of the catalogue	<a href="http://www.bpee.com">www.bpee.com</a>
	Type of Design / Construction	Floor Standing
	Form factor of UPS	NA (for Floor Standing)

Design / Construction	Enclosure (mm)	1.2 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP21
	DC Bus Voltage (In Volts)	36
	Other Constructional Features	Mains ON/OFF MCB, Static bypass facility, UPS shall be free from workmanship defects, sharp edges, nicks, scratches, burst, etc. All fasteners shall be fixed properly. The equipment shall be complete with all parts and all parts shall be functional
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	50 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	95 percent
Buyer Specific Requirement	Environmental Test Report Requirements	Damp Heat Test : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C
	Battery Test Report	Capacity Test Report as per relevant governing specifications from Govt Lab/NABL accredited lab
	Intended Applications	Support for Data Centers, Network operating centers, Security operation centers, State and District centers, Command and Control center etc., across the Country to provide impetus to the e-Governance services e.g. Public food distribution, e Way bill, Counseling, e-Office, IVFRT etc., services under Digital India Programme, Network IT Equipment
	Other Requirements	ROHS compliance, KW rating shall be 0.8 time of KVA rating
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	OEM
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

#### ईपीबीजी विवरण | ePBG Detail

NA

#### नियम और शर्तें| Terms and Conditions

##### 1. Special terms and conditions- Version:1 effective from 06-07-2022

1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS ( Version 2.0) with reference to Installation and Commissioning.

**Seller's Responsibility:** Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

**Buyer's Responsibility:** Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

##### 2. General Terms and Conditions-

2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.