

अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687782997878

अनुबंध तिथि | Generated Date : 27-Mar-2024

संगठन विवरण Organisation Details		खरीदार विवरण Buyer Details				
प्ररूप Type :	State Government	पद Designation :	Assistant Accountant			
मंत्रालय Ministry :	-	संपर्क नंबर Contact No. :	-			
विभाग Department :	Social Welfare (Sanik Kalyan) Department Uttar Pradesh	ईमेल आईडी Email ID :	buycon82.swsdkup.up@gembuyer.in			
संगठन का नाम Organisation Name :	N/A	जीएसटीआईएन GSTIN :	-			
कार्यालय क्षेत्र Office Zone :	Directorate Of Social Welfare Up Lucknow	पता Address :	District Social Welfare Officer, Vikas Bhawan, District Kanpur Nagar, Uttar Pradesh Pin code 208002, KANPUR NAGAR, UTTAR PRADESH-208002, India			
वित्तीय स्वीकृति विवरण Financial Approval Detail		भुगतान प्राधिकरण विवरण Paying Authority Details				
आईएफडी सहमति IFD Concurrence :	No	Role:	BUYER			
प्रशासनिक अनुमोदन का पदनाम Designation of Administrative Approval:	BUYER	भुगतान का तरीका Payment Mode:	Offline			
वित्तीय अनुमोदन का पदनाम Designation of Financial Approval :	BUYER	पद Designation :	Assistant Accountant			
		ईमेल आईडी Email ID :	buycon82.swsdkup.up@gembuyer.in			
		जीएसटीआईएन GSTIN :	-			
		पता Address:	District Social Welfare Officer, Vikas Bhawan, District Kanpur Nagar, Uttar Pradesh Pin code 208002, Kanpur Nagar, UTTAR PRADESH-208002, India			
विक्रेता विवरण Seller Details						
जेम विक्रेता आईडी GeM Seller ID :	BFTY230007911171					
कंपनी का नाम Company Name :	VISHWAS ENTERPRISES					
संपर्क नंबर Contact No. :	07007685151					
ईमेल आईडी Email ID :	malasingh8707@gmail.com					
पता Address :	E W S 128, MAHARSHI DAYANAND VIHAR, KALYANPUR, Kanpur Nagar, Kanpur Nagar, UTTAR PRADESH-208017, -					
एमएसएमई पंजीकरण संख्या MSME Registration number :	-					
जीएसटीआईएन GSTIN:	09BRTPM1229A1ZT					
*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा GST / Tax invoice to be raised in the name of - Buyer						
वितरण निर्देश Delivery Instructions : OK						
उत्पाद विवरण Product Details						
#	आइटम विवरण Item Description	आइटम विवरण Ordered Quantity	इकाई Unit	इकाई मूल्य (INR) Unit Price (INR)	कर विभाजन (INR) Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम Product Name : Unbranded RO Water Plant for Hemodialysis 1000 Ltrs/Hr Capacity ब्रांड Brand : NA ब्रांड प्रकार Brand Type : Unbranded कैटलॉग की स्थिति Catalogue Status: Catalogue not verified by OEM कैसे बेचा जा रहा है Selling As : Reseller not verified by OEM श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : RO Water Plant for Hemodialysis (Q3) मॉडल Model: RLP-RR0-48 एचएसएन कोड HSN Code: HSN not specified by seller	2	pieces	58,000	NA	116,000
कुल ऑर्डर मूल्य Total Order Value (in INR)						116,000
परोक्षी विवरण Consignee Detail						
क्र.सं. S.No	परोक्षी Consignee	वस्तु Item	लॉट नंबर Lot No.	मात्रा Quantity	दिनांक के बाद डिलीवरी शुरू करना है Delivery Start After	वितरण पूरा कब तक करना है Delivery To Be Completed By
1	पद Designation : Assistant Accountant ईमेल आईडी Email ID : buycon82.swsdkup.up@gembuyer.in संपर्क Contact : - जीएसटीआईएन GSTIN : -	Unbranded RO Water Plant for Hemodialysis	-	2	27-Mar-2024	11-Apr-2024

पता | Address : District Social Welfare Officer, Vikas Bhawan, District
Kanpur Nagar, Uttar Pradesh Pin code 208002,
KANPUR NAGAR, UTTAR PRADESH-208002, India

1000 Ltrs/Hr Capacity

Product Specification for Unbranded RO Water Plant for Hemodialysis 1000 Ltrs/Hr Capacity

विनिर्देश Specification	उप-विनिर्देश Sub-Spec	मूल्य Value
GENERAL FEATURES	Clinical Purpose	RO water for hemodialysis to be applied in therapies such as HD, SLED, HDF, HF
	Product name	RO Water Plant for Hemodialysis
	Plant capacity (Ltrs/Hr)	1000
	Plant type	Microprocessor/microcontroller controlled Single stage RO water system (Feed water TDS less than 500 PPM)
	Various stages in RO water treatment process	Pre-filter or Sediment filter, Carbon filter, Water softner, Reverse Osmosis system, Distribution system, Storage Tank, Ultraviolet disinfection, Final filtration, Final alarms, System monitoring and disinfection
	System type	Offline
	System shall have microprocessor based control panel for ease of operation and inbuilt process logic	Yes
	System shall have auto start/stop based on water level in the supply tank	Yes
	System shall be equipped with Electrical panel/MCB for plant protection	Yes
PRE-TREATMENT	Raw water mesh filtering size to prevent big dust/sand particles with back wash control	50 to 200 microns
	Vertical water tank with automatic water float	Yes
	Raw water pump with automatic pressure control and run dry protection	Yes
	Raw water feed pump type	Centrifugal
	Double raw water pump (one active and the other stand by)	No
	Raw water feed pump capacity (LPH)	1500
	Sand/iron filter with 20micron filter and sample valve	Yes
	Softener for one in operation while the other in standby and vice-versa with sample valve with brain tank and automatic regeneration capacity	Yes
	Double activated Carbon filter to remove Chlorine and Chloramines with sample valve	Yes
	Micron particle filter after activated Carbon filter for removing suspended particles more than micron size	1
	All pretreatment module should be programmable back wash and regeneration facility	Yes
	Online rotameter for measuring flow	Yes
	Pressure monitoring facility of all filtering stages with glycerin filled SS pressure gauge	Yes
	Sample valve facility for all filtering stages	Yes
RO UNIT FOR MAIN TREATMENT	Distribution of RO plant water sufficient for number of dialysis machines	5-10
	Monitoring facility for input and output water conductivity, feed water pressure and injection flow rate	Yes
	Alarm against low feed water, high output conductivity and high temperature of pump motor	Yes
	Unused water feed back facility to RO unit for saving on water injection in online mode	Yes
	The unit should be programmable and automatic rinsing/flushing facility at regular intervals when system is not in use, to prevent drying of filter media	Yes
	Emergency mode operation to run permeate output in case of electronic failure	Yes
RO MEMBRANE	Efficiency of unit with maximum saving of water (%)	55 to 75
	Sample valve for permeate	Yes
	Material of Booster pump (offline)	NA
	Vertical storage water tank with automatic float control for filling and dry run protection for off-line system	NA

POST TREATMENT	Direct and indirect feed for full close loop distribution piping system	Yes
	Chemical disinfection and decalcification	Semi-automatic
	Provision of volume controlled heat disinfection of permeate loop complied with ISO 15883	Yes
	The permeate should be supplied to distribution loop through 0 point 2 micron bacteria filter for offline system using pex piping and high grade SS316 push pull connectors	NA
	The distribution loop should contain loop pressure regulator to maintain the desired loop back pressure	Yes
USER INTERFACE	Digital display of values of Conductivity/permeable flow/reject flow/temperature/pressure monitoring	Yes
	Touch screen/button type illuminated display for easy to finger operation of user	Yes
	Signal and control lights with possibility to connect external lights	Yes
	Software update via SD Card or Ethernet	No
	Memory storage device	No
STANDARD CONSUMABLES AND ACCESSORIES	All media and consumables (membrane, cartidge filter, filter media, chemicals, softner salt) for setting up and standardization should be provided	Yes
	Seller should ensure the availability of all consumables required to run the RO plant during complete warranty period to be purchased by the buyer independently at actual cost	Yes
	UPS of Suitable Capacity to pe provided	No
CERTIFICATIONS & REPORTS	Submission of Test Report for permeate water quality as per AAMI/ISO-13959/13500 from Central Govt/NABL/ILAC accredited Lab to prove the conformity to declared specification after installation	YES
	Product certification	EU-CE
	Certificate No	CE-16084
	Certificate Date	14 th may 2023
	Certificate issuing authority	UKCERT
	Four digit number of notified body If product is EU-CE certified	1608
	Certification, performance and safety standards specific to the device	IEC-60601
	Submission of all the certifications and test reports to the buyer along with supplies on demand	Yes
PRE-INSTALLATION REQUIREMENT FOR THE BUYER	All Pre-installation requirements along with site preparation should be provided by the seller to the buyer well in advance before the supply of equipment	Yes
	All Pre-installation requirements should be done by the buyer	Yes
	Minimum room size required for the plant (H x W x L) m	3050 x 7000 x 3050
	Feed water line till RO room	Yes
	Number of drain outlets required	6
	Overhead tank for storage depending on plant size	Yes
	Door width required for RO room (cm)	120
	Airconditioning as per rquirements	Yes
Power requirements	220-240 VAC, single phase	
INSTALLATION & TRAINING	Supplier to perform installation, safety and operation checks before handover	Yes
	Training of users in operation and basic maintenance shall be provided	Yes
WARRANTY & MAINTENANCE	Warranty in Years (Option of comprehensive warranty is available through bidding only, which if opted will supersede normal warranty in the catalogue)	2
	User technical and maintenance manual detailing complete maintaining schedule with routine maintenance should be provided	Yes
	Contact details of manufacturer, supplier and local service agent to be provided	Yes

टिप्पणी | Note:: Seller has given an undertaking that it has made arrangements for getting the stores from an authorized distributor / dealer / channel partner of the OEM of the offered product. At the time of delivery of goods, Seller will provide necessary chain documents (in the form of GST Invoice) to prove that the supplied goods are genuine and are being sourced from an authorized distributor / dealer / channel partner of the OEM. In case of any complaint about genuineness of the supplied products, Seller shall be responsible for providing genuine replacement supplies.

ईपीबीजी विवरण | ePBG Detail

NA

नियम और शर्तें | Terms and Conditions

1. Special terms and conditions- Version:2 effective from 24-11-2023

1.1.1. Comprehensive warranty:

Comprehensive warranty shall include preventive maintenance including calibration as per technical/ service /operational manual of the manufacturer, service charges and spares,. During the warranty period commencing from date of the successful completion of warranty period, Service personnel shall visit each consignee site as recommended in the manufacturer's technical/ service /operational manual, at least once in six months. warranty shall not be including the consumables .Further there will be 98% uptime warranty during warranty period on 24 (hrs) X 7 (days) X 365 (days) basis, with penalty, to extend warranty period by double the downtime period.

2. Service centres:

Details of Service outlets in India to render services for equipment to be furnished to buyer/consignees with complete address ,telephone numbers, e mails etc at time of making the supplies .It shall be the responsibility of seller to ensure that authorized service centres are available to cater to the areas where supplies are made within reasonable distance from where the service calls can be handled. Details of toll free numbers for service call and online registration of service requests also to be provided buyer/consignee at the time of supplies.

3. Source of supply:

It shall be responsibility of seller to provide Documents regarding source of equipments such as copy of Performa invoice or any other documents to establish that the products supplied are manufactured by OEM indicated and sourced from them.

4. Packing and Marking:

Medical equipments being very delicate and sensitive packing for the goods should be strong and durable enough to withstand transit including transhipment (if any), rough handling, open storage etc. without any damage, deterioration etc. .The size, weights and volumes of the packing cases, remoteness of the final destination of the goods, availability or otherwise of transport and handling facilities at all points during transit up to final destination,. Quality of packing, the manner of marking within & outside the packages and provision of accompanying documentation shall take in to consideration the type of medical equipments being supplied. The accessories shall be suitably labelled and packed .Each of the package shall be marked on three sides with indelible paint of proper quality: indicating contract number and date , brief description of goods including quantity ,. Packing list reference number , country of origin of goods and any other relevant details.

5. Spare Parts:

Seller shall provide materials, information etc. pertaining to spare parts manufactured and supplied by the OEM . It shall be ensured that the required spares are available for purchase at least for 10 years from date of supplies .In case due to any reasons the production of the spare parts is discontinued sufficient advance notice should be given to the buyer/consignee before such discontinuation to provide adequate time to purchase the required spare parts etc. Further, OEM and their service centres/dealers shall carry sufficient inventories to assure ex-stock supply of consumables and spares for the equipments so that the same are available.

OEM or reseller shall always accord most favoured client status to the buyer/consignee and shall give the most competitive price for spares and consumables of its machines/equipments supplied

6. Installation, Training, Manuals:

Seller shall be responsible to carry out Installation & commissioning, Supervision and Demonstration of the goods. They shall provide required jigs and tools for assembly, minor civil works for the completion of the installation and Training of Consignee's representatives for operating and maintaining the equipment and Supplying required number of operation & maintenance manual for the goods. In case the category parameters are specifying any requirements regarding the installations , training and manuals the same shall also be applicable.

7. Electrical safety checking:

Sellers are required to make sure that they furnish the list of equipments with carrying out routine and preventive maintenance to buyer/consignee .They should make sure to periodically check the electrical safety aspects as per BIS Safety Standards or equivalent .In case they do not have required equipment for such testing should ensure that the equipments checked for electrical safety compliance through labs with facilities for such checking during every preventive maintenance call.

8. Software:

All software updates should be provided free of cost during warranty period.

2. General Terms and Conditions-

2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.

