

अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687729612072

अनुबंध तिथि | Generated Date : 28-Mar-2024

संगठन विवरण Organisation Details	खरीदार विवरण Buyer Details
प्रकार Type : State Government मंत्रालय Ministry : - विभाग Department : Home Department Uttar Pradesh संगठन का नाम Organisation Name : Police Department कार्यालय क्षेत्र Office Zone : Adg Bareilly Zone	पद Designation : SP Shahajahanpur संपर्क नंबर Contact No. : - ईमेल आईडी Email ID : spsha-up@nic.in जीएसटीआईएन GSTIN : N पता Address : SP OFFICE, NEAR KATCHERY SHAHJAHANPUR, SHAHJAHANPUR, UTTAR PRADESH-242001, India

वित्तीय स्वीकृति विवरण Financial Approval Detail	भुगतान प्राधिकरण विवरण Paying Authority Details
आईएफडी सहमति IFD Concurrence : No प्रशासनिक अनुमोदन का पदनाम Designation of Administrative Approval : SP Shahjahanpur वित्तीय अनुमोदन का पदनाम Designation of Financial Approval : SP Shahjahanpur	Role: BUYER भुगतान का तरीका Payment Mode: Offline पद Designation : SP Shahajahanpur ईमेल आईडी Email ID : spsha-up@nic.in जीएसटीआईएन GSTIN : N पता Address : SP OFFICE, NEAR KATCHERY SHAHJAHANPUR, SHAHJAHANPUR, UTTAR PRADESH-242001, India

विक्रेता विवरण Seller Details
जेम विक्रेता आईडी GeM Seller ID : 9XDE230008865742 कंपनी का नाम Company Name : M/S M.A. ENTERPRISES संपर्क नंबर Contact No. : 07985234155 ईमेल आईडी Email ID : shanukhan99445@gmail.com पता Address : 267, NEAR OLD HOME GAURD OFFICE, MOHALLA DILAZAK, TEHSIL SADAR, Shahjahanpur, UTTAR PRADESH-242001, - एमएसएमई पंजीकरण संख्या MSME Registration number : - जीएसटीआईएन GSTIN : 09ESGPA4994B1ZP

*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Buyer

वितरण निर्देश | Delivery Instructions : NA

उत्पाद विवरण Product Details						
#	आइटम विवरण Item Description	आइटम विवरण Ordered Quantity	इकाई Unit	इकाई मूल्य (INR) Unit Price (INR)	कर विभाजन (INR) Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम Product Name : PERFECT Power Generator- DG set of 20 Manual Control Panel ब्रांड Brand : PERFECT ब्रांड प्रकार Brand Type : Registered Brand कैटलॉग की स्थिति Catalogue Status : OEM verified catalogue कैसे बेचा जा रहा है Selling As : OEM verified Reseller श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : Power Generator - DG Set (up to 900 KVA) (Q2) मॉडल Model : M3205G2 एचएसएन कोड HSN Code : HSN not specified by seller	1	pieces	474,999	NA	474,999
कुल ऑर्डर मूल्य Total Order Value (in INR)						474,999

परोक्ष विवरण Consignee Detail						
क्र.सं. S.No	परोक्षी Consignee	वस्तु Item	लॉट नंबर Lot No.	मात्रा Quantity	दिनांक के बाद डिलीवरी शुरू करना है Delivery Start After	वितरण पूरा कब तक करना है Delivery To Be Completed By
1	पद Designation : SP Shahajahanpur ईमेल आईडी Email ID : spsha-up@nic.in संपर्क Contact : - जीएसटीआईएन GSTIN : N पता Address : SP OFFICE, NEAR KATCHERY SHAHJAHANPUR, SHAHJAHANPUR, UTTAR PRADESH-242001, India	PERFECT Power Generator- DG set of 20 Manual Control Panel	-	1	28-Mar-2024	27-Apr-2024

Product Specification for PERFECT Power Generator- DG set of 20 Manual Control Panel

विनिर्देश Specification	उप-विनिर्देश Sub-Spec	मूल्य Value
Power Generator INSTALLATION CONFIGURATIONS	Power Generator installation configurations as defined in CPWD General Specifications for Electrical works - Part VII (DG Set)	Fixed (Power Generators are permanently installed)"
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (kVA)	20
	No of Phase (Single Phase-3-5kVA) (Single Phase or Three Phase-5 & 7-5, 10,15, 20, 25, 30 & 40 kVA) (Three Phase-50 to 900 kVA)	Three Phase
ENGINE	Make of Engine	Mahindra&Mahindra
	Model Number of Engine	M3205G2
	Capacity of Engine (cc)	2048
	Rated Engine Power (kWm)	100 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (KVA) of power generator + Any Auxilary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency
	Type of Engine cooling	Liquid Cooled
	Type of governer	Mechanical
	Number of cylinders (nos)	3
	No of Strokes (nos)	4
	Rated RPM of Engine (RPM)	1500
	Fuel	High Speed Diesel (HSD)
	Overload capacity	Engine is capable of delivering an output of 10% in excess of rated KVA for a period of one hour in any period of 12 hours continous running
	Specific Fuel Consumption (gm/kWh)	200 to 265
	Starting voltage (volt)	12
	Salient Features of Engine	Turbo Charged Engine,Naturally aspirated engine,Direct injection Fuel System,CRDi Fuel System,cold start upto (-20 deg c),No derating applicable upto 4500 above MSL of altitude at 25 degree celcius,Indirect injection (IDI) Fuel System
Class of governer	A2 or better	
"Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Transient) "	10	
"Maximum Recovery Time in Seconds on suddenly taking-off the rated load(Transient) "	10 second	
Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Permanent)	3	
"Maximum Change		

GOVERNING CLASS	of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Transient) "	3
	"Maximum Recovery Time in Seconds on a change of load, both on and off, by all steps of 25 percent of the rated load(Transient) "	3 second
	"Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Permanent)	1
ALTERNATOR	AC GENERATOR (ALTERNATOR) Make	LS/CG
	AC GENERATOR (ALTERNATOR) model Number	LS/CG
	Alternator Voltage Rating	415 Volt
	Rating of AC Generator (KVA)	20
	Power Factor of AC generator	0.8
	Efficiency at rated Power factor at 75% of full Load	94 percent
	Conformity to Indian Standard (for Alternator)	Generally conforming to IS:13364 (Part-2) latest (Above 20 KVA)
	Type of alternator	Brushless
	Voltage Regulation Grade	VG 3
	Alternator IP Rating	IP 23
	Class of Insulation	H
Salient features of Alternator	Resistance Temperature Detectors (RTD),Bearing Temperature Detectors (BTD),space heater	
CONTROL PANEL	Control Panel	Manual Control Panel
	Control Panel Location	Inside the canopy
	IP Rating of Control Panel	IP 53
	Display meters in the control panel (with appropriate rating and accuracy class) - inclusive in the scope of supply	Voltmeter,Ammeter,Frequency meter,Power Factor meter,Multifunctional Digital display meter (displaying Voltage, Current, Frequency, Power Factor)
	Other devices in the control panel (with appropriate rating) - inclusive in the scope of supply	Required switches and cutout,MCB,MCCB,Contactor,Circuit breaker,Battery charger
	Displayed parameters/Features	Engine Speed,Lube oil pressure,Coolant/cylinder head Temperature,Engine running hours,Engine battery voltage,Engine Running status,Generator Voltage (Ph-Ph),Generator Voltage (Ph-N),Generator Current (R, Y, B),Generator apparent Power (kVA),Generator active Power (kW),Powerfactor,Frequency,Fuel level,Event log,Control supply Voltage,Temperature scanner (RTD,BTD)
	Indicators	Low Lube oil pressure,High water / coolant / cylinder head temperature,Low fuel level,Over speed

	Audio Alarm	Low Lube oil pressure, High water / coolant / cylinder head temperature, Low fuel level, Over speed
ACOUSTIC ENCLOSURE	Acoustic Enclosure (inclusive in the scope of supply)	Yes, Power Generator supplied with Acoustic Enclosure
	Sheet Thickness(mm)	1.6
	Thickness of insulation	20 millimeter
	Density of insulation (kg/cubic m)	20
	Noise level at 1 meter (dB)	75
Fuel Tank	Fuel Tank Capacity	75 liter
	Number of Fuel tank	1
	Fuel Tank Sheet Material Thickness(mm)	2
	Fuel Tank Fabricated Material	M.S Sheet
	Fuel Tank Features	Fuel Tank capacity is sufficient for 8 hrs of running at full load
BATTERY	Battery Type & Specification	"Low Maintenance free to IS: 14257 for high cranking performance"
	Battery capacity (Ah)	65
	No of batteries	1
SALIENT FEATURES	Salient Features of Power Generator	Glass window on Accoustic Enclosure in front of the Control Panel, Emergency Stop outside the Accoustic Enclosure
	Additional Features	NA
TRAILER	Trailer	NA for Fixed/Skid Mounted Power Generator
	Pay load of the Trailer	0 kilogram
	Number of Axlels	0
	Number of wheels	'NA' for without trailer
	Wheel Tyre size	0 inch
	Brakes	NA for Fixed/Skid Mounted Power Generator
	Trailer Complying to CMVR act and Regulation	NA for Fixed/Skid Mounted Power Generator
	Maximum permissible Speed of Trailer(Km/hr)	0
	Trailer unladen weight	0 kilogram
	Trailer overall length	0 millimeter
	Gross Towing Weight (including Power Generator)	0 kilogram
	Salient Features of trailer	NA
General Technical Requirements (GTR) / Commissioning(Part-1)	General Technical Requirements (GTR) / Commissioning(Part-1)	a) Power Generator shall be complete with Diesel Engine, Alternator and AMF/MANUAL Control Panel along with Acoustic Enclosure. Diesel engine and alternator shall be closely coupled or provided with flexible coupling and mounted on a base plate / M.S. frame of robust in construction.
	General Technical Requirements (GTR) / Commissioning(Part-2)	b) Anti-Vibration mountings shall be provided for complete Power Generator in case of flexible coupling. In case of direct coupling Anti-Vibration mountings shall be provided for the Engine as well as the alternator.
	General Technical Requirements (GTR) /	c) Power Generator should have protection against under voltage, over voltage, under frequency, over frequency, low battery voltage, over current, earth-fault, short circuit, phase sequence change etc.

General Technical Requirements (GTR) / Commissioning	Commissioning(Part-3)	
	General Technical Requirements (GTR) / Commissioning(Part-4)	d) Automatic Mains Failure (AMF) control panel, where applicable, shall be able to start up the Power Generator and transfer the load on to the Power Generator on mains failure without requiring any human intervention. Similarly on restoration of mains supply, it shall be able to transfer the load to mains supply and switch off the Power Generator automatically.
	General Technical Requirements (GTR) / Commissioning(Part-5)	e) Control Panel (Manual / AMF), where applicable, shall be equipped with suitable Voltmeter, Ammeter, Frequency meter, power factor meter (these items can be alternatively supplied in one multifunctional digital display meter), battery charger, indicators, various switches and cutout / MCB / MCCB / Contactor / Circuit breaker for the DG output of appropriate rating and accuracy class as per trade practice for better utility.
	General Technical Requirements (GTR) / Commissioning(Part-6)	f) Supply and installation of a change-over Switch / MCCB of suitable rating for Power Generator with manual control panel, where applicable, is inclusive in the scope of supply.
	General Technical Requirements (GTR) / Commissioning(Part-7)	g) Acoustic Enclosure shall be made of Pre-treated and Powder coated CRCA Sheet. The sheet shall be Pre-treated and Powder coated with weather-proof paint. The Acoustic Enclosure shall be vermin proof. The enclosure shall accommodate the (daily service) fuel tank of the Power Generator to make the system compact.
	General Technical Requirements (GTR) / Commissioning(Part-8)	h) Power Generators shall meet the requirements of Environmental (Protection) Rules 1986 as laid down by Min. of Environment & Forests read with GSR 371 (E) dated 17.5.2002,GSR 520(E)dated 1.7.2003 , No.448 (E)dated 12.07.2004 , GSR 771(E) dated 11.12.2013 GSR 232(E)dated 31.03.2014,Gazette Notification No.167 dated. 31.03.2014 and Gazette Notification No. 578 dated. 11.11.2014 in respect of noise and emission norms. The latest amendments to above GSRs shall be applicable as and when amended by Ministry of Environment and Forest.
	General Technical Requirements (GTR) / Commissioning(Part-9)	i) Standard set of tools consisting of a set of 3 spanners, one screw driver, one standard plier and one nose plier of appropriate size shall be provided along with each Power Generator.
	General Technical Requirements (GTR) / Commissioning(Part-10)	j) Supply of Fuel tank of suitable capacity, sufficient for minimum 8 hours running/990 liters(whichever is lower) the Power Generator, is inclusive in the scope of supply. Fuel Tank shall be complete with fuel piping (between fuel tank and diesel engine), valves, level indications and all standard accessories. MS pipes, heavy class of suitable dia conforming to IS 1239 (Part-1) - latest shall be used for fuel piping.
	General Technical Requirements (GTR) / Commissioning(Part-11)	Buyer's Responsibilities: i. Mains ACB for AMF operation shall be provided by the buyer for DG set rating above 600 KVA and above .For DG set other ratings seller shall provide mains and DG contactor/breaker, ii. Exhaust piping, extra civil work, distribution board shall be provided by the buyer. iii. Consumables such as filters, lube oil at the time of servicing during warranty period shall be provided by the buyer. iv. Obtaining necessary approvals, if any, is the responsibility of the buyer.
	Above General Technical Requirements (GTR) / Commissioning have been seen, read, understood and agreed to comply	Yes
SCOPE OF INSTALLATION	Installation	with installation - inclusive in the scope of supply
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-1)	a) Installation of Power Generator when offered by the vendor is inclusive in the scope of supply and shall be done by the seller. The installation work of Power Generator and its constituent parts shall be generally conforming to CPWD General Specification for Electrical Works, Part - VII - latest. b) Foundation shall be constructed by the seller. Foundation shall be of PCC type with the ratio of 4:2:1. The length and breadth of the foundation shall be 300 mm more from the respective length and breadth of the Power Generator. The height of the foundation shall be 400 mm, i.e., 200 mm below and 200 mm above the ground level. All the materials / labour required for foundation work shall be supplied by the seller.
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-2)	c) Supply, laying and termination of interconnecting power and control cable shall be done by the seller. The cable supplied shall be ISI marked heavy duty PVC insulated, armoured cable, with PVC outer Sheath of Type ST-2 (FR Grade, Category C1), with aluminium conductor having insulation of PVC compound type -C, suitable for rated voltage upto and including 1100 volts and conforming to IS: 1554 (Part-1) latest. For 3-Phase Power Generators, 3.5 core or higher core cables shall be used. Total length of the cable supplied by the seller shall be within 30 meters for each Power Generator with manual control panel and within 60 metres for each Power Generator with AMF control panel. The current rating of the cables shall be as indicated below: 2C, 6 Sq mm for Single Phase, 3.5 & 5.0 KVA 2C, 10 Sq mm for Single Phase, 7.5 & 10 KVA 2C, 25 Sq mm for Single Phase, 15 KVA 2C, 35 Sq mm for Single Phase, 20 KVA 2C, 70Sq mm for Single Phase, 25 KVA 2C, 95Sq mm for Single Phase, 30 KVA 2C, 120Sq mm for Single Phase, 40 KVA 4C, 4 Sq mm for Three Phase,
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of	d) 10 KVA 4C, 6 Sq mm for Three Phase, 15 KVA 4C, 10 Sq mm for Three Phase, 20 & 25 KVA 4C, 16 Sq mm for Three Phase, 30 KVA 3.5C, 25 Sq mm for Three Phase, 40 KVA 3.5C, 35 Sq mm for Three Phase, 50 KVA 3.5C, 70 Sq mm for Three Phase, 62.5 & 75 KVA 3.5C, 95 Sq mm for Three Phase, 82.5 KVA 3.5C, 120 Sq mm for Three Phase, 100 KVA 3.5C, 185 Sq mm for Three Phase, 125 KVA 3.5C, 300 Sq mm for Three Phase, 160 KVA 3.5C, 2 Run of 120 Sq mm for Three Phase, 180 KVA 3.5C, 2 Run of 150 Sq mm for Three Phase, 200 KVA 3.5C, 2 Run of 185 Sq mm for Three Phase, 225 KVA 3.5C, 2 Run of 240 Sq mm for Three Phase, 250 & 275 KVA 3.5C, 3 Run of 185 Sq mm for Three Phase, 320 KVA 3.5C, 3 Run of 240 Sq mm for Three Phase, 380 & 400 KVA 3.5C, 4 Run of

	supply(Part-3)	240 Sq mm for Three Phase, 500, 600 & 750 KVA 3.5C, 6 Run of 240 Sq mm for Three Phase, 900 KVA
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-4)	e) Construction of suitable earthing station and necessary connections shall be done by the seller. All the materials / labour required for construction of earthing station shall be supplied by the seller. The total number of earthing pits/stations shall be 4, i.e., 2 for neutral and 2 for body-earthing. Netutral earthing shall be done with copper Plate and Body earthing shall be done with G.I. plate / Copper. The consignee should choose installation site in such a way that the earthing stations can be made within 10 metres of the Power Generator. Earthing station shall be typically constructed as per prevalent standard practices and shall be generally conforming to CPWD General specification for Electrical Works, Part - VII & Part - I - latest. e) Installation of Fuel Tank including foundation / stand shall be done by the seller. f)The warranty is applicable upto specified value of month/hours whichever occurs first's.
	Above Scope of installation for Diesel Generating Set when offered by the vendor has been seen, read, understood and agreed to comply	Yes
WARRANTY/SERVICES	Warranty on Complete power genertor/DG Set	24 month
	Warranty in running hours	5000 hour
	Number of preventive maintenance visits offered in an year during warranty period (Supply of all consumables is the buyer's responsibilty)*	1
	Response Time to attend the complaint during Warranty	1 day
	Time Duration for Repairing /Replace the defect during Warranty	2 day
TEST REPORTS	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	Certificates required as per CPCB,Govt Lab,NABL accredited lab
	Test report Available for (Test/approval)	Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB,COP Certificate for engine,Type test report and Endurance test report for Engine as per IS: 10001 latest / IS: 10002 latest,Type test report for Alternator as per IS:13364 (Part-1) latest / IS:13364 (Part-2) latest to prove conformity to the specifications
	Agree to provide all relevant documents Test Report/supporting document /reports etc to the buyer at the time of bidding or on demand	YES

ईपीबीजी विवरण | ePBG Detail

NA

नियम और शर्तें | Terms and Conditions

1. General Terms and Conditions-

1.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

1.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.