

अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687701065191

अनुबंध तिथि | Generated Date : 12-Apr-2024

बोली/आरए/पीबीपी संख्या | Bid/RA/PBP No.: [GEM/2024/B/4699168](#)

संगठन विवरण Organisation Details		खरीदार विवरण Buyer Details	
प्ररूप Type :	Central Government	पद Designation :	Sr DMM Nagpur
मंत्रालय Ministry :	Ministry of Railways	संपर्क नंबर Contact No. :	-9343086237-
विभाग Department :	Indian Railways	ईमेल आईडी Email ID :	nikhil.verma@gov.in
संगठन का नाम Organisation Name :	South East Central Railway	जीएसटीआईएन GSTIN :	N
कार्यालय क्षेत्र Office Zone:	HQ NEW GENERAL MANAGER SECR	पता Address :	DRM Office, Nagpur, NAGPUR, MAHARASHTRA-440001, India

वित्तीय स्वीकृति विवरण Financial Approval Detail		भुगतान प्राधिकरण विवरण Paying Authority Details	
आईएफडी सहमति IFD Concurrence :	No	Role:	BUYER
प्रशासनिक अनुमोदन का पदनाम	SR DEE G NGP SECR	भुगतान का तरीका	Railways
Designation of Administrative Approval:	SR DFM NGP SECR	Payment Mode:	
वित्तीय अनुमोदन का पदनाम		पद Designation :	Sr DMM Nagpur
Designation of Financial Approval :		ईमेल आईडी Email ID :	nikhil.verma@gov.in
		जीएसटीआईएन GSTIN :	N
		पता Address:	DRM Office, Nagpur, NAGPUR CITY, MAHARASHTRA-440001, India

विक्रेता विवरण Seller Details	
जेम विक्रेता आईडी GeM Seller ID :	6D69190000865585
कंपनी का नाम Company Name :	RAMP TECHNOMATION PRIVATE LIMITED
संपर्क नंबर Contact No. :	08511160695
ईमेल आईडी Email ID :	project@ramptechnomation.com
पता Address :	31/A,Sakhiba Estate,B/h Indo German Tool Room,,GIDC VATVA,Phase 4, Vatva, AHMEDABAD, GUJARAT-382445,-
एमआईआई स्थिति MII Status :	True
एमएसएमई सत्यापिता MSME verified :	Yes
एमएसएमई पंजीकरण संख्या MSME Registration number :	UDYAM-GJ-01-0114247
एमएसई सामाजिक श्रेणी MSE Social Category :	General
एमएसई लिंग श्रेणी MSE Gender :	Male
जीएसटीआईएन GSTIN:	24AACCR0880J1ZE (B) , (M) , (R)

*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Consignee

वितरण निर्देश Delivery Instructions : NA	
उत्पाद विवरण Product Details	

#	आइटम विवरण Item Description	आइटम विवरण Ordered Quantity	इकाई Unit	इकाई मूल्य (INR) Unit Price (INR)	कर विभाजन (INR) Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम Product Name : ASHOK LEYLAND-RAMP TECHNOMATION PVT LTD Power Generator-DG set of 125 AMF Control Panel ब्रांड Brand : ASHOK LEYLAND-RAMP TECHNOMATION PVT LTD ब्रांड प्रकार Brand Type : Registered Brand कैटलॉग की विवरण Catalogue Status: OEM verified catalogue कैसे बेचा जा रहा है Selling As: OEM श्रेणी का नाम और चतुर्भूति Category Name & Quadrant : Power Generator - DG Set (up to 900 KVA) (Q2) मॉडल Model: LP125D एचएसएन कोड HSN Code: HSN not specified by seller	1	pieces	924,499	NA	924,499
कुल ऑर्डर मूल्य Total Order Value (in INR)						924,499

परेषिती विवरण Consignee Detail						
क्र.सं. S.No	परेषिती Consignee	वस्तु Item	लॉट नंबर Lot No.	मात्रा Quantity	दिनांक के बाद डिलीवरी शुरू करना है Delivery Start After	वितरण पूरा कब तक करना है Delivery To Be Completed By
	पद Designation :-	ASHOK LEYLAND-RAMP				

1	ईमेल आईडी Email ID : shivdasm.0506@gov.in संपर्क Contact :- जीएसटीआईएन GSTIN :- पता Address : DRM OFFICE, Nagpur, NAGPUR, MAHARASHTRA-440001, India	TECHNOMATION PVT LTD Power Generator- DG set of 125 AMF Control Panel	-	1	12-Apr-2024	11-Jul-2024
Product Specification for ASHOK LEYLAND-RAMP TECHNOMATION PVT LTD Power Generator- DG set of 125 AMF Control Panel						
विवरण Specification	उप-विवरण Sub-Spec	मूल्य Value				
Power Generator INSTALLATION CONFIGURATIONS	Power Generator installation configurations as defined in CPWD General Specifications for Electrical works - Part VII (DG Set)	Fixed (Power Generators are permanently installed)"				
OUTPUT CAPACITY RATING/ PHASE	Nominal Rated Capacity (kVA)	125				
	No of Phase (Single Phase-3-5kVA) (Single Phase or Three Phase-5 & 7-5, 10,15, 20, 25, 30 & 40 kVA) (Three Phase-50 to 900 kVA)	Three Phase				
ENGINE	Make of Engine	ASHOK LEYLAND				
	Model Number of Engine	AL6DTIDG6				
	Capacity of Engine (cc)	5760				
	Rated Engine Power (kWm)	100 % of the required powered at STP(Standard Temperature Pressure) i.e equal to (Nominal Rated Capacity (kVA) of power generator + Any Auxiliary power Consumption by the Power generator) x Power factor(0.8) / Alternator efficiency				
	Type of Engine cooling	Liquid Cooled				
	Type of governer	Electronic				
	Number of cylinders (nos)	6				
	No of Strokes (nos)	4				
	Rated RPM of Engine (RPM)	1500				
	Fuel	High Speed Diesel (HSD)				
	Overload capacity	Engine is capable of delivering an output of 10% in excess of rated KVA for a period of one hour in any period of 12 hours continous running				
GOVERNING CLASS	Specific Fuel Consumption (gm/kWh)	200 to 265				
	Starting voltage (volt)	12				
	Salient Features of Engine	Turbo Charged Engine,Direct injection Fuel System,No derating applicable upto 4500 above MSL of altitude at 25 degree celcius,Ambient working temperature upto 55 degree celcius.				
	Class of governer	A2 or better				
	"Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Transient) "	15				
	"Maximum Recovery Time in Seconds on suddenly taking-off the rated load(Transient) "	15 second				
	Maximum Change of Speed as a Percentage of Rated Speed on suddenly taking-off the rated load(Permanent)	5				
	"Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on and off, by all steps of 25 percent of the rated load (Transient) "	4				
	"Maximum Recovery Time in Seconds on a change of load, both on and off, by all steps of 25 percent of the rated load(Transient) "	4 second				
	"Maximum Change of Speed as a Percentage of Rated Speed On a change of load, both on					

	and off, by all steps of 25 percent of the rated load (Permanent)	1.5
ALTERNATOR	AC GENERATOR (ALTERNATOR) Make	LS / CG
	AC GENERATOR (ALTERNATOR) model Number	AS PER COMPANY
	Alternator Voltage Rating	415 Volt
	Rating of AC Generator (KVA)	125
	Power Factor of AC generator	0.8
	Efficiency at rated Power factor at 75% of full Load	91.9 percent
	Conformity to Indian Standard (for Alternator)	Generally conforming to IS:13364 (Part-2) latest (Above 20 KVA)
	Type of alternator	Brushless
	Voltage Regulation Grade	VG 3
	Alternator IP Rating	IP 23
CONTROL PANEL	Class of Insulation	H
	Salient features of Alternator	NA
	Control Panel	AMF Control Panel
	Control Panel Location	Inside the canopy
	IP Rating of Control Panel	IP 53
	Display meters in the control panel (with appropriate rating and accuracy class) - inclusive in the scope of supply	Multifunctional Digital display meter (displaying Voltage, Current, Frequency, Power Factor)
	Other devices in the control panel (with appropriate rating) - inclusive in the scope of supply	Required switches and cutout, MCB, MCCB, Contactor, Circuit breaker, Battery charger
ACOUSTIC ENCLOSURE	Displayed parameters/Features	Engine Speed, Lube oil pressure, Coolant/cylinder head Temperature, Engine running hours, Engine battery voltage, Engine Running status, Generator Voltage (Ph-Ph), Generator Voltage (Ph-N), Generator Current (R, Y, B), Generator apparent Power (kVA), Generator active Power (kW), Power factor, Frequency, Fuel level, Event log, Control supply Voltage
	Indicators	Low Lube oil pressure, High water / coolant / cylinder head temperature, Low fuel level, Over speed
	Audio Alarm	Low Lube oil pressure, High water / coolant / cylinder head temperature, Low fuel level, Over speed
	Acoustic Enclosure (inclusive in the scope of supply)	Yes, Power Generator supplied with Acoustic Enclosure
	Sheet Thickness(mm)	1.6
Fuel Tank	Thickness of insulation	50 millimeter
	Density of insulation (kg/cubic m)	32
	Noise level at 1 meter (dB)	75
	Fuel Tank Capacity	175 liter
	Number of Fuel tank	1
BATTERY	Fuel Tank Sheet Material Thickness(mm)	2
	Fuel Tank Fabricated Material	M.S Sheet
	Fuel Tank Features	Fuel Tank capacity is sufficient for 8 hrs of running at full load
	Battery Type & Specification	"Low Maintenance free to IS: 14257 for high cranking performance"
	Battery capacity (Ah)	90
SALIENT FEATURES	No of batteries	1
	Salient Features of Power Generator	Glass window on Acoustic Enclosure in front of the Control Panel, Emergency Stop outside the Acoustic Enclosure
	Additional Features	NA
	Trailer	NA for Fixed/Skid Mounted Power Generator

TRAILER	Pay load of the Trailer	0 kilogram
	Number of Axles	0
	Number of wheels	'NA' for without trailer
	Wheel Tyre size	0 inch
	Brakes	NA for Fixed/Skid Mounted Power Generator
	Trailer Complying to CMVR act and Regulation	NA for Fixed/Skid Mounted Power Generator
	Maximum permissible Speed of Trailer(Km/hr)	0
	Trailer unladen weight	0 kilogram
	Trailer overall length	0 millimeter
	Gross Towing Weight (including Power Generator)	0 kilogram
General Technical Requirements (GTR) / Commissioning	Salient Features of trailer	NA
	General Technical Requirements (GTR) / Commissioning(Part-1)	a) Power Generator shall be complete with Diesel Engine, Alternator and AMF/MANUAL Control Panel along with Acoustic Enclosure. Diesel engine and alternator shall be closely coupled or provided with flexible coupling and mounted on a base plate / M.S. frame of robust in construction.
	General Technical Requirements (GTR) / Commissioning(Part-2)	b) Anti-Vibration mountings shall be provided for complete Power Generator in case of flexible coupling. In case of direct coupling Anti-Vibration mountings shall be provided for the Engine as well as the alternator.
	General Technical Requirements (GTR) / Commissioning(Part-3)	c) Power Generator should have protection against under voltage, over voltage, under frequency, over frequency, low battery voltage, over current, earth-fault, short circuit, phase sequence change etc.
	General Technical Requirements (GTR) / Commissioning(Part-4)	d) Automatic Mains Failure (AMF) control panel, where applicable, shall be able to start up the Power Generator and transfer the load on to the Power Generator on mains failure without requiring any human intervention. Similarly on restoration of mains supply, it shall be able to transfer the load to mains supply and switch off the Power Generator automatically.
	General Technical Requirements (GTR) / Commissioning(Part-5)	e) Control Panel (Manual / AMF), where applicable, shall be equipped with suitable Voltmeter, Ammeter, Frequency meter, power factor meter (these items can be alternatively supplied in one multifunctional digital display meter), battery charger, indicators, various switches and cutout / MCB / MCCB / Contactor / Circuit breaker for the DG output of appropriate rating and accuracy class as per trade practice for better utility.
	General Technical Requirements (GTR) / Commissioning(Part-6)	f) Supply and installation of a change-over Switch / MCCB of suitable rating for Power Generator with manual control panel, where applicable, is inclusive in the scope of supply.
	General Technical Requirements (GTR) / Commissioning(Part-7)	g) Acoustic Enclosure shall be made of Pre-treated and Powder coated CRCA Sheet. The sheet shall be Pre-treated and Powder coated with weather-proof paint. The Acoustic Enclosure shall be vermin proof. The enclosure shall accommodate the (daily service) fuel tank of the Power Generator to make the system compact.
	General Technical Requirements (GTR) / Commissioning(Part-8)	h) Power Generators shall meet the requirements of Environmental (Protection) Rules 1986 as laid down by Min. of Environment & Forests read with GSR 371 (E) dated 17.5.2002, GSR 520(E) dated 1.7.2003, No.448 (E) dated 12.07.2004, GSR 771(E) dated 11.12.2013 GSR 232(E) dated 31.03.2014, Gazette Notification No.167 dated 31.03.2014 and Gazette Notification No. 578 dated 11.11.2014 in respect of noise and emission norms. The latest amendments to above GSRs shall be applicable as and when amended by Ministry of Environment and Forest.
	General Technical Requirements (GTR) / Commissioning(Part-9)	i) Standard set of tools consisting of a set of 3 spanners, one screw driver, one standard plier and one nose plier of appropriate size shall be provided along with each Power Generator.
Above General Technical Requirements (GTR) / Commissioning have been seen, read, understood and agreed to comply	General Technical Requirements (GTR) / Commissioning(Part-10)	j) Supply of Fuel tank of suitable capacity, sufficient for minimum 8 hours running/990 liters(whichever is lower) the Power Generator, is inclusive in the scope of supply. Fuel Tank shall be complete with fuel piping (between fuel tank and diesel engine), valves, level indications and all standard accessories. MS pipes, heavy class of suitable dia conforming to IS 1239 (Part-1) - latest shall be used for fuel piping.
	General Technical Requirements (GTR) / Commissioning(Part-11)	Buyer's Responsibilities: i. Mains ACB for AMF operation shall be provided by the buyer for DG set rating above 600 KVA and above .For DG set other ratings seller shall provide mains and DG contactor/breaker, ii. Exhaust piping, extra civil work, distribution board shall be provided by the buyer. iii. Consumables such as filters, lube oil at the time of servicing during warranty period shall be provided by the buyer. iv. Obtaining necessary approvals, if any, is the responsibility of the buyer.
	Installation	Without installation
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-1)	Not Applicable as Installation not offered

SCOPE OF INSTALLATION	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-2)	Not Applicable as Installation not offered
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-3)	Not Applicable as Installation not offered
	Scope of installation for Diesel Generating Set when offered by the vendor - inclusive in the scope of supply(Part-4)	Not Applicable as Installation not offered
	Above Scope of installation for Diesel Generating Set when offered by the vendor has been seen, read, understood and agreed to comply	Not Applicable as Installation not offered
WARRANTY/SERVICES	Warranty on Complete power generotor/DG Set	24 month
	Warranty in running hours	5000 hour
	Number of preventive maintenance visits offered in an year during warranty period (Supply of all consumables is the buyer's responsibility)*	2
	Response Time to attend the complaint during Warranty	2 day
	Time Duration for Repairing /Replace the defect during Warranty	7 day
TEST REPORTS	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	Certificates required as per CPCB
	Test report Available for (Test/approval)	COP Certificate for engine, Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB
	Agree to provide all relevant documents Test Report/supporting document /reports etc to the buyer at the time of bidding or on demand	YES

खरीदार परिभ्राष्टि अतिरिक्त विशेषता के लिए | Buyer Defined Additional Specification for ASHOK LEYLAND-RAMP TECHNOMATION PVT LTD Power Generator- DG set of 125 AMF Control Panel

विवरण Specification	मूल्य Value
Detailed description (In case of dispute these shall supercede)	Supply of 125 KVA water cooled, 3 phase, 415 Volts Diesel Generator set with AMF panel & Acoustic enclosure conforming to IS:13364 (Part-2) latest.
Remarks	Type Approval Certificate for the specified rating of the Power Generator from any of the designated agency authorized by CPCB, COP Certificate for engine, type test report and endurance test report for engine as per IS: 10001 latest/IS: 10002 latest, type test report for alternator as per IS:13364 (Part-1) latest/IS:13364 (Part-2) latest to prove conformity to the specifications to be submitted

ईपीबीजी विवरण | ePBG Detail

सलाहकार बैंक Advisory Bank :	NA
ईपीबीजी प्रतिशेषत (%) ePBG Percentage(%):	NA

नियम और शर्तें| Terms and Conditions

1. General Terms and Conditions-

- 1.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.
- 1.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions

(ATC), as applicable

2. Buyer Added Bid Specific Terms and Conditions-

2.1 *Generic*

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

2.2 *Scope of Supply.*

Scope of supply (Bid price to include all cost components) : Only supply of Goods

2.3 *Buyer Added Bid Specific ATC:*

Buyer Added text based ATC clauses

Terms and eligibility

1. Delivery Location for supply of item:- Office of Senior Section Electrical Engineer/ CWA, Near Chhindwara Railway Station, Chhindwara, Madhya Pradesh, Pin Code- 480001.

2. Inspection: By RITES (all charge will be borne by seller). In case of any deviation from this clause offer will be summarily rejected

3. Detailed description: - Supply of 125 KVA water cooled, 3 phase, 415 Volts Diesel Generator set with AMF panel & Acoustic enclosure conforming to IS:13364 (Part-2) latest. Standard set of tools consisting of a set of 3 spanners, one screw driver, one standard plier and one nose plier of appropriate size shall be provided along with each Power Generator.

4. Warranty/Guarantee Certificate, RITES Inspection Certificate, test reports & testing/Operating manual to be submitted at the time of delivery of material.

6. Eligibility criteria:

a). OEM authorization: Only OEM or authorized dealer of OEM are eligible for participation. Authorized dealer must submit bid specific authorization of OEM along with offer.

b). Past performance: Firm shall submit past performance as per GeM clause for min 20% tender quantity. Only CRAC/R-note/Receipted challan from gazetted officer will serve as proof of supply.

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.