

अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687725007238

अनुबंध तिथि | Generated Date : 19-Apr-2024

बोली/आरए/पीबीपी संख्या | Bid/RA/PBP No.: [GEM/2023/B/3927563](#)

संगठन विवरण Organisation Details	खरीदार विवरण Buyer Details
प्रकार Type : Central Government मंत्रालय Ministry : Ministry of Water Resources River Development and Ganga विभाग Department : Rejuvenation संगठन का नाम Organisation Name : NA कार्यालय क्षेत्र Office Zone : Central Water and Power Research Station (CWPRS) पता : Pune	पद Designation : ARO संपर्क नंबर Contact No. : 020-24103254 ईमेल आईडी Email ID : kori.sk@cwprs.gov.in जीएसटीआईएन GSTIN : 27AAATC7523J1ZO पता Address : CENTRAL WATER AND POWER RESEARCH STATION, Sinhagad Road Khadakwasla R.S. Pune (M.H.), PUNE, MAHARASHTRA-411024, India

वित्तीय स्वीकृति विवरण Financial Approval Detail	भुगतान प्राधिकरण विवरण Paying Authority Details
आईएफडी सहमति IFD Concurrence : Yes प्रशासनिक अनुमोदन का पदनाम Designation of Administrative Approval : director CWPRS वित्तीय अनुमोदन का पदनाम Designation of Financial Approval : director CWPRS	Role: DDO भुगतान का तरीका Payment Mode: PFMS पद Designation : Scientist C ईमेल आईडी Email ID : cpc.cwprs-pune@gov.in जीएसटीआईएन GSTIN : N पता Address : CENTRAL WATER AND POWER RESEARCH STATION, Sinhagad Road Khadakwasla R.S. Pune (M.H.), PUNE CITY, MAHARASHTRA-411024, India

विक्रेता विवरण Seller Details
जेम विक्रेता आईडी GeM Seller ID : 5B83180000093795 कंपनी का नाम Company Name : CEDAR ENGINEERS AND SYSTEM PRIVATE LIMITED संपर्क नंबर Contact No. : 09336855701 ईमेल आईडी Email ID : cedar_engineers@rediffmail.com पता Address : C-10, SAGAR MARKET, 25/16, KARACHI KHANA, kanpur, KANPUR, U.P.-208001, - एमआईआई स्थिति MII Status : True एमएसएमई सत्यापित MSME verified : No एमएसएमई पंजीकरण संख्या MSME Registration number : UDYAM-UP-43-0010631 एमएसएमई सामाजिक श्रेणी MSE Social Category : General एमएसएमई लिंग श्रेणी MSE Gender : Male जीएसटीआईएन GSTIN : 09AACCC0402B1ZK (B), (R)

*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Buyer

वितरण निर्देश | Delivery Instructions : NA

उत्पाद विवरण Product Details						
#	आइटम विवरण Item Description	आइटम विवरण Ordered Quantity	इकाई Unit	इकाई मूल्य (INR) Unit Price (INR)	कर विभाजन (INR) Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम Product Name : Uniline Online UPS of Rating 5.0 KVA With Battery Of Backup Time 120 Minutes ब्रांड Brand : Uniline ब्रांड प्रकार Brand Type : Registered Brand कैटलॉग की स्थिति Catalogue Status : OEM verified catalogue कैसे बेचा जा रहा है Selling As : OEM verified Reseller श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : Online UPS (V2) (Q2) मॉडल Model : MAXIPOWER - 5000 एचएसएन कोड HSN Code : 8504	1	pieces	146,000	NA	146,000
कुल ऑर्डर मूल्य Total Order Value (in INR)						146,000

परोक्ष विवरण Consignee Detail						
क्र.सं. S.No	परोक्ष Consignee	वस्तु Item	लॉट नंबर Lot No.	मात्रा Quantity	दिनांक के बाद डिलीवरी शुरू करना है Delivery Start After	वितरण पूरा कब तक करना है Delivery To Be Completed By

1	पद Designation :- ईमेल आईडी Email ID : kori.sk@cwprs.gov.in संपर्क Contact : 020-24103254- जीएसटीआईएन GSTIN : 27AAATC75231ZO पता Address : CENTRAL WATER AND POWER RESEARCH STATION, Sinhagad Road Khadakwasla R.S. Pune (M.H.), PUNE, MAHARASHTRA-411024, India	Uniline Online UPS of Rating 5.0 KVA With Battery Of Backup Time 120 Minutes	-	1	19-Apr-2024	18-Jul-2024
---	--	---	---	---	-------------	-------------

Product Specification for Uniline Online UPS of Rating 5.0 KVA With Battery Of Backup Time 120 Minutes

विनिर्देश Specification	उप-विनिर्देश Sub-Spec	मूल्य Value
Generic	Rating in KVA	5.0 KVA
	Switching Technology	IGBT-PWM
	Input Voltage	AC Single phase 160V - 260V 50Hz
	Output Voltage	AC Single phase 230V +/-1% 50 Hz
	Warranty for UPS (Years)	2
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS (Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021)	With Battery
	Type of Battery (hint: NA in case Battery not provided)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest
	Backup time (Minutes) (hint: NA in case battery not provided)	120 Minutes
	Battery Make	GLOBAL OR EQUIVALENT
	Battery Model Number	GLOBAL OR EQUIVALENT
	Battery capacity (Ah)	100
	Weight of the Battery (kg)	26
	Number of Batteries	14
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time
	Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided	2
	Accessories with Battery	NA
Installation and Commissioning or Service	Installation and Commissioning (Covered in the Scope of Supply)	Provided
	After sales service (Turn Around Time)	Within 48 hours,NA
	Preventive Maintenance (Hint: Mention Timeline if provided, NA if not provided)	NA
	Other Services provided	PAN India service support on 24 x 7 basis
Performance / Functional	Inbuilt isolation transformer	With
	Overall Efficiency (%)	>/=80% & <90% with Inbuilt isolation transformer
	Power Factor Load Supported	0.8 or better
	Overload limit	20% Overload for minimum 5 minute
	Total Harmonic Distortion(THD) (%)	3% Maximum @ 100% Linear Load
Other Functional Features	Crest factor on full non-linear load is not less than 3:1,Noise level (1 meter distance from UPS) should be less than 70dB	
Accessories	Accessories	The UPS shall be complete with Trolley for battery bank,battery, Cables and connectors etc,NA
Salient Features	Protection	Protection for under voltage at battery terminal
	Metering	Input Voltage,Output Voltage
	Alarms and Indications	Indicator for Mains presence,Alarm for Low Battery
	Additional Features	Pure Sinewave AC Output
	Provide URL of the catalogue	www.unilineindia.com
Design / Construction	Type of Design / Construction	Floor Standing
	Form factor of UPS	NA (for Floor Standing)
	Enclosure (mm)	1.0 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP20
	DC Bus Voltage (In Volts)	168

	Other Constructional Features	Mains ON/OFF MCB
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	45 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	90 percent
Buyer Specific Requirement	Environmental Test Report Requirements	NA
	Battery Test Report	NA
	Intended Applications	Critical Infrastructure,Network IT Equipment
	Other Requirements	KW rating shall be 0.8 time of KVA rating
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	OEM
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

ईपीबीजी विवरण | ePBG Detail

सलाहकार बैंक Advisory Bank :	NA
ईपीबीजी प्रतिशत (%) ePBG Percentage(%):	NA

नियम और शर्तें | Terms and Conditions

1. Special terms and conditions- Version:1 effective from 06-07-2022

1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS (Version 2.0) with reference to Installation and Commissioning.

Seller's Responsibility: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

Buyer's Responsibility: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

2. General Terms and Conditions-

2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

3. Buyer Added Bid Specific Terms and Conditions-

3.1 Scope of Supply:

Scope of supply (Bid price to include all cost components) : Supply Installation Testing and Commissioning of Goods

3.2 Service & Support:

Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

3.3 Service & Support:

Dedicated /toll Free Telephone No. for Service Support : BIDDER/OEM must have Dedicated/toll Free Telephone No. for Service Support.

3.4 Service & Support:

Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

3.5 Warranty:

Warranty period of the supplied products shall be as given in specifications from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

3.6 Certificates:

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

3.7 Certificates:

ISO 9001: The bidder or the OEM of the offered products must have ISO 9001 certification.

3.8 Certificates:

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

3.9 OEM

IMPORTED PRODUCTS: In case of imported products, OEM or Authorized Seller of OEM should have a registered office in India to provide after sales service support in India. The certificate to this effect should be submitted.

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.