

## अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687714085170

अनुबंध तिथि | Generated Date : 25-Apr-2024

संगठन विवरण   Organisation Details	खरीदार विवरण   Buyer Details
प्ररूप   Type : Central PSU मंत्रालय   Ministry : Ministry of Finance विभाग   Department : BANKING SECTOR संगठन का नाम   Organisation Name : Punjab National Bank कार्यालय क्षेत्र   Office Zone : ZO CHANDIGARH	पद   Designation : Senior Manager IT संपर्क नंबर   Contact No. : -9599937732- ईमेल आईडी   Email ID : buycon487.pnb.hr@gembuyer.in जीएसटीआईएन   GSTIN : - पता   Address : PNB Circle Office Panipat, SCO-170 Sector 13-17, Huda, Panipat, PANIPAT, HARYANA-132103, India

वित्तीय स्वीकृति विवरण   Financial Approval Detail	भुगतान प्राधिकरण विवरण   Paying Authority Details
आईएफडी सहमति   IFD Concurrence : No प्रशासनिक अनुमोदन का पदनाम   Designation of Administrative Approval : dgm वित्तीय अनुमोदन का पदनाम   Designation of Financial Approval : dgm	Role: BUYER भुगतान का तरीका   Payment Mode: Offline पद   Designation : Senior Manager IT ईमेल आईडी   Email ID : buycon487.pnb.hr@gembuyer.in जीएसटीआईएन   GSTIN : 06AAACP0165G4ZQ पता   Address : PNB Circle Office Panipat, SCO-170 Sector 13-17, Huda, Panipat, HARYANA-132103, India

विक्रेता विवरण   Seller Details
जेम विक्रेता आईडी   GeM Seller ID : 2229180000558496 कंपनी का नाम   Company Name : M/S SDV ENGINEERING संपर्क नंबर   Contact No. : 09795087888 ईमेल आईडी   Email ID : sdvengineering@gmail.com पता   Address : B1/3-K-1A-4,RAVINDRAPURI EXT., VARANASI, UTTAR PRADESH-221005, - एमएसएमई पंजीकरण संख्या   MSME Registration number : UDYAM-UP-75-0008374 एमएसई सामाजिक श्रेणी   MSE Social Category : General एमएसई लिंग श्रेणी   MSE Gender : Male जीएसटीआईएन   GSTIN : 09ALBPM0505C1ZR (R)

\*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Consignee

वितरण निर्देश | Delivery Instructions : the ups is to be delivered directly to branch address VPO Mohana Sonapat 131001

उत्पाद विवरण   Product Details						
#	आइटम विवरण   Item Description	आइटम विवरण   Ordered Quantity	इकाई   Unit	इकाई मूल्य (INR)   Unit Price (INR)	कर विभाजन (INR)   Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित)   Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम   Product Name : BPE Online UPS of Rating 5.0 KVA With Battery Of Backup Time 120 Minutes ब्रांड   Brand : BPE ब्रांड प्रकार   Brand Type : Registered Brand कैटलॉग की स्थिति   Catalogue Status: OEM verified catalogue कैसे बेचा जा रहा है   Selling As : OEM verified Reseller श्रेणी का नाम और चतुर्थांश   Category Name & Quadrant : Online UPS (V2) (Q2) मॉडल   Model: PB1105L16 एचएसएन कोड   HSN Code: HSN not specified by seller	1	pieces	125,123	NA	125,123
कुल ऑर्डर मूल्य   Total Order Value (in INR)						125,123

परोक्षी विवरण   Consignee Detail						
क्र.सं.   S.No	परोक्षी   Consignee	वस्तु   Item	लॉट नंबर   Lot No.	मात्रा   Quantity	दिनांक के बाद डिलीवरी शुरू करना है   Delivery Start After	वितरण पूरा कब तक करना है   Delivery To Be Completed By
	पद   Designation : Senior Manager IT ईमेल आईडी   Email ID : buycon487.pnb.hr@gembuyer.in					

1	संपर्क   Contact : -9599937732- जीएसटीआईएन   GSTIN : - पता   Address : PNB Circle Office Panipat, SCO-170 Sector 13-17, Huda, Panipat, PANIPAT, HARYANA-132103, India	BPE Online UPS of Rating 5.0 KVA With Battery Of Backup Time 120 Minutes	-	1	25-Apr-2024	24-Jul-2024
<b>Product Specification for BPE Online UPS of Rating 5.0 KVA With Battery Of Backup Time 120 Minutes</b>						
<b>विनिर्देश   Specification</b>	<b>उप-विनिर्देश   Sub-Spec</b>	<b>मूल्य   Value</b>				
Generic	Rating in KVA	5.0 KVA				
	Switching Technology	IGBT-PWM				
	Input Voltage	AC Single phase 160V - 260V 50Hz				
	Output Voltage	AC Single phase 230V +/-1% 50 Hz				
	Warranty for UPS (Years)	2				
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS ( Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021 )	With Battery				
	Type of Battery (hint: NA in case Battery not provided)	SMF-VRLA conforming to JISC:8702(Pt.I,II&III), Stationary Lead Acid Batteries (with tubular positive plates) in monobloc container conforming to IS:13369:1992 latest				
	Backup time (Minutes) (hint: NA in case battery not provided)	120 Minutes				
	Battery Make	EXIDE/QUANTA/247PWR				
	Battery Model Number	NA				
	Battery capacity (Ah)	42				
	Weight of the Battery (kg)	20				
	Number of Batteries	10				
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time				
	Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided	2				
	Accessories with Battery	NA				
Installation and Commissioning or Service	Installation and Commissioning ( Covered in the Scope of Supply)	Provided				
	After sales service ( Turn Around Time)	Within 48 hours				
	Preventive Maintenance ( Hint: Mention Timeline if provided, NA if not provided)	NA				
	Other Services provided	PAN India service support on 24 x 7 basis,AMC support available warranty,Availability of spares in close proximity (Spares should be easily available close to the site),NA				
Performance / Functional	Inbuilt isolation transformer	With				
	Overall Efficiency (%)	>/=90% with Inbuilt isolation transformer				
	Power Factor Load Supported	0.8 or better				
	Overload limit	20% Overload for minimum 10 minute,50% Overload for minimum 1 minute				
	Total Harmonic Distortion(THD) (%)	3% Maximum @ 100% Linear Load				
Other Functional Features	Crest factor on full non-linear load is not less than 3:1					
Accessories	Accessories	Rack for Batteries,Cabling 6 meters ( input upto 3m and output upto 3m),The UPS shall be complete with Trolley for battery bank,battery, Cables and connectors etc				
Salient Features	Protection	Protection for under voltage at battery terminal,Protection of Over voltage,Short Circuit & over load at UPS output terminal,Over temperature protection				
	Metering	Input Voltage,Output Voltage,Input Frequency,Output Frequency,Output Power Factor				
	Alarms and Indications	Indicator for Mains presence,Indicator for Battery charging and discharging,Indicator for Output Over Load with Audible Alarm,Indicator for Low Battery Voltage with Audible Alarm,Alarm for Over temperature,Alarm for Low Battery				
	Additional Features	Pure Sinewave AC Output,NA				
	Provide URL of the catalogue	www.bpee.com				
	Type of Design / Construction	Floor Standing				
	Form factor of UPS	NA (for Floor Standing)				

Design / Construction	Enclosure (mm)	1.2 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP21
	DC Bus Voltage (In Volts)	120
	Other Constructional Features	UPS shall be free from workmanship defects, sharp edges, nicks, scratches, burst, etc. All fasteners shall be fixed properly. The equipment shall be complete with all parts and all parts shall be functional
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	45 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	95 percent
Buyer Specific Requirement	Environmental Test Report Requirements	Damp Heat Test : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C,two cycles of (12+12) hours each 2007),Dry Heat Test : in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs,Cold Test : in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs,NA
	Battery Test Report	Type Test Report as per relevant governing specifications from Govt Lab/NABL accredited lab
	Intended Applications	Critical Infrastructure,Network IT Equipment,Medical Equipment,Support for Data Centers, Network operating centers, Security operation centers, State and District centers, Command and Control center etc., across the Country to provide impetus to the e-Governance services e.g. Public food distribution, e Way bill, Counseling, e-Office, IVFRT etc., services under Digital India Programme,NA
	Other Requirements	ROHS compliance,KW rating shall be 0.8 time of KVA rating,NA
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	OEM
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

## ईपीबीजी विवरण | ePBG Detail

NA

## नियम और शर्तें | Terms and Conditions

### 1. Special terms and conditions- Version:1 effective from 06-07-2022

1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS ( Version 2.0) with reference to Installation and Commissioning.

**Seller's Responsibility:** Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

**Buyer's Responsibility:** Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

**Note:** The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

### 2. General Terms and Conditions-

2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.