

अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687711958687

अनुबंध तिथि | Generated Date : 08-May-2024

संगठन विवरण Organisation Details	खरीदार विवरण Buyer Details
प्ररूप Type : Central PSU	पद Designation : SENIOR MANAGER4
मंत्रालय Ministry : Ministry of Finance	संपर्क नंबर Contact No. : -
विभाग Department : Department of Financial Services	ईमेल आईडी Email ID : buycon392.ubiu.ap@gembuyer.in
संगठन का नाम Organisation Name : Union Bank of India (UBI)	जीएसटीआईएन GSTIN : -
कार्यालय क्षेत्र Office Zone : CENTRAL OFFICE DEPT OF INFORMATION TECHNOLOGY	पता Address : Union Bank of India,FGM office,47-7-30/2 ,2nd floor, Mohan Mansion, 4th Lane, Dwarakanagar, Visakhapatnam-530016. VISAKHAPATNAM, ANDHRA PRADESH-530016, India

वित्तीय स्वीकृति विवरण Financial Approval Detail	भुगतान प्राधिकरण विवरण Paying Authority Details
आईएफडी सहमति IFD Concurrence : No	Role: PAO
प्रशासनिक अनुमोदन का पदनाम Designation of Administrative Approval: AGM	भुगतान का तरीका Payment Mode: Offline
वित्तीय अनुमोदन का पदनाम Designation of Financial Approval : AGM	पद Designation : Chief Manager
	ईमेल आईडी Email ID : pay86.ubiu.ap@gembuyer.in
	जीएसटीआईएन GSTIN : 37AAACU0564G2ZF
	पता Address : Field General Manager Office, Union Bank of India, D No 47-7-30/2 , Plot 121-C, Mohan Mansion building, 2nd floor, 4th lane Dwarakanagar, Visakhapatnam, ANDHRA PRADESH-530016, India

विक्रेता विवरण Seller Details
जेम विक्रेता आईडी GeM Seller ID : A8D8180000090745
कंपनी का नाम Company Name : TECHSER POWER SOLUTIONS PRIVATE LIMITED
संपर्क नंबर Contact No. : 09448990444
ईमेल आईडी Email ID : gem@techser.com
पता Address : 12/1,TECHSER HOUSE, JALAHALLI,MES RING ROAD, SHARADAMBANAGAR,BENGALURU, Bangalore, KARNATAKA-560013, -
एमएसएमई पंजीकरण संख्या MSME Registration number : UDYAM-KR-03-0010269
एमएसई सामाजिक श्रेणी MSE Social Category : General
एमएसई लिंग श्रेणी MSE Gender : Male
जीएसटीआईएन GSTIN: 09AABCT0359D1ZK (B) , 29AABCT0359D1ZI (R) , (M) , 02AABCT0359D2ZX (M) , 05AABCT0359D2ZR (B) , 33AABCT0359D1ZT (B) , 27AABCT0359D1ZM (B) , 36AABCT0359D1ZN (B) , 30AABCT0359D1ZZ (B) , 37AABCT0359D1ZL (B) , 19AABCT0359D1ZJ (B) , 32AABCT0359D1ZV (B) , 10AABCT0359D1Z1 (B) , 07AABCT0359D1ZO (B) , 08AABCT0359D1ZM (B) , 23AABCT0359D1ZU (B)

*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Consignee

वितरण निर्देश | Delivery Instructions : delivery address details will be shared subsequently over mail

उत्पाद विवरण Product Details						
#	आइटम विवरण Item Description	आइटम विवरण Ordered Quantity	इकाई Unit	इकाई मूल्य (INR) Unit Price (INR)	कर विभाजन (INR) Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम Product Name : Techser Online UPS of Rating 3.0 KVA Without Battery Of Backup Time NA ब्रांड Brand : Techser ब्रांड प्रकार Brand Type : Registered Brand कैटलॉग की स्थिति Catalogue Status: OEM verified catalogue कैसे बेचा जा रहा है Selling As : OEM श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : Online UPS (V2) (Q2) मॉडल Model: TECHGLARE 3000 एचएसएन कोड HSN Code: 8504	14	pieces	35,400	NA	495,600
कुल ऑर्डर मूल्य Total Order Value (in INR)						495,600

परोक्षी विवरण Consignee Detail						
क्र.सं. S.No	परोक्षी Consignee	वस्तु Item	लॉट नंबर Lot No.	मात्रा Quantity	दिनांक के बाद डिलीवरी शुरू करना है Delivery Start	वितरण पूरा कब तक करना है Delivery To Be

					After	Completed By
1	<p>पद Designation : SENIOR MANAGER4</p> <p>ईमेल आईडी Email ID : buycon392.ubiu.ap@gembuyer.in</p> <p>संपर्क Contact : -</p> <p>जीएसटीआईएन GSTIN : -</p> <p>पता Address : Union Bank of India,FGM office,47-7-30/2 ,2nd floor, Mohan Mansion, 4th Lane, Dwarakanagar, Visakhapatnam-530016. Visakhapatnam, VISAKHAPATNAM, ANDHRA PRADESH-530016, India</p>	Techser Online UPS of Rating 3.0 KVA Without Battery Of Backup Time NA	-	14	08-May-2024	06-Aug-2024
Product Specification for Techser Online UPS of Rating 3.0 KVA Without Battery Of Backup Time NA						
विनिर्देश Specification	उप-विनिर्देश Sub-Spec	मूल्य Value				
Generic	Rating in KVA	3.0 KVA				
	Switching Technology	IGBT-PWM				
	Input Voltage	AC Single phase 160V - 260V 50Hz				
	Output Voltage	AC Single phase 230V +/-1% 50 Hz				
	Warranty for UPS (Years)	2				
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS (Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021)	Without Battery				
	Type of Battery (hint: NA in case Battery not provided)	NA				
	Backup time (Minutes) (hint: NA in case battery not provided)	NA				
	Battery Make	NA				
	Battery Model Number	NA				
	Battery capacity (Ah)	0				
	Weight of the Battery (kg)	0				
	Number of Batteries	0				
	Minimum Guaranteed VAH	NA				
	Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided	NA				
	Accessories with Battery	NA				
Installation and Commissioning or Service	Installation and Commissioning (Covered in the Scope of Supply)	Provided				
	After sales service (Turn Around Time)	Within 48 hours				
	Preventive Maintenance (Hint: Mention Timeline if provided, NA if not provided)	Yearly				
	Other Services provided	AMC support available warranty,PAN India service support on 24 x 7 basis,Availability of spares in close proximity (Spares should be easily available close to the site)				
Performance / Functional	Inbuilt isolation transformer	With				
	Overall Efficiency (%)	>/=90% & <94% without Inbuilt isolation transformer				
	Power Factor Load Supported	0.8 or better				
	Overload limit	20% Overload for minimum 10 minute,50% Overload for minimum 3 seconds,20% Overload for minimum 5 minute,50% Overload for minimum 1 minute				
	Total Harmonic Distortion(THD) (%)	3% Maximum @ 100% Linear Load				
	Other Functional Features	Crest factor on full non-linear load is not less than 3:1,Noise level (1 meter distance from UPS) should be less than 70dB,Voltage Regulation from no load to full load (%) (< / = 2%),UPS input power factor better than 0.95 (at rated voltage)				
Accessories	Accessories	Rack for Batteries,Cabling 6 meters (input upto 3m and output upto 3m),Paralleling kit (Hot Standby Configuration),SNMP Card (with Suitable Software) for communication,The UPS shall be complete with Trolley for battery bank,battery, Cables and connectors etc,NA				
Salient Features	Protection	Protection for under voltage at battery terminal,Protection of Over voltage,Short Circuit & over load at UPS output terminal,Over temperature protection				
	Metering	Input Voltage,Output Voltage,Input Frequency,Output Frequency,Output Power Factor				
	Alarms and Indications	Indicator for Mains presence,Indicator for Battery charging and discharging,Indicator for Output Over Load with Audible Alarm,Indicator for Low Battery Voltage with Audible				

		Alarm,Alarm for Over temperature,Alarm for Low Battery
	Additional Features	Pure Sinewave AC Output
	Provide URL of the catalogue	www.techser.com
Design / Construction	Type of Design / Construction	Floor Standing
	Form factor of UPS	NA (for Floor Standing)
	Enclosure (mm)	1.0 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP20
	DC Bus Voltage (In Volts)	96
	Other Constructional Features	Mains ON/OFF MCB,Battery Fuse,Static by pass facility,Manual by pass facility,UPS shall be free from workmanship defects, sharp edges, nicks, scratches, burst, etc. All fasteners shall be fixed properly. The equipment shall be complete with all parts and all parts shall be functional
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	45 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	90 percent
Buyer Specific Requirement	Environmental Test Report Requirements	Damp Heat Test : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C
	Battery Test Report	Capacity Test Report as per relevant governing specifications from Govt Lab/NABL accredited lab
	Intended Applications	Critical Infrastructure,Network IT Equipment,Medical Equipment,Support for Data Centers, Network operating centers, Security operation centers, State and District centers, Command and Control center etc., across the Country to provide impetus to the e-Governance services e.g. Public food distribution, e Way bill, Counseling, e-Office, IVFRT etc., services under Digital India Programme
	Other Requirements	ROHS compliance,KW rating shall be 0.8 time of KVA rating
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	Govt Lab
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

ईपीबीजी विवरण | ePBG Detail

NA

नियम और शर्तें | Terms and Conditions

1. Special terms and conditions- Version:1 effective from 06-07-2022
- 1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS (Version 2.0) with reference to Installation and Commissioning.

Seller's Responsibility: Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

Buyer's Responsibility: Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.
2. General Terms and Conditions-
- 2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.

