

अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687728696813

अनुबंध तिथि | Generated Date : 15-May-2024

बोली/आरए/पीबीपी संख्या | Bid/RA/PBP No.: [GEM/2023/B/3162555](#)

अनुसूची नाम | Schedule Name: Schedule 3, Schedule 2

संगठन विवरण Organisation Details	खरीदार विवरण Buyer Details
प्ररूप Type : Joint Venture of Central and State Government मंत्रालय Ministry : Ministry of Housing & Urban Affairs (MoHUA) विभाग Department : Ministry of Housing and Urban Affairs संगठन का नाम Organisation Name : Delhi Metro Rail Corporation Limited कार्यालय क्षेत्र Office Zone: Delhi Metro Rail Corporation Limited	पद Designation : DyCOS III संपर्क नंबर Contact No. : -9910375461- ईमेल आईडी Email ID : bycon1.dmrc.newdelhi@gembuyer.in जीएसटीआईएन GSTIN : 07AAACD3254A2ZA पता Address : OFFICE OF CONTROLLER OF STORES, DO BUILDING, SHASTRI PARK TRAIN DEPOT SHASTRI PARK, DELHI-110053, NORTH EAST DELHI, DELHI-110053, India

वित्तीय स्वीकृति विवरण Financial Approval Detail	भुगतान प्राधिकरण विवरण Paying Authority Details
आईएफडी सहमति IFD Concurrence : No प्रशासनिक अनुमोदन का पदनाम Designation of Administrative Approval: Dy.COS वित्तीय अनुमोदन का पदनाम Designation of Financial Approval: JGM/FO&M	भुगतान का तरीका Role: PAO भुगतान का तरीका Payment Mode: Offline पद Designation : AM/Finance/O&M/DMRC ईमेल आईडी Email ID : pao1.dmrc.dl@gembuyer.in जीएसटीआईएन GSTIN : N पता Address: DELHI METRO RAIL CORPORATION LTD. METRO BHAWAN FIRE BRIGADE LANE BARAKHAMBA ROAD NEW DELHI 110001, CENTRAL DELHI, DELHI-110001, India

विक्रेता विवरण Seller Details	
जेम विक्रेता आईडी GeM Seller ID :	22F1180000094675
कंपनी का नाम Company Name :	UNITED FIRE EQUIPMENTS PRIVATE LIMITED
संपर्क नंबर Contact No. :	09811172252
ईमेल आईडी Email ID :	ufe126@gmail.com
पता Address :	B-38,,MANGOLPURI, INDUSTRIAL AREA, PHASE-II,, DELHI, DELHI-110034, -
एमआईआई स्थिति MII Status :	True
एमएसएमई सत्यापित MSME verified :	Yes
एमएसएमई पंजीकरण संख्या MSME Registration number :	UDYAM-DL-06-0007057
एमएसएमई सामाजिक श्रेणी MSE Social Category :	General
एमएसएमई लिंग श्रेणी MSE Gender :	Male
जीएसटीआईएन GSTIN:	07AAACU0169P1ZZ (B) , (R) , (M) , 06AAACU0169P1Z1 (M)

*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Buyer

वितरण निर्देश | Delivery Instructions : NA

उत्पाद विवरण Product Details						
#	आइटम विवरण Item Description	आइटम विवरण Ordered Quantity	इकाई Unit	इकाई मूल्य (INR) Unit Price (INR)	कर विभाजन (INR) Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम Product Name : LIFEGUARD Portable Fire Extinguishers as per IS 15683 (2018) Low Pressure Extinguisher (Service Pressure ≤19 bar) Water Based Class -A ब्रांड Brand : LIFEGUARD ब्रांड प्रकार Brand Type : Registered Brand कैटलॉग की स्थिति Catalogue Status: OEM verified catalogue कैसे बेचा जा रहा है Selling As : OEM श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : Portable Fire Extinguishers (V2) as per IS 15683:2018 (Q2) मॉडल Model: LG-109 (LIFEGUARD) एचएसएन कोड HSN Code: 84241000	137	pieces	995	NA	136,315
2	उत्पाद का नाम Product Name : LIFEGUARD Portable Fire Extinguishers as per IS 15683 (2018) Low Pressure Extinguisher (Service Pressure ≤19 bar) Powder Based (as per IS 4308) Class -A ब्रांड Brand : LIFEGUARD ब्रांड प्रकार Brand Type : Registered Brand कैटलॉग की स्थिति Catalogue Status: OEM verified catalogue कैसे बेचा जा रहा है Selling As : OEM श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : Portable Fire Extinguishers (V2) as per IS 15683:2018 (Q2)	90	pieces	1,440	NA	129,600

मॉडल | Model: 4 KG ABC TYPE FIRE EXTINGUISHER (LIFEGUARD)
एचएसएन कोड | HSN Code: 8424

कुल ऑर्डर मूल्य | Total Order Value (in INR)

265,915

परोषिती विवरण | Consignee Detail

क्र.सं. S.No	परोषिती Consignee	वस्तु Item	लॉट नंबर Lot No.	मात्रा Quantity	दिनांक के बाद डिलीवरी शुरू करना है Delivery Start After	वितरण पूरा कब तक करना है Delivery To Be Completed By
1	पद Designation :- ईमेल आईडी Email ID : con86.mud.dl@gembuyer.in संपर्क Contact : -8595933970- जीएसटीआईएन GSTIN :- पता Address : Shastri Park Train Depot, DMRC, East Approach Road, Delhi 110053, NORTH EAST DELHI, DELHI-110053, India	LIFEGUARD Portable Fire Extinguishers as per IS 15683 (2018) Low Pressure Extinguisher (Service Pressure \leq 19 bar) Water Based Class - A	-	34	15-May-2024	12-Sep-2024
		LIFEGUARD Portable Fire Extinguishers as per IS 15683 (2018) Low Pressure Extinguisher (Service Pressure \leq 19 bar) Powder Based (as per IS 4308) Class -A	-	90	15-May-2024	12-Sep-2024
2	पद Designation :- ईमेल आईडी Email ID : satish.13468.dmrc@nic.in संपर्क Contact :- जीएसटीआईएन GSTIN :- पता Address : DMRC TRAIN MAINTENANCE DEPOT, DWARKA, D-21 CORPORATE PARK, NEAR DWARKA SECTOR 8 METRO STATION, DWARKA SECTOR 21, NEW DELHI-110075, SOUTH WEST DELHI, DELHI-110075, India	LIFEGUARD Portable Fire Extinguishers as per IS 15683 (2018) Low Pressure Extinguisher (Service Pressure \leq 19 bar) Water Based Class - A	-	103	15-May-2024	12-Sep-2024

Product Specification for LIFEGUARD Portable Fire Extinguishers as per IS 15683 (2018) Low Pressure Extinguisher (Service Pressure \leq 19 bar) Water Based Class -A

विनिर्देश Specification	उप-विनिर्देश Sub-Spec	मूल्य Value
Generic	Conformity to Standard	IS: 15683: 2018 (Latest amendments)
	Type	Stored Pressure
	Extinguishing Media	Water Based
	Expellant Medium	N2 Based (Stored Pressure)
Constructional Material	Type of Extinguisher	Low Pressure Extinguisher (Service Pressure \leq 19 bar)
	Material Specification for the body of High Pressure Extinguisher	NA
	Material Specification for the body of Low Pressure Extinguisher	Welded low carbon steel cylinders (as per Clause 9.2.5 of IS 15683)
Construction	Foam Based Extinguishing Media	NA
	Powder Based Extinguishing Media	NA
	Type of Clean Agent for Clean Agent Based Fire Extinguisher (as per CL 5-1-3)	NA
	Name of Clean Agent as per (CL 5-1-3)	NA
	Foam Based Fire Extinguisher Capacity in Liters	NA
	Powder Based Fire Extinguisher Capacity in Kg	NA
	Carbon Dioxide Based Fire Extinguisher Capacity in Kg	NA
	Water Based Fire Extinguisher Capacity in Liters	9
	Clean Agents Fire Extinguisher Capacity in Kg	NA
	Water Mist Fire Extinguisher Capacity in Liters	NA
	Weight of Filled Portable Fire Extinguisher	12 kilogram
Features of Fire Extinguisher	Carrying Handle (Mandatory If Extinguisher having mass \geq 1.5Kg or Cylinder diameter,Safety Devices (Mandatory for High Pressure Extinguisher),Rechargeable,Hose Assemblies (Mandatory If mass or volume of Extinguishing medium > 3 Kg or Litres),NA	

	Marking	As per clause 10.2 of IS 15683 (latest)
	Colour Coding Band (As per CL 10-1)	Red (water/water mist)
	Pressure Gauge Range for Low-Pressure Extinguishers	15 bar
	Class of fire for which Fire Extinguisher is suitable	Class -A
Performance	Operating Temperature (°C)	+5°C to +60°C
	Test Pressure for all Fire extinguisher except CO2	35 bar
	Burst Pressure for all Fire extinguisher except CO2	55 bar
	Minimum Effective discharge time for Fire Extinguisher	13 second
	Fire Rating of different class of fires	2A
	Discharge Range of Class-A and Class-B Fire Extinguisher (As per table 1 of CL 7-2-2) (Hint : ≥ 2 in case applicable on Class-A or Class A & B both / ≥ 1 in case applicable on Class-B only)	2 meter
Certification	BIS Marking	Yes
	CM/L No With Validity Period	8633079
	Availability of Test Report from Central Govt/NABL/ILAC accredited lab to prove conformity to specification	Availability of Test Report from NABL accredited Laboratory
	Test Report No	1872
	Test Report Date	19.06.2019
	Name of the lab	Advance Firetec
	Address of the lab	Mangolpuri Delhi
	Agreed to furnish all the test reports and certificates to buyer on demand	Yes

उत्पाद का बीआईएस लाइसेंस | BIS license of the product: 8633079

खरीदार परिभाषित अतिरिक्त विशिष्टता के लिए | Buyer Defined Additional Specification for LIFE GUARD Portable Fire Extinguishers as per IS 15683 (2018) Low Pressure Extinguisher (Service Pressure ≤ 19 bar) Water Based Class -A

विनिर्देश Specification	मूल्य Value
Test Pressure for all Fire Extinguisher (Except CO2)	35 BAR
Burst Pressure for all Fire Extinguisher (Except CO2)	55 BAR

Product Specification for LIFE GUARD Portable Fire Extinguishers as per IS 15683 (2018) Low Pressure Extinguisher (Service Pressure ≤ 19 bar) Powder Based (as per IS 4308) Class -A

विनिर्देश Specification	उप-विनिर्देश Sub-Spec	मूल्य Value
Generic	Conformity to Standard	IS: 15683: 2018 (Latest amendments)
	Type	Gas Cartridge Type (as per IS 4947)
	Extinguishing Media	Powder Based (as per IS 4308)
	Expellant Medium	CO2 Cartridge Based
Constructional Material	Type of Extinguisher	Low Pressure Extinguisher (Service Pressure ≤ 19 bar)
	Material Specification for the body of High Pressure Extinguisher	NA
	Material Specification for the body of Low Pressure Extinguisher	Welded low carbon steel cylinders (as per Clause 9.2.5 of IS 15683)
	Foam Based Extinguishing Media	NA
	Powder Based Extinguishing Media	ABC
	Type of Clean Agent for Clean Agent Based Fire Extinguisher (as per CL 5-1-3)	NA
	Name of Clean Agent as per (CL 5-1-3)	NA
	Foam Based Fire Extinguisher Capacity in Liters	NA
	Powder Based Fire Extinguisher Capacity in Kg	4
	Carbon Dioxide Based Fire Extinguisher Capacity in Kg	NA
	Water Based Fire Extinguisher Capacity in Liters	NA

Construction	Clean Agents Fire Extinguisher Capacity in Kg	NA
	Water Mist Fire Extinguisher Capacity in Liters	NA
	Weight of Filled Portable Fire Extinguisher	7.5 kilogram
	Features of Fire Extinguisher	Carrying Handle (Mandatory If Extinguisher having mass \geq 1.5Kg or Cylinder diameter,Safety Devices (Mandatory for High Pressure Extinguisher),Rechargeable,Hose Assemblies (Mandatory If mass or volume of Extinguishing medium > 3 Kg or Litres),NA
	Marking	As per clause 10.2 of IS 15683 (latest)
	Colour Coding Band (As per CL 10-1)	Blue (Powder)
	Pressure Gauge Range for Low-Pressure Extinguishers	15 bar
	Class of fire for which Fire Extinguisher is suitable	Class -A
Performance	Operating Temperature (°C)	-30°C to +60°C
	Test Pressure for all Fire extinguisher except CO2	35 bar
	Burst Pressure for all Fire extinguisher except CO2	55 bar
	Minimum Effective discharge time for Fire Extinguisher	13 second
	Fire Rating of different class of fires	3A
	Discharge Range of Class-A and Class-B Fire Extinguisher (As per table 1 of CL 7-2-2) (Hint : \geq 2 in case applicable on Class-A or Class A & B both / \geq 1 in case applicable on Class-B only)	2 meter
Certification	BIS Marking	Yes
	CM/L No With Validity Period	8633079
	Availability of Test Report from Central Govt/NABL/ILAC accredited lab to prove conformity to specification	Availability of Test Report from NABL accredited Laboratory
	Test Report No	20150228006
	Test Report Date	28.02.2015
	Name of the lab	Bharat Test House
	Address of the lab	Azadpur Delhi
	Agreed to furnish all the test reports and certificates to buyer on demand	Yes

ईपीबीजी विवरण | ePBG Detail

सलाहकार बैंक Advisory Bank :	NA
ईपीबीजी प्रतिशत (%) ePBG Percentage(%):	NA

नियम और शर्तें | Terms and Conditions

1. General Terms and Conditions-

- 1.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.
- 1.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

2. Buyer Added Bid Specific Terms and Conditions-

2.1 Generic.

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

2.2 Scope of Supply:

Scope of supply (Bid price to include all cost components) : Only supply of Goods

2.3 Buyer Added Bid Specific ATC:

Buyer Added text based ATC clauses

- To be eligible for award of contract, Bidder / OEM must possess following Certificates / Test Reports on the date of bid opening (to be uploaded with bid): Type Test Report from NABL accredited lab confirming the specifications of required items as per mentioned IS.
- Bidder offer will be summarily rejected if they do not upload any of the certificates/documents sought in the Bid Document, ATC and Corrigendum if any.
- Warranty period of the supplied products shall be 2 years from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if in

cluded in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

2.4 Certificates:

Material Test Certificate Should Be Sent Along with The Supply. The Material Will Be Checked by Buyer's Lab & the Results of the Lab will be the Sole Criteria for Acceptance of the Item.

2.5 Certificates:

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.