

अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687791891367

अनुबंध तिथि | Generated Date : 31-May-2024

बोली/आरए/पीबीपी संख्या | Bid/RA/PBP No.: [GEM/2023/B/4400902](#)

संगठन विवरण Organisation Details	खरीदार विवरण Buyer Details
प्रकार Type : Central PSU मंत्रालय Ministry : Ministry of Coal विभाग Department : NLC TAMIL NADU POWER Limited संगठन का नाम Organisation Name : NLC TAMIL NADU POWER Limited कार्यालय क्षेत्र Office Zone : TUTICORIN 628004	पद Designation : Executive Engineer संपर्क नंबर Contact No. : 0461-2352840- ईमेल आईडी Email ID : ranganathan.nlc@nic.in जीएसटीआईएन GSTIN : 33AACCN3238N1ZD पता Address : NLC TAMILNADU POWER LIMITED 2X500 MW THERMAL POWER PLANT HORBOUR ESTATE, TUTICORIN, TUTICORIN, TAMIL NADU-628004, India

वित्तीय स्वीकृति विवरण Financial Approval Detail	भुगतान प्राधिकरण विवरण Paying Authority Details
आईएफडी सहमति IFD Concurrence : No प्रशासनिक अनुमोदन का पदनाम Designation of Administrative Approval : CEO/NTPL वित्तीय अनुमोदन का पदनाम Designation of Financial Approval : CFO/NTPL	Role: PAO भुगतान का तरीका Payment Mode: Internet Banking पद Designation : DCM ईमेल आईडी Email ID : gv.ramakrishna.nlc@nic.in जीएसटीआईएन GSTIN : 33AACCN3238N1ZD पता Address : NLC TAMILNADU POWER LIMITED 2X500 MW THERMAL POWER PLANT HORBOUR ESTATE, TUTICORIN, Tuticorin (thoothukudi), TAMIL NADU-628004, India

विक्रेता विवरण Seller Details
जेम विक्रेता आईडी GeM Seller ID : D98B18000097418 कंपनी का नाम Company Name : BAID POWER SERVICES PRIVATE LIMITED संपर्क नंबर Contact No. : 09836398664 ईमेल आईडी Email ID : info@indiapowerhouse.net पता Address : BLOCK "B", 152 Block B, LAKE TOWN, HOLDING NO. 152, GROUND, Lake Town, KOLKATA, WEST BENGAL-700089, - एमएसएमई सत्यापित MSME verified : Yes एमएसएमई पंजीकरण संख्या MSME Registration number : UDYAM-WB-14-0001212 एमएसएमई सामाजिक श्रेणी MSE Social Category : General एमएसएमई लिंग श्रेणी MSE Gender : Male जीएसटीआईएन GSTIN : 19AACCB5805B1Z3 (R), (M)

*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Consignee

वितरण निर्देश | Delivery Instructions : NA

उत्पाद विवरण Product Details						
#	आइटम विवरण Item Description	आइटम विवरण Ordered Quantity	इकाई Unit	इकाई मूल्य (INR) Unit Price (INR)	कर विभाजन (INR) Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम Product Name : BPS 24 V SMPS based Float Cum Boost Charger (Battery Chargers) ब्रांड Brand : BPS ब्रांड प्रकार Brand Type : Registered Brand कैटलॉग की स्थिति Catalogue Status : OEM verified catalogue कैसे बेचा जा रहा है Selling As : OEM श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : Float Cum Boost Charger (Battery Chargers) (Q3) मॉडल Model: FCBC-24-GS-10 एचएसएन कोड HSN Code: 85044030	5	pieces	14,590	NA	72,950
कुल ऑर्डर मूल्य Total Order Value (in INR)						72,950

परोक्ष विवरण Consignee Detail						
क्र.सं. S.No	परोक्षी Consignee	वस्तु Item	लॉट नंबर Lot No.	मात्रा Quantity	दिनांक के बाद डिलीवरी शुरू करना है Delivery Start After	वितरण पूरा कब तक करना है Delivery To Be Completed By

1	पद Designation :- ईमेल आईडी Email ID : veluchamy.v.nlc@nic.in संपर्क Contact : 0461-2626105- जीएसटीआईएन GSTIN : 33AACCN3238N1ZD पता Address : NLC TAMILNADU POWER LIMITED 2X500 MW THERMAL POWER PLANT HORBOUR ESTATE, TUTICORIN, TUTICORIN, TAMIL NADU-628004, India	BPS 24 V SMPS based Float Cum Boost Charger (Battery Chargers)	-	5	31-May-2024	29-Aug-2024
Product Specification for BPS 24 V SMPS based Float Cum Boost Charger (Battery Chargers)						
विनिर्देश Specification	उप-विनिर्देश Sub-Spec				मूल्य Value	
GENERIC	Float cum boost charger (FCBC) type				SMPS based	
	Hot stand by module for redudancy				Yes	
	FCBC suitable for charging of				Lead Acid SMF VRLA type	
	Installation				No	
	Warranty (In Years)				1	
INPUT	Voltage				230 V +/-10%, 1 Phase AC	
	Frequency				50 Hz +/-5%	
	Power factor (50% load to 100% load) Maximum				0.75	
	Efficiency (in %age)				> / = 85	
	Dielectric Strength				1.5 KV AC (I/P to O/P & Case)	
OUTPUT	Nominal voltage				24 V	
	Output rating				10 A	
	Net Regulation				+/- 1%	
	Ripple factor				</=1%	
	Audible Noise				< 50 dB	
	Battery Current Limit				0.1 Ah of battery (for VRLA)	
PROTECTION	AC input circuit breaker				Yes	
	DC output circuit breaker				Yes	
	DC over voltage protection				Yes	
	Battery input fuses				Yes	
	Charger over load				Yes	
	Battery charging current limit				Yes	
	Short circuit protection				Yes	
	Enclosure protection				IP 42	
CONSTRUCTION	FCBC shall be modular system, easy for maintenance and for upgradable Hot plug in modules				Yes for SMPS based FCBC	
	Cabinet Material				" CRC Sheet, duly Powder coated Case	
	Active Current Sharing facility				Yes, Provided for Redudancy system	
	Potential Free Contacts for Remote Fault Annunciation				No	
	Input high voltage disconnect				Yes	
	Battery Low Voltage Disconnect				Yes. Provided	
	Display				Digital	
	Common O/P Voltage Controller				Yes. Provided	
	Charging Capacity				To charge two banks simultaneously	
	Battery Current Limiting for each battery path (Presentable to suit battery simultaneously)				Yes	
	Operating Temperature				0 deg C to 50 deg C	
	Storage Temperature				-10 deg C to +70 deg C	
	Cooling type				Convection	
	Humidity				< 95%	
FEATURES	FCBC should work in hot standby in 1+1 configuration				Yes	
	In case of failure of any component on one FCBC, the auto switchover of load to second FCBC should take place.				Yes for redudancy type	
	In Case of battery bank voltage dropping below some threshold level, audible alarm should be sounded				Yes	

ALARM/INDICATIONS	Input on	Yes
	Charger On Float, Charger On Boost	Yes
	DC Over Voltage	Yes
	DC under Voltage	Yes
	AC Supply fail	Yes
	Charger fail	Yes
	Rectifier fuse fail	NA for SMPS based
	DC/Battery Earth Fault	Yes
	Battery Fuse Blown/Battery Isolated	Yes
	Load on battery	Yes
	Battery Discharging	Yes
	Indication through either bright leds or multi point facia facility	Yes
	The audible alarm should be sounded for failure of any one of FCBC or its components	Yes
CERTIFICATIONS	Availability of type test report from Central Govt., lab/NABL/ILAC accredited lab to conformity of the specification	Yes
	Test report number - Must declare	KT&MTR/21-22/003/07C
	Test report date - Must declare	01.12.2021
	Name of lab - Must declare	SAMEER KOLKATA
	Address of lab - Must declare	SECTOR V SALT LAKE
	All the test reports and certificates shall furnish by the seller to purchase authority on demand	Yes

शुद्धिपत्र | Corrigendum

- तक बढ़ाया गया | Extended Upto : 2024-02-05 09:00:00
- तक बढ़ाया गया | Extended Upto : 2024-02-20 09:00:00
- तक बढ़ाया गया | Extended Upto : 2024-03-05 15:00:00
- तक बढ़ाया गया | Extended Upto : 2024-03-15 15:00:00
- तक बढ़ाया गया | Extended Upto : 2024-04-05 09:00:00

ईपीबीजी विवरण | ePBG Detail

सलाहकार बैंक Advisory Bank :	NA
ईपीबीजी प्रतिशत (%) ePBG Percentage(%):	NA

नियम और शर्तें | Terms and Conditions

1. General Terms and Conditions-

- 1.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.
- 1.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

2. Buyer Added Bid Specific Terms and Conditions-

2.1 Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

2.2 Generic

Bidder shall submit the following documents along with their bid for Vendor Code Creation:

- Copy of PAN Card.
- Copy of GSTIN.
- Copy of Cancelled Cheque.
- Copy of EFT Mandate duly certified by Bank.

2.3 Scope of Supply:

Scope of supply (Bid price to include all cost components) : Only supply of Goods

2.4 Inspection:

Nominated Inspection Agency: On behalf of the Buyer organization, any one of the following Inspection Agency would be conducting inspection of stores before acceptance: Pre-dispatch Inspection at Seller Premises (applicable only if pre-dispatch inspection clause has been selected in ATC):

Not applicable

Post Receipt Inspection at consignee site before acceptance of stores:
At NTPL STORES, upon receipt of material, by NTPL executives.

2.5 Certificates:

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

2.6 Warranty:

Warranty period of the supplied products shall be as given in specifications from the date of final acceptance of goods or after completion of installation, commissioning & testing of goods (if included in the scope of supply), at consignee location. OEM Warranty certificates must be submitted by Successful Bidder at the time of delivery of Goods. The seller should guarantee the rectification of goods in case of any break down during the guarantee period. Seller should have well established Installation, Commissioning, Training, Troubleshooting and Maintenance Service group in INDIA for attending the after sales service. Details of Service Centres near consignee destinations are to be uploaded along with the bid.

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.