

## अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687722188266

अनुबंध तिथि | Generated Date : 01-Jun-2024

<b>संगठन विवरण   Organisation Details</b>		<b>खरीदार विवरण   Buyer Details</b>				
प्रकार   Type :	State Government	पद   Designation :	Principal VENGOOR			
मंत्रालय   Ministry :	-	संपर्क नंबर   Contact No. :	0484-2659714-			
विभाग   Department :	Labour and Skills Department Kerala	ईमेल आईडी   Email ID :	prlitivengor.trg@kerala.gov.in			
संगठन का नाम   Organisation Name :	Industrial Training Department	जीएसटीआईएन   GSTIN :	32CHNG05566B1DQ			
कार्यालय क्षेत्र   Office Zone :	Directorate Of Training		GOVT ITI, VENGOOR GOVT. ITI, VENGOOR NEDUNGAPRA			
		पता   Address :	P.O, PERUMBAVOOR, ERNAKULAM, KERALA- 683545 Pincode - 683545, ERNAKULAM, KERALA-683545, India			
<b>वित्तीय स्वीकृति विवरण   Financial Approval Detail</b>		<b>भुगतान प्राधिकरण विवरण   Paying Authority Details</b>				
आईएफडी सहमति   IFD Concurrence :	No	Role:	DDO			
प्रशासनिक अनुमोदन का पदनाम   Designation of Administrative Approval:	Director of training, Industrial Training Department	भुगतान का तरीका   Payment Mode:	Offline			
वित्तीय अनुमोदन का पदनाम   Designation of Financial Approval :	Director of training, Industrial Training Department	पद   Designation :	Junior Superintendent			
		ईमेल आईडी   Email ID :	cru.itivng@kerala.gov.in			
		जीएसटीआईएन   GSTIN :	-			
		पता   Address:	GOVT ITI, VENGOOR GOVT. ITI, VENGOOR NEDUNGAPRA P.O, PERUMBAVOOR, ERNAKULAM, KERALA- 683545 Pincode - 683545, Ernakulam, KERALA-683545, India			
<b>विक्रेता विवरण   Seller Details</b>						
जेम विक्रेता आईडी   GeM Seller ID :	KPUM210003268377					
कंपनी का नाम   Company Name :	POWERON BUSINESS SOLUTIONS					
संपर्क नंबर   Contact No. :	09567849494					
ईमेल आईडी   Email ID :	poweronbs@gmail.com					
पता   Address :	41/1395-6, Haniyas Building, RC Road, Near KSRTC Stand, Palakkad, Kerala-678004, -					
एमएसएमई पंजीकरण संख्या   MSME Registration number :	UDYAM-KL-10-0005956					
एमएसई सामाजिक श्रेणी   MSE Social Category :	OBC					
एमएसई लिंग श्रेणी   MSE Gender :	Male					
जीएसटीआईएन   GSTIN:	32BWBPA7769Q1Z2 (R)					
*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा   GST / Tax invoice to be raised in the name of - Buyer						
वितरण निर्देश   Delivery Instructions : NA						
<b>उत्पाद विवरण   Product Details</b>						
#	आइटम विवरण   Item Description	आइटम विवरण   Ordered Quantity	इकाई   Unit	इकाई मूल्य (INR)   Unit Price (INR)	कर विभाजन (INR)   Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित)   Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम   Product Name : SUPRA Online UPS of Rating 5.0 KVA With Battery Of Backup Time 120 Minutes ब्रांड   Brand : SUPRA ब्रांड प्रकार   Brand Type : Registered Brand कैटलॉग की स्थिति   Catalogue Status : OEM verified catalogue कैसे बेचा जा रहा है   Selling As : OEM verified Reseller श्रेणी का नाम और चतुर्थांश   Category Name & Quadrant : Online UPS (V2) (Q2) मॉडल   Model: 11D150M120TB3 एचएसएन कोड   HSN Code: HSN not specified by seller	1	pieces	166,450	NA	166,450
कुल ऑर्डर मूल्य   Total Order Value (in INR)						166,450
<b>परोक्षी विवरण   Consignee Detail</b>						
क्र.सं.   S.No	परोक्षी   Consignee	वस्तु   Item	लॉट नंबर   Lot No.	मात्रा   Quantity	दिनांक के बाद डिलीवरी शुरू करना है   Delivery Start After	वितरण पूरा कब तक करना है   Delivery To Be Completed By

1	<p>पद   Designation : Principal VENGOOR  ईमेल आईडी   Email ID : prlitiengor.trg@kerala.gov.in  संपर्क   Contact : 0484-2659714-  जीएसटीआईएन   GSTIN : 32CHNG05566B1DQ  पता   Address : GOVT ITI, VENGOOR GOVT. ITI, VENGOOR NEDUNGAPRA  P.O, PERUMBAVOOR, ERNAKULAM, KERALA- 683545 Pincode - 683545,  ERNAKULAM, KERALA-683545, India</p>	SUPRA Online UPS of Rating 5.0 KVA With Battery Of Backup Time 120 Minutes	-	1	01-Jun-2024	30-Aug-2024
---	--	---	---	---	-------------	-------------

**Product Specification for SUPRA Online UPS of Rating 5.0 KVA With Battery Of Backup Time 120 Minutes**

विनिर्देश   Specification	उप-विनिर्देश   Sub-Spec	मूल्य   Value
Generic	Rating in KVA	5.0 KVA
	Switching Technology	IGBT-PWM
	Input Voltage	AC Single phase 160V - 260V 50Hz
	Output Voltage	AC Single phase 230V +/-1% 50 Hz
	Warranty for UPS (Years)	3
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS ( Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021 )	With Battery
	Type of Battery (hint: NA in case Battery not provided)	Lead Acid type (with tubular positive plates) conforming to IS:1651:1991 latest
	Backup time (Minutes) (hint: NA in case battery not provided)	120 Minutes
	Battery Make	SUPRA
	Battery Model Number	TB
	Battery capacity (Ah)	150
	Weight of the Battery (kg)	48
	Number of Batteries	10
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time
	Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided	3
	Accessories with Battery	NA
Installation and Commissioning or Service	Installation and Commissioning ( Covered in the Scope of Supply)	Provided
	After sales service ( Turn Around Time)	Within 24 hours,Within 48 hours,Within 7 days,NA
	Preventive Maintenance ( Hint: Mention Timeline if provided, NA if not provided)	NA
	Other Services provided	NA
Performance / Functional	Inbuilt isolation transformer	With
	Overall Efficiency (%)	>/=90% with Inbuilt isolation transformer
	Power Factor Load Supported	0.8 or better
	Overload limit	20% Overload for minimum 10 minute,20% Overload for minimum 5 minute,50% Overload for minimum 1 minute,50% Overload for minimum 3 seconds
	Total Harmonic Distortion(THD) (%)	3% Maximum @ 100% Linear Load
	Other Functional Features	Crest factor on full non-linear load is not less than 3:1
Accessories	Accessories	Rack for Batteries,Cabling 6 meters ( input upto 3m and output upto 3m),Paralleling kit for synchronizing (Parallel Redundant Load Sharing Configuration),The UPS shall be complete with Trolley for battery bank,battery, Cables and connectors etc,NA
Salient Features	Protection	Over temperature protection
	Metering	Input Voltage
	Alarms and Indications	Indicator for Mains presence,Alarm for Low Battery
	Additional Features	Pure Sinewave AC Output,NA
	Provide URL of the catalogue	www.suprahitech.com
	Type of Design / Construction	Floor Standing
	Form factor of UPS	NA (for Floor Standing)
	Enclosure (mm)	1.2 mm Minimum Thickness of M.S. Sheet duly powder coated

Design / Construction	Degree of Protection	IP21
	DC Bus Voltage (In Volts)	120
	Other Constructional Features	Mains ON/OFF MCB
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	40 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	90 percent
Buyer Specific Requirement	Environmental Test Report Requirements	NA
	Battery Test Report	NA
	Intended Applications	Critical Infrastructure, Network IT Equipment, Medical Equipment, Support for Data Centers, Network operating centers, Security operation centers, State and District centers, Command and Control center etc., across the Country to provide impetus to the e-Governance services e.g. Public food distribution, e Way bill, Counseling, e-Office, IVFRT etc., services under Digital India Programme, NA
	Other Requirements	ROHS compliance, KW rating shall be 0.8 time of KVA rating, NA
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	OEM
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

#### ईपीबीजी विवरण | ePBG Detail

NA

#### नियम और शर्तें | Terms and Conditions

##### 1. Special terms and conditions- Version:1 effective from 06-07-2022

1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS ( Version 2.0) with reference to Installation and Commissioning.

**Seller's Responsibility:** Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

**Buyer's Responsibility:** Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

Note: The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

##### 2. General Terms and Conditions-

2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.