

## अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687796296206

अनुबंध तिथि | Generated Date : 06-Jun-2024

संगठन विवरण   Organisation Details	खरीदार विवरण   Buyer Details
प्ररूप   Type : Central PSU मंत्रालय   Ministry : Ministry of Finance विभाग   Department : Department of Financial Services संगठन का नाम   Organisation Name : Bank of India कार्यालय क्षेत्र   Office Zone : Head Office	पद   Designation : manager संपर्क नंबर   Contact No. : - ईमेल आईडी   Email ID : buycon334.bi.ap@gembuyer.in जीएसटीआईएन   GSTIN : - पता   Address : Bank of India , Vijayawada Zonal Office, D No:31-23-1A,PVR complex, 1st floor,Beside BSNL Bhavan,Eluru Road, Chuttugunta, Machavaram post,Vijayawada-52004, KRISHNA, ANDHRA PRADESH-520004, India

वित्तीय स्वीकृति विवरण   Financial Approval Detail	भुगतान प्राधिकरण विवरण   Paying Authority Details
आईएफडी सहमति   IFD Concurrence : No प्रशासनिक अनुमोदन का पदनाम   Designation of Administrative Approval: Chief Manager वित्तीय अनुमोदन का पदनाम   Designation of Financial Approval: Chief Manager	Role: PAO भुगतान का तरीका   Payment Mode: Offline पद   Designation : Chief Manager IT ईमेल आईडी   Email ID : pao102.bi.ap@gembuyer.in जीएसटीआईएन   GSTIN : 37AAACB0472C4Z5 पता   Address : Bank of India , Vijayawada Zonal Office, D No:31-23-1A,PVR complex, 1st floor,Beside BSNL Bhavan,Eluru Road, Chuttugunta, Machavaram post,Vijayawada-52004, Krishna, ANDHRA PRADESH-520004, India

विक्रेता विवरण   Seller Details
जेम विक्रेता आईडी   GeM Seller ID : E49B180000107808 कंपनी का नाम   Company Name : NUMAX ENERGY SOLUTIONS संपर्क नंबर   Contact No. : 09052766606 ईमेल आईडी   Email ID : numaxhyd@gmail.com पता   Address : Plot 50 & 51 Narayanaswamy nagar,Cherlapally,Cherlapally,Hyderabad, Hyderabad, TELANGANA-500051, - एमएसएमई पंजीकरण संख्या   MSME Registration number : UDYAM-TS-20-0009920 एमएसई सामाजिक श्रेणी   MSE Social Category : General एमएसई लिंग श्रेणी   MSE Gender : Male जीएसटीआईएन   GSTIN: 36AAIFN0814D1ZO (R) , (M)

\*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Consignee

वितरण निर्देश | Delivery Instructions : To be delivered at Tirupathi Branch Extension counter at Tirumala Hills.

उत्पाद विवरण   Product Details						
#	आइटम विवरण   Item Description	आइटम विवरण   Ordered Quantity	इकाई   Unit	इकाई मूल्य (INR)   Unit Price (INR)	कर विभाजन (INR)   Tax Bifurcation (INR)	मूल्य (INR) में सभी शुल्क और कर सहित   Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम   Product Name : NUMAX Online UPS of Rating 3.0 KVA With Battery Of Backup Time 120 Minutes ब्रांड   Brand : NUMAX ब्रांड प्रकार   Brand Type : Registered Brand कैटलॉग की स्थिति   Catalogue Status : OEM verified catalogue कैसे बेचा जा रहा है   Selling As : OEM श्रेणी का नाम और चतुर्थांश   Category Name & Quadrant : Online UPS (V2) (Q2) मॉडल   Model: DOU3K एचएसएन कोड   HSN Code: HSN not specified by seller	1	pieces	162,000	NA	162,000
कुल ऑर्डर मूल्य   Total Order Value (in INR)						162,000

परेषिती विवरण   Consignee Detail						
क्र.सं.   S.No	परेषिती   Consignee	वस्तु   Item	लॉट नंबर   Lot No.	मात्रा   Quantity	दैनिक के बाद डिलीवरी शुरू करना है   Delivery Start After	वितरण पूरा कब तक करना है   Delivery To Be Completed By

1	<p>पद   Designation : Officer IT  ईमेल आईडी   Email ID : buycon329.bi.ap@gembuyer.in  संपर्क   Contact : -  जीएसटीआईएन   GSTIN : -  पता   Address : Bank of India , Vijayawada Zonal Office, D No:31-23-1A,PVR complex, 1st floor,Beside BSNL Bhavan,Eluru Road, Chuttugunta, Machavaram post,Vijayawada-52004, KRISHNA, ANDHRA PRADESH-520004, India</p>	<p>NUMAX Online UPS of Rating 3.0 KVA With Battery Of Backup Time 120 Minutes</p>	-	1	06-Jun-2024	04-Sep-2024
---	---	---	---	---	-------------	-------------

**Product Specification for NUMAX Online UPS of Rating 3.0 KVA With Battery Of Backup Time 120 Minutes**

विनिर्देश   Specification	उप-विनिर्देश   Sub-Spec	मूल्य   Value
Generic	Rating in KVA	3.0 KVA
	Switching Technology	IGBT-PWM
	Input Voltage	AC Single phase 160V - 260V 50Hz
	Output Voltage	AC Single phase 230V +/-1% 50 Hz
	Warranty for UPS (Years)	3
Battery/Backup Bank	Battery/Backup Bank Provided with Online UPS ( Hint: In case the UPS is supplied with battery, seller shall ensure compliance to the GST Rates as per recommendations made in the 45th Meeting of GST council dated 17th Sep 2021 )	With Battery
	Type of Battery (hint: NA in case Battery not provided)	Lead Acid type (with tubular positive plates) conforming to IS:1651:1991 latest
	Backup time (Minutes) (hint: NA in case battery not provided)	120 Minutes
	Battery Make	EXIDE
	Battery Model Number	6EL130
	Battery capacity (Ah)	130
	Weight of the Battery (kg)	61.1
	Number of Batteries	8
	Minimum Guaranteed VAH	1600 X Per KVA X Per hour of backup time
	Warranty for battery (Years) by Battery Manufacturer/Brand hint: NA in case battery not provided	3
	Accessories with Battery	NA
Installation and Commissioning or Service	Installation and Commissioning ( Covered in the Scope of Supply)	Provided
	After sales service ( Turn Around Time)	Within 48 hours
	Preventive Maintenance ( Hint: Mention Timeline if provided, NA if not provided)	Quarterly
	Other Services provided	PAN India service support on 24 x 7 basis,AMC support available warranty,Availability of spares in close proximity (Spares should be easily available close to the site),NA
Performance / Functional	Inbuilt isolation transformer	With
	Overall Efficiency (%)	>=90% with Inbuilt isolation transformer
	Power Factor Load Supported	0.8 or better
	Overload limit	20% Overload for minimum 5 minute,50% Overload for minimum 3 seconds
	Total Harmonic Distortion(THD) (%)	3% Maximum @ 100% Linear Load
	Other Functional Features	Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD : 8 to 10 Hours
Accessories	Accessories	Rack for Batteries,Cabling 6 meters ( input upto 3m and output upto 3m),The UPS shall be complete with Trolley for battery bank,battery, Cables and connectors etc,NA
Salient Features	Protection	Protection of Over voltage,Protection for under voltage at battery terminal
	Metering	Input Voltage,Output Voltage
	Alarms and Indications	Indicator for Mains presence,Indicator for Battery charging and discharging,Indicator for Output Over Load with Audible Alarm,Indicator for Low Battery Voltage with Audible Alarm,Alarm for Over temperature,Alarm for Low Battery
	Additional Features	Pure Sinewave AC Output,NA
	Provide URL of the catalogue	www.numaxups.co.in

Design / Construction	Type of Design / Construction	Floor Standing
	Form factor of UPS	NA (for Floor Standing)
	Enclosure (mm)	1.0 mm Minimum Thickness of M.S. Sheet duly powder coated
	Degree of Protection	IP20
	DC Bus Voltage (In Volts)	96
	Other Constructional Features	NA
Operating Conditions	Minimum Operating Temperature	0 degree Celsius
	Maximum Operating Temperature	50 degree Celsius
	Relative Humidity Non Condensing at 40 deg C	95 percent
Buyer Specific Requirement	Environmental Test Report Requirements	NA
	Battery Test Report	NA
	Intended Applications	NA
	Other Requirements	NA
Reports And Certification	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	OEM
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes
	As per Meity (Government of India) guidelines UPS shall have valid BIS CRS certifications as applicable	Yes (For UPS rating upto 10KVA)

उत्पाद का बीआईएस लाइसेंस | BIS license of the product: 63002674

#### ईपीबीजी विवरण | ePBG Detail

NA

#### नियम और शर्तें | Terms and Conditions

##### 1. Special terms and conditions- Version:1 effective from 06-07-2022

1.1 In addition to General Terms and Conditions of GeM, the following Special T&C shall be applicable for Online UPS ( Version 2.0) with reference to Installation and Commissioning.

**Seller's Responsibility:** Installation and Commissioning shall involve all the interconnections, any cabling between power source, switch boards within 3 metre range for input power and connecting Output power in the Scope of seller.

**Buyer's Responsibility:** Buyer will ensure well ventilated/covered site/room having requisite power points/distribution board to provide input power to UPS as well as to take out power from UPS within 3 metre of the location of UPS placement.

The above is not applicable for the stores supplied without installation and commissioning.

**Note:** The above is indicative and any incidental requirement related to above responsibilities shall also be considered in the responsibilities of Buyer/Seller as applicable.

##### 2. General Terms and Conditions-

2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.