

1	संपर्क Contact : 0755-2730970- जीएसटीआईएन GSTIN : 23AAAAI1830P2ZQ पता Address : ICAR- INDIAN INSTITUTE OF SOIL SCIENCE, Nabibagh Berasia Road BHOPAL, BHOPAL, MADHYA PRADESH-462038, India	microtek Line Interactive UPS with AVR of Rating 0.65 KVA With Warranty of 1 Year	-	4	27-Jun-2024	12-Jul-2024
---	--	--	---	---	-------------	-------------

Product Specification for microtek Line Interactive UPS with AVR of Rating 0.65 KVA With Warranty of 1 Year

विनिर्देश Specification	उप-विनिर्देश Sub-Spec	मूल्य Value
GENERIC	Rating (in KVA)	0.65
	Technology	MOSFET-PWM
	Inverter Efficiency (%)	60% or better
	Minimum Guaranteed Battery Backup time (Minutes) on Full Load	15
	Warranty for Line Interactive UPS	1 Year
Battery/Backup Bank	Type of battery	SMF-VRLA confirming to JISC-8702 Pt 1,2 &3
	Location of Battery	Inside the Enclosure of UPS
	Battery capacity (Ah)	7Ah
	Minimum Guaranteed VAH provided to meet or exceed minimum guaranteed Back up time	84
	Battery Make (hint: Name of the Brand)	lioch
	Battery Model Number	12v-7AH
	Number of Batteries	1
	Weight of the Battery (kg)	2.2
Warranty for the battery from the date of delivery	1 Year	
CONSTRUCTIONAL	Enclosure	ABS
	Degree of protection	IP 20
	Gross Weight (UPS+Battery) (kg)	4.5
FEATURES	Rated Output (Volt) with Total Harmonic Distortion (%)	Single Phase Quasi Sinewave 230 V AC 50 Hz with Total Harmonic Distortion as <=40%
	Input (Volt)	Single Phase AC (160-280V)
	Salient Features	Maximum 10 milliseconds Switching over time, Load Power Factor >=0.6, +/-10% Variation in output voltage in battery mode, <=0.5 Hz Variation on output frequency in battery mode, UPS shall withstand 10% overload for at least 5 minutes in mains mode
	Variation in AVR output in AC mode (AVR Voltage regulation)	230 Volts +/-9%
	Protection	Under voltage Protection (Input Voltage <160 V), Overvoltage Protection (Input Voltage >280V), Short Circuit of UPS, Low Battery, Overload
BUYER SPECIFIC REQUIREMENT	Environmental Test Report Requirements	NA
	Any Other Requirements	As per Meity (Government of India) guidelines UPS shall have valid IS16242-Part 1 CRS certification
CERTIFICATION / TEST REPORT	Type of lab which carried out Test of Complete Product to prove the conformity of product as per specification	Certificate of Govt. Lab/NABL/ILAC accredited for UPS Testing
	Agree to provide all relevant documents Test Reports/supporting document /reports etc to the buyer at the time of bidding or on demand	Yes

ईपीबीजी विवरण | ePBG Detail

NA

नियम और शर्तें | Terms and Conditions

1. General Terms and Conditions-

1.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.

1.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.