

अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687745572975

अनुबंध तिथि | Generated Date : 03-Jul-2024

बोली/आरए/पीबीपी संख्या | Bid/RA/PBP No.: [GEM/2024/B/5025327](#)

| संगठन विवरण Organisation Details | खरीदार विवरण Buyer Details |
|--|---|
| प्रकार Type : State Government मंत्रालय Ministry : - विभाग Department : Energy Department Uttar Pradesh संगठन का नाम Organisation Name : Uttar Pradesh Power Corporation Limited (UPPCL) कार्यालय क्षेत्र Office Zone : Electricity Civil Transmission Circle 132 Kv S/s Martinpurwa Lucknow | पद Designation : ASSISTANT ENGINEER संपर्क नंबर Contact No. : 12345-67891- ईमेल आईडी Email ID : buycon170.upplu.up@gembuyer.in जीएसटीआईएन GSTIN : 09AAACU8823E1Z9 पता Address : EXECUTIVE ENGINEER 130 D SECOND FLOOR PARESHAN BHAWAN VICTORIA PARK MEERUT, MEERUT, UTTAR PRADESH-250001, India |

| वित्तीय स्वीकृति विवरण Financial Approval Detail | भुगतान प्राधिकरण विवरण Paying Authority Details |
|---|---|
| आईएफडी सहमति IFD Concurrence : Yes प्रशासनिक अनुमोदन का पदनाम Designation of Administrative Approval : SUPERINTENDING ENGINEER वित्तीय अनुमोदन का पदनाम Designation of Financial Approval : SUPERINTENDING ENGINEER | Role: PAO भुगतान का तरीका Payment Mode: Offline पद Designation : EXECUTIVE ENGINEER ईमेल आईडी Email ID : ddo90.upplu.up@gembuyer.in जीएसटीआईएन GSTIN : 09AAACU8823E1Z9 पता Address : EXECUTIVE ENGINEER 130 D SECOND FLOOR PARESHAN BHAWAN VICTORIA PARK MEERUT, Meerut, UTTAR PRADESH-250001, India |

| विक्रेता विवरण Seller Details |
|--|
| जेम विक्रेता आईडी GeM Seller ID : I4MT240011629944 कंपनी का नाम Company Name : PANCHSHEEL ELECTRICALS संपर्क नंबर Contact No. : 09211612114 ईमेल आईडी Email ID : panchsheelectricals123@gmail.com पता Address : B-515, KASHIRM NAGAR, BHOGPUR MITHONI, MORADABAD, Moradabad, UTTAR PRADESH-244001, - एमएसएमई पंजीकरण संख्या MSME Registration number : UDYAM-DL-05-0029683 एमएसई सामाजिक श्रेणी MSE Social Category : General एमएसई लिंग श्रेणी MSE Gender : Male जीएसटीआईएन GSTIN : 09CPXPS9130M2ZO (R) |

*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा | GST / Tax invoice to be raised in the name of - Consignee

वितरण निर्देश | Delivery Instructions : NA

| # | आइटम विवरण Item Description | आइटम विवरण Ordered Quantity | इकाई Unit | इकाई मूल्य (INR) Unit Price (INR) | कर विभाजन (INR) Tax Bifurcation (INR) | मूल्य (INR में सभी शुल्क और कर सहित) Price (Inclusive of all Duties and Taxes in INR) |
|--|--|-------------------------------|-------------|-------------------------------------|---|---|
| 1 | उत्पाद का नाम Product Name : Unbranded 250 W Lamp Ballast For Hpsv Lamps ब्रांड Brand : NA ब्रांड प्रकार Brand Type : Unbranded कैटलॉग की स्थिति Catalogue Status: Catalogue not verified by OEM कैसे बेचा जा रहा है Selling As : Reseller not verified by OEM श्रेणी का नाम और चतुर्थांश Category Name & Quadrant : Lamp Ballast for HPSV Lamps as per IS 15882:2009, IS 15885 (Q3) मॉडल Model: CHOKE एचएसएन कोड HSN Code: HSN not specified by seller | 10 | pieces | 1,298 | NA | 12,980 |
| कुल ऑर्डर मूल्य Total Order Value (in INR) | | | | | | 12,980 |

| क्र.सं. S.No | परोक्षिती Consignee | वस्तु Item | लॉट नंबर Lot No. | मात्रा Quantity | दिनांक के बाद डिलीवरी शुरू करना है Delivery Start After | वितरण पूरा कब तक करना है Delivery To Be Completed By |
|----------------|-----------------------|--------------|--------------------|-------------------|---|--|
| | | | | | | |

| | | | | | | |
|---|--|--|---|----|-------------|-------------|
| 1 | ईमेल आईडी Email ID : buycon170.uppclu.up@gembuyer.in संपर्क Contact : 12345-67891- जीएसटीआईएन GSTIN : 09AAACU8823E1Z9 पता Address : EXECUTIVE ENGINEER 130 D SECOND FLOOR PARESHAN BHAWAN VICTORIA PARK MEERUT, MEERUT, UTTAR PRADESH-250001, India | Unbranded 250 W Lamp Ballast For Hpsv Lamps | - | 10 | 03-Jul-2024 | 18-Jul-2024 |
|---|--|--|---|----|-------------|-------------|

Product Specification for Unbranded 250 W Lamp Ballast For Hpsv Lamps

| विनिर्देश Specification | उप-विनिर्देश Sub-Spec | मूल्य Value |
|--|--|-----------------------------------|
| GENERIC | Ballast for HPSV lamps (Excluding Tubular Fluorescent Lamps) conforming to IS: 15882:2009 and all the ballasts specified in the standard shall meet the requirements of IS: 15885(Part-1):2011 latest and IS: 15885(Part-2/Section-9): 2011 latest | Yes |
| | ISI Marked | No |
| | ISI marked if yes declare CM/L Number If 'No' write NA | NA |
| | Ballast Wattage | 250 W |
| | Operating Voltage | 220 Volt -240 Volt |
| | Supply frequency | 50 Hz +/-5% |
| CONSTRUCTIONAL | Ballast constructional requirements as per IS:15885 (Part 1) shall apply | Yes |
| | Winding material | Copper wound |
| | Supply current: At rated voltage, the supply current shall not differ by more than 10 percent from the value marked on the ballast when the latter is operated with a reference lamp | Yes |
| | Current wave form shall be as per Cl 9 of IS:15882:2009 latest | Yes |
| | Magnetic screening: The ballast shall be effectively screened against the influence of adjacent ferro-magnetic materials as per Cl 10 of IS:15882:2009 latest | Yes |
| | Ballast setting: Power delivered at rated voltage as per Cl. 15.1 of IS:15882:2009 latest (Not Less than 95% and not more than 105% of the reference ballast when operated at the objective lamp voltage as given in IS:9974(Part2) | Yes |
| | Short Circuit current between 92% and 106% of rated voltage as per Cl. 15.2 of IS:15882:2009 latest | Yes |
| | Open circuit voltage between 92% and 106% of its rated voltage as per Cl. 15.3 of IS:15882:2009 latest | Yes |
| | Insulation resistance as per Cl. 11 of IS:15885 Part 1 : 2011 latest | >=2 M Ohm |
| | Electric strength as per Cl. 12 of IS:15885 Part 1 : 2011 latest | Yes |
| | Rated Maximum operating temperature of ballast (Tw) (Ref. Cl. B.9.2 of IS:15885 part 1:2011 latest) | 105 deg C |
| | Ballast shall pass the thermal endurance test for winding of ballast as per Cl.13 of IS:15885 Part 1 :2011 latest | Yes |
| | Ballast shall pass High voltage test 5 KV for 5 Seconds | Yes |
| | Watt Loss | 15 Watts maximum for 70 W Ballast |
| Cold resistance at 20 deg. C (Tolerance: +5%, -10%) - must declare | 10 | |
| Circuit power factor | >=0.85 | |
| WARRANTY | Guaranteed period of replacement | 1 Year |
| CERTIFICATION | Marking: Apart from IS requirement each ballast shall be marked with serial number of ballast, Watt Loss, Tw details | Yes |
| | Availability of Type Test Report from Central Govt./NABL/ILAC accredited lab to prove conformity to IS specifications as applicable | Yes |
| | Test Report Number | 656516 |
| | Test Report Date | 12-05-2017 |
| | Name of Test Lab | QMS LAB |
| | Address of Test Lab | DELHI |

टिप्पणी | Note:: Seller has given an undertaking that it has made arrangements for getting the stores from an authorized distributor / dealer / channel partner of the OEM of the offered product. At the time of delivery of goods, Seller will provide necessary chain documents (in the form of GST Invoice) to prove that the supplied goods are genuine and are being sourced from an authorized distributor / dealer / channel partner of the OEM. In case of any complaint about genuineness of the supplied products, Seller shall be responsible for providing genuine replacement supplies.

ईपीबीजी विवरण | ePBG Detail

| | |
|---|----|
| सलाहकार बैंक Advisory Bank : | NA |
| ईपीबीजी प्रतिशत (%) ePBG Percentage(%): | NA |

नियम और शर्तें | Terms and Conditions

1. General Terms and Conditions-

- 1.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.
- 1.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

2. Buyer Added Bid Specific Terms and Conditions-

2.1 Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

2.2 Generic

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address

ANIL KUMAR MAURYA
220 KV S/S PARTAPUR (JAGRITI VIHAR)
MEERUT
MOBILE NO 9412740217
PIN CODE 250003

2.3 Buyer Added Bid Specific ATC:

Buyer Added text based ATC clauses

Name of material: Conventional Ballast for HPSV having low loss electromeagnetic ballsts consisting of silicon steel lamination, super enameled copper wire , core & coil embeded in polyester thermosetting compound terminal block with taping of 220/40 V 50 HZAC supply of 250 Watt of bajaj/CGL/Philips/Havells/Surya/Equivalent make.

| | | | |
|----|-----------|---|---|
| 01 | RATE: | : | F.O.R. Destination at 220 KV Sub-Station Partapur (Jagrati Vihar), Meerut. |
| 02 | GST | : | RATES INCLUSIVE OF GST. Anti-Profitteering clause "As per section 171 of GST Act 2017, Any reduction in rate of tax on any supply of goods or service on the benefits of input tax credit shall be passed on to the recipient by way of commensurate reduction in prices. Hence supplier/manufacturer to ensure to pass the benefits of reduced prices to UPPTCL. Further price quoted by supplier/manufacturer is subject to scrutiny under above the section." |
| 03 | DELIVERY | : | Within fifteen days from the date of issue of this order, the above material may be delivered to J.E. of SDO, ETSD-I, Medical College of this division. |
| 04 | PAYMENT | : | shall be made after receipt of material in good condition and check at site for which bill in triplicate duly pre receipted may be sent to his office, along with original copy of order (Bill Copy). |
| 05 | PENALTY | : | @ ½% per week subject to a maximum of 10% on the total value shall be imposed if the material is not supplied within the above noted period. |
| 06 | DISPUTE | : | All dispute relating to the subject matter shall be to the jurisdiction of local court of Meerut. |
| 07 | MATERIAL | : | Defective/inferior Quality material will be rejected and shall have to be replaced free of cost. |
| 08 | GUARANTEE | : | 06 Months All other terms & conditions shall be governed as per UPPCL/UPPTCL form-B currently in force. Please acknowledge the receipt of this order in 02 copies and confirm your acceptance within a week period. One of the original copy of this order is to be submitted with Bill. |

1. Bidder shall provide detail information on litigation or arbitration arising out of contracts completed or under execution by it over last three years with UPPTCL. A history or records involving litigations against the bidder may result in rejection of bid. Bidder shall furnish a self-declaration to this effect, failing which the bid is liable to be rejected.
2. The bidder should not have been black listed or disqualified for non-performance in any of the Government utilities in the past two years as on the date of bid opening and bidder shall furnish self-declaration to this effect, failing which the bid is liable to be rejected.

3. Bidder must have valid Vendor ID and BTS Login ID of UPPTCL, if not, the bidder shall complete the registration process before applying for bid in GEM portal. Bidder shall submit the documentary evidence against the same otherwise the bid liable to be rejected.

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.