

## अनुबंध | Contract



अनुबंध क्रमांक | Contract No: GEMC-511687793977378

अनुबंध तिथि | Generated Date : 16-Jul-2024

<b>संगठन विवरण   Organisation Details</b>		<b>खरीदार विवरण   Buyer Details</b>				
प्ररूप   Type :	State Autonomous	पद   Designation :	Gramsevak			
मंत्रालय   Ministry :	-	संपर्क नंबर   Contact No. :	02427-241231-			
विभाग   Department :	Department of Panchayati Raj	ईमेल आईडी   Email ID :	gpbakupimpalgaon-mh@panchayat.gov.in			
संगठन का नाम   Organisation Name :	AHMEDNAGAR District Panchayats	जीएसटीआईएन   GSTIN :	-			
कार्यालय क्षेत्र   Office Zone:	BAKU PIMPALGAON	पता   Address :	at.post baku pimpalgaon, tel. newasa, AHMED NAGAR, MAHARASHTRA-414603, India			
<b>वित्तीय स्वीकृति विवरण   Financial Approval Detail</b>		<b>भुगतान प्राधिकरण विवरण   Paying Authority Details</b>				
आईएफडी सहमति   IFD Concurrence :	No	Role:	BUYER			
प्रशासनिक अनुमोदन का पदनाम	Gramsevak	भुगतान का तरीका	MOPR			
Designation of Administrative Approval:		Payment Mode:				
वित्तीय अनुमोदन का पदनाम	Gramsevak	पद   Designation :	Gramsevak			
Designation of Financial Approval :		ईमेल आईडी   Email ID :	gpbakupimpalgaon-mh@panchayat.gov.in			
		जीएसटीआईएन   GSTIN :	-			
		पता   Address:	at.post baku pimpalgaon, tel. newasa, Ahmednagar, MAHARASHTRA-414603, India			
<b>विक्रेता विवरण   Seller Details</b>						
जेम विक्रेता आईडी   GeM Seller ID :	QCK7210004295712					
कंपनी का नाम   Company Name :	Varad Enterprises					
संपर्क नंबर   Contact No. :	07020080315					
ईमेल आईडी   Email ID :	langhepravin@gmail.com					
पता   Address :	SHOP NO1,SAI ANAND APPT, NEAR PNB BANK,GULMOHAR ROAD SAVEDI,AHMEDNAGAR, Ahmednagar, MAHARASHTRA-414003, -					
एमएसएमई पंजीकरण संख्या   MSME Registration number :	UDYAM-MH-01-0108185					
एमएसई सामाजिक श्रेणी   MSE Social Category :	OBC					
एमएसई लिंग श्रेणी   MSE Gender :	Male					
जीएसटीआईएन   GSTIN:	27AEBPL1637D1ZW (R)					
*जिसके नाम के पक्ष में GST/TAX इनवॉइस पेश किया जाएगा   GST / Tax invoice to be raised in the name of - Consignee						
वितरण निर्देश   Delivery Instructions : NA						
<b>उत्पाद विवरण   Product Details</b>						
#	आइटम विवरण   Item Description	आइटम विवरण   Ordered Quantity	इकाई   Unit	इकाई मूल्य (INR)   Unit Price (INR)	कर विभाजन (INR)   Tax Bifurcation (INR)	मूल्य (INR में सभी शुल्क और कर सहित)   Price (Inclusive of all Duties and Taxes in INR)
1	उत्पाद का नाम   Product Name : Unbranded RO Water Plant for Hemodialysis 500 Ltrs/Hr Capacity ब्रांड   Brand : NA ब्रांड प्रकार   Brand Type : Unbranded कैटलॉग की स्थिति   Catalogue Status: Catalogue not verified by OEM कैसे बेचा जा रहा है   Selling As : Reseller not verified by OEM श्रेणी का नाम और चतुर्थांश   Category Name & Quadrant : RO Water Plant for Hemodialysis (Q3) मॉडल   Model: Eureka50002 एचएसएन कोड   HSN Code: HSN not specified by seller	1	pieces	30,500	NA	30,500
कुल ऑर्डर मूल्य   Total Order Value (in INR)						30,500
<b>प्रेषिती विवरण   Consignee Detail</b>						
क्र.सं.   S.No	प्रेषिती   Consignee	वस्तु   Item	लॉट नंबर   Lot No.	मात्रा   Quantity	दिनांक के बाद डिलीवरी शुरू करना है   Delivery Start After	वितरण पूरा कब तक करना है   Delivery To Be Completed By
1	पद   Designation : Gramsevak ईमेल आईडी   Email ID : gpbakupimpalgaon-mh@panchayat.gov.in संपर्क   Contact : 02427-241231- जीएसटीआईएन   GSTIN : -	Unbranded RO Water Plant for Hemodialysis	-	1	16-Jul-2024	31-Jul-2024

	पता  Address : at.post baku pimpalgaon, tel. newasa, AHMED NAGAR, MAHARASHTRA-414603, India	500 Ltrs/Hr Capacity				
<b>Product Specification for Unbranded RO Water Plant for Hemodialysis 500 Ltrs/Hr Capacity</b>						
विनिर्देश Specification	उप-विनिर्देश Sub-Spec		मूल्य Value			
GENERAL FEATURES	Clinical Purpose		RO water for hemodialysis to be applied in therapies such as HD, SLED, HDF, HF			
	Product name		RO Water Plant for Hemodialysis			
	Plant capacity (Ltrs/Hr)		500			
	Plant type		Microprocessor/microcontroller controlled dual stage RO water system ( Feed water TDS more than 500 PPM)			
	Various stages in RO water treatment process		Pre-filter or Sediment filter, Carbon filter, Water softner, Reverse Osmosis system, Distribution system, Storage Tank, Ultraviolet disinfection, Final filtration,Final alarms, System monitoring and disinfection			
	System type		Offline			
	System shall have microprocessor based control panel for ease of operation and inbuilt process logic		Yes			
	System shall have auto start/stop based on water level in the supply tank		Yes			
	System shall be equipped with Electrical panel/MCB for plant protection		Yes			
PRE-TREATMENT	Raw water mesh filtering size to prevent big dust/sand particles with back wash control		50 to 200 microns			
	Vertical water tank with automatic water float		Yes			
	Raw water pump with automatic pressure control and run dry protection		Yes			
	Raw water feed pump type		Centrifugal			
	Double raw water pump ( one active and the other stand by)		Yes			
	Raw water feed pump capacity (LPH)		2000			
	Sand/iron filter with 20micron filter and sample valve		Yes			
	Softener for one in operation while the other in standby and vice-versa with sample valve with brain tank and automatic regeneration capacity		Yes			
	Double activated Carbon filter to remove Chlorine and Chloramines with sample valve		Yes			
	Micron particle filter after activated Carbon filter for removing suspended particles more than micron size		5			
	All pretreatment module should be programmable back wash and regeneration facility		Yes			
	Online rotameter for measuring flow		Yes			
	Pressure monitoring facility of all filtering stages with glycerin filled SS pressure gauge		Yes			
	Sample valve facility for all filtering stages		Yes			
RO UNIT FOR MAIN TREATMENT	Distribution of RO plant water sufficient for number of dialysis machines		30-40			
	Monitoring facility for input and output water conductivity, feed water pressure and injection flow rate		Yes			
	Alarm against low feed water, high output conductivity and high temperature of pump motor		Yes			
	Unused water feed back facility to RO unit for saving on water injection in online mode		Yes			
	The unit should be programmable and automatic rinsing/flushing facility at regular intervals when system is not in use, to prevent drying of filter media		Yes			
	Emergency mode operation to run permeate output in case of electronic failure		Yes			
RO MEMBRANE	Efficiency of unit with maximum saving of water (%)		55 to 75			
	Sample valve for permeate		Yes			
	Material of Booster pump (offline)		NA			
	Vertical storage water tank with automatic float control for filling and dry run protection for off-line system		Yes			
	Direct and indirect feed for full close loop distribution piping system		Yes			

POST TREATMENT	Chemical disinfection and decalcification	Semi-automatic
	Provision of volume controlled heat disinfection of permeate loop complied with ISO 15883	Yes
	The permeate should be supplied to distribution loop through 0 point 2 micron bacteria filter for offline system using pex piping and high grade SS316 push pull connectors	Yes
	The distribution loop should contain loop pressure regulator to maintain the desired loop back pressure	Yes
USER INTERFACE	Digital display of values of Conductivity/permeable flow/reject flow/temperature/pressure monitoring	Yes
	Touch screen/button type illuminated display for easy to finger operation of user	Yes
	Signal and control lights with possibility to connect external lights	Yes
	Software update via SD Card or Ethernet	No
	Memory storage device	No
STANDARD CONSUMABLES AND ACCESSORIES	All media and consumables ( membrane, cartidge filter, filter media, chemicals, softner salt) for setting up and standardization should be provided	Yes
	Seller should ensure the availability of all consumables required to run the RO plant during complete warranty period to be purchased by the buyer independently at actual cost	Yes
	UPS of Suitable Capacity to pe provided	No
CERTIFICATIONS & REPORTS	Submission of Test Report for permeate water quality as per AAMI/ISO-13959/13500 from Central Govt/NABL/ILAC accredited Lab to prove the conformity to declared specification after installation	YES
	Product certification	BIS
	Certificate No	15
	Certificate Date	20
	Certificate issuing authority	25
	Four digit number of notified body If product is EU-CE certified	4
	Certification, performance and safety standards specific to the device	IS:13450(Part 1)
	Submission of all the certifications and test reports to the buyer along with supplies on demand	Yes
PRE-INSTALLATION REQUIREMENT FOR THE BUYER	All Pre-installation requirements along with site preparation should be provided by the seller to the buyer well in advance before the supply of equipment	Yes
	All Pre-installation requirements should be done by the buyer	Yes
	Minimum room size required for the plant (H x W x L) m	11X20X20
	Feed water line till RO room	Yes
	Number of drain outlets required	3
	Overhead tank for storage depending on plant size	Yes
	Door width required for RO room (cm)	305
	Airconditioning as per rquirements	Yes
	Power requirements	220-240 VAC, single phase
INSTALLATION & TRAINING	Supplier to perform installation, safety and operation checks before handover	Yes
	Training of users in operation and basic maintenance shall be provided	Yes
WARRANTY & MAINTENANCE	Warranty in Years (Option of comprehensive warranty is available through bidding only, which if opted will supersede normal warranty in the catalogue)	2
	User technical and maintenance manual detailing complete maintaining schedule with routine maintenance should be provided	Yes
	Contact details of manufacturer, supplier and local service agent to be provided	Yes
टिप्पणी   Note:: Seller has given an undertaking that it has made arrangements for getting the stores from an authorized distributor / dealer / channel partner of the OEM of the offered product. At the time of delivery of goods, Seller will provide necessary chain documents (in the form of GST Invoice) to prove that the supplied goods are genuine and are		

being sourced from an authorized distributor / dealer / channel partner of the OEM. In case of any complaint about genuineness of the supplied products, Seller shall be responsible for providing genuine replacement supplies.

## ईपीबीजी विवरण | ePBG Detail

NA

## नियम और शर्तें | Terms and Conditions

### 1. Special terms and conditions- Version:3 effective from 26-06-2024

- 1.1
1. All Provisions of Drugs and Cosmetics Act, 1940 and Rules (including Medical Device Rule 2017) made there under as amended till date will always be applicable. This will include all notifications issued by Central Drugs Standard Control Organization (CDSCO), Ministry of Health & Family Welfare (MoHFW) and Department of Pharmaceuticals (DOP), Ministry of Chemicals & Fertilizers time to time in this regard.
  2. The sellers are registered on GeM based on self-declaration of valid Medical Device License, product certification, test reports etc. However, buyers must check and validate the details at their end for all applicable licenses and certifications e.g., validity and authenticity/genuineness of drug license, product certification, manufacturer certification/licenses, test reports etc.
  3. In case of authorized resellers/distributors, it will be the legal & regulatory liability of the manufacturer to ensure that their resellers/distributors are operating in compliance with all relevant laws and regulations and are properly licensed to sell the manufacturer's products, including verifying the validity and authenticity of drug license held by them.
  4. The price offered by the seller/bidder shall not, in any case exceed the DPCO/NPPA controlled price or price fixed by State Government, if any. The seller must reduce the prices if there is any reduction in DPCO/NPPA ceiling price or price fixed by State Government, if any.
  5. Any other Terms and Conditions which is not included or at variance with the conditions specified in STC/GTC, may be added by the buyer through Additional Terms and Conditions (ATC) in the bid to ensure items are procured from authentic/validated source with appropriate and applicable quality. The above terms and conditions are in reverse order of precedence i.e. ATC shall supersede specific STC which shall supersede General Terms and Conditions (GTC), whenever there are any conflicting provisions.
  6. Comprehensive warranty: Comprehensive warranty shall include preventive maintenance including calibration as per technical/ service /operational manual of the manufacturer, service charges and spares. During the warranty period commencing from date of the successful completion of warranty period, Service personnel shall visit each consignee site as recommended in the manufacturer's technical/ service /operational manual, at least once in six months. warranty shall not be including the consumables. Further there will be 98% uptime warranty during warranty period on 24 (hrs) X 7 (days) X 365 (days) basis, with penalty, to extend warranty period by double the downtime period.
  7. Service centres: Details of Service outlets in India to render services for equipment to be furnished to buyer/consignees with complete address,telephone numbers, e mails etc at time of making the supplies. It shall be the responsibility of seller to ensure that authorized service centres are available to cater to the areas where supplies are made within reasonable distance from where the service calls can be handled.Details of toll-free numbers for service call and online registration of service requests also to be provided buyer/consignee at the time of supplies.
  8. Source of supply: It shall be responsibility of seller to provide Documents regarding source of equipments such as copy of Performa invoice or any other documents to establish that the products supplied are manufactured by OEM indicated and sourced from them.
  9. Packing and Marking: Medical equipments being very delicate and sensitive packing for the goods should be strong and durable enough to withstand transit including transshipment (if any), rough handling, open storage etc. without any damage, deterioration etc. .The size, weights and volumes of the packing cases, remoteness of the final destination of the goods, availability or otherwise of transport and handling facilities at all points during transit up to final destination,. Quality of packing, the manner of marking within & outside the packages and provision of accompanying documentation shall take into consideration the type of medical equipments being supplied. The accessories shall be suitably labelled and packed. Each of the package shall be marked on three sides with indelible paint of proper quality: indicating contract number and date, brief description of goods including quantity, Packing list reference number, country of origin of goods and any other relevant details.
  10. Spare Parts: Seller shall provide materials, information etc. pertaining to spare parts manufactured and supplied by the OEM. It shall be ensured that the required spares are available for purchase at least for 10 years from date of supplies. In case due to any reasons the production of the spare parts is discontinued sufficient advance notice should be given to the buyer/consignee before such discontinuation to provide adequate time to purchase the required spare parts etc. Further, OEM and their service centres/dealers shall carry sufficient inventories to assure ex-stock supply of consumables and spares for the equipments so that the same are available.  
OEM or reseller shall always accord most favoured client status to the buyer/consignee and shall give the most competitive price for spares and consumables of its machines/equipments supplied.
  11. Installation, Training, Manuals: Seller shall be responsible to carry out Installation & commissioning, Supervision and Demonstration of the goods. They shall provide required jigs and tools for assembly, minor civil works for the completion of the installation and Training of Consignee's representatives for operating and maintaining the equipment and supplying required number of operation & maintenance manual for the goods. In case the category parameters are specifying any requirements regarding the installations, training and manuals the same shall also be applicable.
  12. Electrical safety checking: Sellers are required to make sure that they furnish the list of equipments for carrying out routine and preventive maintenance to buyer/consignee .They should make sure to periodically check the electrical safety aspects as per BIS Safety Standards or equivalent .In case they do not have required equipment for such testing should ensure that the equipments checked for electrical safety compliance through labs with facilities for such checking during every preventive maintenance call.
  13. Software: All software updates should be provided free of cost during warranty period.
  14. Any other Terms and Conditions which is not included or at variance with the conditions specified in STC/GTC, may be added by the buyer through Additional Terms and Conditions in the bid to ensure items are procured from authentic/validated source with appropriate and applicable quality. The above terms and conditions are in reverse order of precedence i.e. ATC shall supersede specific STC which shall supersede General Terms and Conditions ("GTC"), whenever there are any conflicting provisions.

### 2. General Terms and Conditions-

- 2.1 This contract is governed by the [General Terms and Conditions](#), conditions stipulated to this Product/Service as provided in the Marketplace.
- 2.2 This Contract between the Seller and the Buyer, is for the supply of the Goods and/ or Services, detailed in the schedule above, in accordance with the General Terms and Conditions (GTC) unless otherwise superseded by Goods / Services specific Special Terms and Conditions (STC) and/ or BID/Reverse Auction Additional Terms and Conditions (ATC), as applicable

नोट: यह सिस्टम जनरेटेड फाइल है। कोई हस्ताक्षर की आवश्यकता नहीं है। इस दस्तावेज़ का प्रिंट आउट भुगतान/लेनदेन उद्देश्य के लिए मान्य नहीं है।

Note: This is system generated file. No signature is required. Print out of this document is not valid for payment/ transaction purpose.

